

Building Assessment Referral Response

Application Number:	DA2025/1488
Proposed Development:	Use of premises as light industry and an industrial retail outlet
Date:	11/11/2025
To:	Claire Ryan
Land to be developed (Address):	Lot 6 SP 52368 , 6 / 161 - 163 South Creek Road CROMER NSW 2099 Lot 7 SP 52368 , 7 / 161 - 163 South Creek Road CROMER NSW 2099

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate. Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Parts 10, 11 & 12 of the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulation 2021.

Building Code of Australia Upgrade requirements and Fire Safety Upgrade

The Building Code of Australia works and fire upgrading measures to upgrade the building as detailed and recommended in the Building Code of Australia Audit Report prepared by BCA Vision, dated 14 September 2025, Report Ref No. P250115 are to be carried out to the building.

Details demonstrating implementation and compliance are to be submitted to the Principal Certifier prior to the issue of any Interim or Final Occupation Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant safety.