



Reference number 5166

Member of the Fire Protection Association of Australia

Lot 1, DP 514756, 52 Collaroy Street, Collaroy, NSW 2097.

Wednesday, 10 September 2025

Prepared by:	Matthew Willis <i>BPAD – Level 3 Certified Practitioner</i> Certification No: BPD-PA 09337		10/09/2025
Can this proposal comply with AS3959-2018 (inc section 7.5, 7.5.1, 7.5.2, 7.5.3, 7.5.4 (where applicable) of the Rural Fire Services document Planning for Bushfire Protection 2019)?	Yes		
What is the recommended AS 3959-2018 level of compliance?	BAL-12.5		
Is referral to the RFS required?	No		
Can this development comply with the requirements of PBP?	Yes		
Plans by "Next Storey Home Additions" (Appendix 1) dated.	11/9/25		

© This document is copyright. It is a breach of copyright for this document to be used to support a development application or any other purpose for any persons/entities other than those for whom this document was prepared. Other than for the purpose for which this document has been prepared and subject to conditions prescribed under the Copyright Act no part of this document may in any form nor by any means be reproduced or stored in a retrieval system or transmitted without the prior written permission of the company (Bushfire Planning Services Pty Ltd ACN 115 714 826).



Bushfire Planning Services

15 Parkcrest Place

Kenthurst NSW 2156

02 96543228

0428408577

mattw@bushfireconsultants.com.au

Bushfire Risk Assessment

Wednesday, 10 September 2025

Contact

Joleen Kelly

Next Storey Home Additions

15/410 Pittwater Road

North Manly NSW 2100

0476 163 596

Subject Property

Lot 1, DP 514756

52 Collaroy Street

Collaroy NSW 2097

Document tracking.

Date	Reason for change	Author

BUSHFIRE RISK ASSESSMENT CERTIFICATE

THIS FORM IS TO BE COMPLETED BY A RECOGNISED CONSULTANT IN BUSHFIRE RISK ASSESSMENT IN ACCORDANCE WITH SECTION 4.14 OF THE ENVIRONMENTAL PLANNING AND ASSESSMENT ACT.

Property Address	Lot 1, DP 514756, number 52 Collaroy Street Collaroy
Description of the Proposal	Alterations and additions to an existing building
Plan Reference	11/9/25
BAL Rating	BAL-12.5
Does the Proposal Rely on Alternate Solutions?	No

I, **Matthew Willis of Bushfire Planning Services Pty Ltd** have carried out a bushfire risk assessment on the above-mentioned proposal and property. A detailed Bushfire Assessment Report is attached which includes the submission requirements set out in Planning for Bushfire Protection 2019 together with recommendations as to how the relevant Specifications and requirements are to be achieved.

I hereby advise, in accordance with Section 4.14 of the Environmental Planning and Assessment Act 1979 No 203:

1. That I am a person recognised by the NSW Rural Fire Service as a qualified consultant in bushfire risk assessment; and

2. That subject to the recommendations contained in the attached Bushfire Risk Assessment Report the proposed development conforms to the relevant specifications and requirements*

*The relevant specifications and requirements being specifications and requirements of the document entitled Planning for Bush Fire Protection prepared by the NSW Rural Fire Service in co-operation with the Department of Planning and any other document as prescribed by Section 4.14 of the Environmental Planning and Assessment Act 1979 No 203.

I am aware that the Bushfire Assessment Report, prepared for the above-mentioned site is to be submitted in support of a development application for this site and will be relied upon by Northern Beaches Council as the basis for ensuring that the bushfire risk management aspects of the proposed development have been addressed in accordance with Planning for Bushfire Protection 2019.

REPORT REFERENCE	<i>Wednesday, 10 September 2025</i>
REPORT DATE	<i>Wednesday, 10 September 2025</i>
CERTIFICATION NO/ACCREDITED SCHEME	<i>FPA A BPAD A BPD-PA 09337</i>

Attachments:

- Bushfire Risk Assessment Report
- Recommendations

SIGNATURE: ---  ----- **DATE:** -----Wednesday, 10 September 2025

Contents.

1	Executive Summary.	5
2	General.	6
3	Block Description.	6
4	Vegetation.	8
5	Known constraints on subject block.	10
6	Slope.	10
7	Utilities.	11
7.1	Water.	11
7.2	Electricity	11
7.3	Gas	11
8	Access/Egress.	11
9	Compliance with Planning for Bushfire Protection setbacks.	12
10	Siting.	12
11	Construction and design.	13
12	Utilities.	13
12.1	Water.	13
12.2	Electricity and Gas.	13
13	Asset Protection Zone (APZ).	13
14	Landscaping.	14
15	Constraints on the subject block.	15
16	Access/Egress.	15
17	Compliance or non compliance with the specifications and requirements for bushfire protection measures.	15
18	Conclusions.	16
19	References.	18
20	Appendix 1 - Plans .	19

1 Executive Summary.

Bushfire Planning Services has been requested by Joleen Kelly from Next Storey Home Additions to supply a bushfire compliance report on lot 1, DP 514756, 52 Collaroy Street, Collaroy.

The works proposed for the subject lot are for the alterations and additions to an existing building, see attached plans for details.

The subject lot is on the northern side of Collaroy Street and at its closest point to the hazard the proposed new work has a separation distance to the south of approximately 79.2m.

The vegetation that is considered to be the hazard to this proposal is situated on land that slopes down slope away from the property at an angle of approximately 19.82°.

For the purposes of this assessment this vegetation is considered to be Rainforest/remnant.

The remaining vegetation within the study area is contained within the boundaries of established allotments and is managed land and of low threat to this proposal.

The calculations and assumptions outlined in this report show that the development will be required to comply with the construction requirements of AS 3959-2018 BAL-12.5 and any additional construction requirements contained within section 7.5, 7.5.1, 7.5.2, 7.5.3, 7.5.4 (where applicable) of the Rural Fire Services document Planning for Bushfire Protection 2019.

The following table is a summary of the pertinent findings of this assessment.

Aspect	North	East	South	West
Vegetation type	Managed land	Managed land	Managed land/rainforest	Managed land
Slope	N/A	N/A	15-20 degrees downslope	N/A
Setback within lot 1	N/A	N/A	29.7m	N/A
Setback outside lot 1	N/A	N/A	49.5m	N/A
Total setback	N/A	N/A	79.2m	N/A
Bal level	N/A	N/A	BAL-12.5	N/A

Note: The above table is a summary of the significant variables used to determine the highest BAL for this proposal. THIS TABLE IS NOT INTENDED FOR CONSTRUCTION! Only the highest BAL level is shown, aspects marked as N/A will still have a BAL. Refer to section 11 for construction requirements for these other aspects.

2 General.

This proposal relates to the alterations and additions to an existing building on the subject lot and its ability to comply with the rules and regulations for building in a bushfire prone area.

The methodology used on this report is based on Planning for Bushfire Protection 2019 (PBP) as published by the New South Wales Rural Fire Service.

Any wording that appears in *blue italics* is quotes from Planning for Bushfire Protection 2019. Some of the measurements used in this report have been taken from aerial photographs and as such are approximate only.

3 Block Description.

The subject block is situated on the northern side of Collaroy Street in an established area of Collaroy.

The lot currently contains a multi-level class 1 dwelling.


The lands surrounding the proposed site on the subject lot to a distance of at least 79.2m contain existing development or land that is otherwise not considered to be a significant bushfire hazard.

- Lot; 1
- DP; 514756.
- LGA; Northern Beaches.
- Area; 585.44m².
- Address; 52 Collaroy Street, Collaroy.

This section has been left blank.



Map 1 shows the cadastral layout around the subject lot.



Map 2 is an extract from the councils' bushfire prone land map. The map shows lot 1 to be within the buffer zone of category 1 bushfire vegetation.

4 Vegetation.

The study area for the vegetation is 140m surrounding the subject block.

The vegetation within the study area for this development is considered to be largely managed land.

The major potential hazard to this development is the vegetation within an area of undeveloped land to the south. The vegetation on the interface of this mapped hazard is highly disturbed and weed infested. The vegetation is considered to be “weeds and exotics” and equal to remnant vegetation for the purpose of compliance with PBP.

For the purpose of this assessment and compliance with Planning for Bushfire Protection this area of undeveloped land is considered to be Rainforest and is the hazard to this proposal.




Photo 1 - An overview of the vegetation within the general area.

This area has been left intentionally blank.




Photo 2 is a closer view of the vegetation in the area.

Table 1 outlines the vegetation orientation and distance from the development area.

Aspect	North	East	South	West
Vegetation type	Managed land	Managed land	Managed land/rainforest	Managed land
Setback within lot 1	N/A	N/A	29.7m	N/A
Off-site setback	N/A	N/A	49.5m	N/A
Total setback	N/A	N/A	79.2m	N/A

Table 1 - Any aspect marked with "N/A" in the table above indicates that it is considered there is none or only a secondary hazard in that direction.

This area has been left intentionally blank.

5 Known constraints on subject block.

I have not been informed or know of any places of cultural or environmental significance within the boundaries of the subject block. Given the nature of the surrounding land it is considered highly unlikely that anything of significance will be affected by this development.

6 Slope.

The slope of the land beneath the hazard that is most likely to influence bushfire behaviour has been calculated by topographical map analysis to a distance of 100m from the subject lot. An extract of the topographical map for the area is shown below and the relevant slope analysis is shown in Table 2.




Table 2 shows the slope beneath the hazard.

Aspect	North	East	South	West
Slope	N/A	N/A	15-20 degrees downslope	N/A


Table 2 - Any aspect marked with "N/A" in the table above indicates that it is considered there is no hazard in that direction.

7 Utilities.

7.1 Water.

The subject block will be serviced by a reticulated water supply.

The following map is an extract from Sydney waters hydrant map. Hydrants are indicated by a blue dot on a blue line. As can be seen there is at least one hydrant point indicated within close proximity of the property.



7.2 Electricity

Main's electricity is available to the block.

7.3 Gas

It is unknown if either bottled or mains gas is to be altered or installed in this proposal.

8 Access/Egress.

Access to the development site will be via a short private driveway from Collaroy Street.

All roads in the vicinity are considered to be capable of carrying emergency services vehicles and pedestrian access onto the lot is also considered to be adequate.

Analysis of development and recommendation.

9 Compliance with Planning for Bushfire Protection setbacks.

Based on the development design, vegetation classification, effective slope estimates and setback distance already outlined in this report the subject development will be required to comply with the deemed to satisfy construction requirements of AS 3959-2018 BAL-12.5 and the RFS requirements on all fire prone aspects.

The following table is an extract from table A1.12.5 of Planning for Bushfire Protection 2019. This table is used to calculate the BAL for a proposal in an area with an FDI of 100.

The variables that have already been outlined in this assessment are highlighted in red with the highest BAL highlighted in yellow.

15-20 DEGREES DOWNSLOPE	Keith Vegetation Formation	BUSHFIRE ATTACK LEVEL (BAL)				
		BAL-FZ	BAL-40	BAL-29	BAL-19	BAL-12.5
	Arid-Shrublands (acacia and chenopod)	< 7	7 -< 10	10 -< 16	16 -< 23	23 -< 100
	Forest (wet and dry sclerophyll) including Coastal Swamp Forest, Pine Plantations and Sub-Alpine Woodland	< 46	46 -< 56	56 -< 73	73 -< 92	92 -< 100
	Forested Wetland (excluding Coastal Swamp Forest)	< 19	19 -< 26	26 -< 37	37 -< 50	50 -< 100
	Freshwater Wetlands	< 6	6 -< 8	8 -< 13	13 -< 18	18 -< 100
	Grassland	< 13	13 -< 17	17 -< 26	26 -< 36	36 -< 50
	Grassy and Semi-Arid Woodland (including Mallee)	< 24	24 -< 32	32 -< 44	44 -< 59	59 -< 100
	Rainforest	< 23	23 -< 30	30 -< 42	42 -< 56	56 -< 100
	Short Heath	< 11	11 -< 15	15 -< 23	23 -< 32	32 -< 100
	Tall Heath	< 19	19 -< 25	25 -< 36	36 -< 49	49 -< 100

For the purpose of this assessment the southern aspect has been chosen as the most potentially hazardous aspect due to the effective slope, potential run of fire and the prevailing fire weather of the area.

10 Siting.

The current site provides adequate separation between the proposed building and surrounding vegetation for a compliant structure to be built.

Recommendation;

Nil.

11 Construction and design.

All new work is to be undertaken in accordance with the relevant requirements of the NCC and AS3959 2018. The following recommendations are a minimum level of construction. Constructing the proposal to a higher level than that recommended is allowable under AS3959.

Recommendation; all new work.

1. New construction shall comply with the requirements of section 3 of Australian Standard AS3959-2018 "Construction of buildings in bush fire-prone areas" and,
2. New construction shall also comply with the requirements of BAL-12.5 Australian Standard AS3959-2018 "Construction of buildings in bush fire-prone areas" or NASH Standard "National Standard Steel Framed Construction in Bushfire Areas" and any additional construction requirements contained within section 7.5, 7.5.1, 7.5.2, 7.5.3, 7.5.4 (where applicable) of the Rural Fire Services document Planning for Bushfire Protection 2019.
3. New roofing valleys and guttering should be fitted with a non-combustible leaf protection to stop the accumulation of debris.

AS-3959 2018 is available as PDF from;

https://infostore.saiglobal.com/en-au/standards/as-3959-2018-122340_saig_as_as_2685241/

12 Utilities.

12.1 Water.

The proposed development will have access to a reticulated water supply. There is at least one hydrant indicated within the required distance from the dwelling.

Recommendation;

Nil.

12.2 Electricity and Gas.

Recommendation;

4. Any new electricity or gas connections are to comply with the requirements of table 7.4a of Planning for Bushfire Protection.

13 Asset Protection Zone (APZ).

The Asset Protection Zone is *"An area surrounding a development managed to reduce the bushfire hazard to an acceptable level. The width of an APZ will vary with slope, vegetation and construction level"*.

Recommendation;

5. At the commencement of building works and in perpetuity the entire property shall be managed as an Asset Protection Zone in accordance with the requirements of Planning for Bushfire Protection, the RFS document Standards for Asset Protection Zones and in a manner that does not create a bushfire hazard to the property.

14 Landscaping.

Recommendation;

6. Any new fencing is to be constructed in accordance with section 7.6 of Planning for Bushfire Protection 2019.
7. Any new landscaping to the site is to comply with the principles of Appendix 4 and section 3.7 of Planning for Bush Fire Protection 2019. In this regard the following landscaping principles are, where applicable, to be incorporated into the development¹:
 - Suitable impervious areas being provided immediately surrounding the building such as courtyards, paths and driveways;
 - Grassed areas/mowed lawns/ or ground cover plantings being provided in close proximity to the building;
 - Restrict planting in the immediate vicinity of the building which may over time and if not properly maintained come in contact with the building;
 - Maximum tree cover should be less than 30%, and maximum shrub cover less than 20%;
 - Planting should not provide a continuous canopy to the building (i.e. trees or shrubs should be isolated or located in small clusters);
 - When considering landscape species consideration needs to be given to estimated size of the plant at maturity;
 - Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
 - Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
 - Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
 - Avoid climbing species to walls and pergolas;
 - Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
 - Locate combustible structures such as garden sheds, pergolas and materials such timber garden furniture way from the building; and
 - Use of low flammability vegetation species.

¹Refer to referenced documents for a complete description.

15 Constraints on the subject block.

None known.

Recommendation;

Nil

16 Access/Egress.

All roads in the area are considered to be capable of handling emergency service vehicles. Access from the roadway onto the property is also considered to be adequate for firefighting purposes.

Recommendation

Nil

17 Compliance or non compliance with the specifications and requirements for bushfire protection measures.

APZ A defensible space is provided onsite. An APZ is provided and maintained for the life of the development.	Achievable with the implementation of the recommendations in section 13
SITING AND DESIGN: Buildings are sited and designed to minimise the risk of bush fire attack.	Achievable with the implementation of the recommendations in section 10
CONSTRUCTION STANDARDS: It is demonstrated that the proposed building can withstand bush fire attack in the form of wind, smoke, embers, radiant heat and flame contact.	Achievable with the implementation of the recommendations in section 11
ACCESS Safe, operational access is provided (and maintained) for emergency services personnel in suppressing a bush fire while residents are seeking to relocate, in advance of a bush fire, (satisfying the intent and performance criteria for access roads in sections 4.1.3 and 4.2.7).	Achievable with the implementation of the recommendations in section 16
WATER AND UTILITY SERVICES: • adequate water and electricity services are provided for firefighting operations	Achievable with the implementation of the recommendations in section 12

• Gas and electricity services are located so as not to contribute to the risk of fire to a building.	
LANDSCAPING: • it is designed and managed to minimise flame contact and radiant heat to buildings, and the potential for wind driven embers to cause Ignitions.	Achievable with the implementation of the recommendations in section 14

18 Conclusions.

Based on the above report and with the implementation of the recommendation contained within this report the consent authority should determine that this development can comply with the requirements of AS 3959-2018 and 'Planning for Bushfire Protection' guidelines.

The recommendations contained within this report are to be implemented in their entirety. Changing one aspect may have an adverse effect on the rest of the recommendations.

Bushfires are affected by many external influences such as climactic conditions, vegetation type, moisture content of the fuel, slope of the land and human intervention to name a few and are difficult to predict.

This report does not intend to provide a guarantee that the subject property will survive if a bushfire should impact the surrounding area. The purpose of this report is to show the developments level of compliance or in some cases non-compliance with the New South Wales legislation regarding building in bushfire prone areas.

Where non-compliance is found measures will be suggested that should make the building less susceptible to the various attack mechanisms of a bushfire and comply with the performance requirements of the Building Code of Australia.

The opinions expressed in this report are based on the writers' experience and interpretation of the relevant guidelines and standards. Notwithstanding the above, these guidelines and standards are open to interpretation. All care has been taken to ensure that the opinions expressed in this report are consistent with past successful outcomes.

Some of the information used in the compilation of this assessment has been provided by the proponent or the proponent's representatives. While we believe this information to be true and have accepted the information in good faith however this company or its representatives will not accept any responsibility if the provided information is determined to be incorrect.

This document is to assist the consenting authorities with their assessment of this proposal. The recommendations contained in this assessment reflect the normal conditions that are typically applied by the consent authority for a proposal such as this however the conditions of consent for the proposal will be supplied by the certifying authority on approval of the development and may not necessarily be the same as the recommendations of this assessment.

The recommendations in this assessment are for planning guidance only, construction details and compliance with all building requirements are the responsibility of the Architect/Designer, Builder and Certifier.

To avoid confusion, unless specifically referenced by the consenting authority, it is strongly recommended that once this proposal has been approved that this document is no longer referenced and that only the official conditions of consent as reflected in documentation by the certifying body are used for construction guidance.

If any further clarification is required for this report, please do not hesitate to contact me using the details above.

Yours Sincerely



Matthew Willis


*Grad Dip Planning for Bushfire Prone Areas
Bushfire Planning Services Pty Limited*


19 References.


- *Australian Building Codes Board (2019). National Construction Code Volume One - Building Code of Australia. ABCB*
- *Australian Building Codes Board (2019). National Construction Code Volume two - Building Code of Australia. ABCB.*
- *Keith, D.A. (2004). Ocean Shores to Desert Dunes: The Native Vegetation of New South Wales and the ACT. NSW Department of Environment and Conservation.*
- *National Association of Steel Framed Housing (2014). "Steel Framed Construction in Bush Fire Areas. NASH*
- *Ramsay, C and Rudolph, L (2003) "Landscape and Building Design for Bush fire Areas". CSIRO Publishing, Collingwood.*
- *Resources and Energy NSW (2016). ISSC 3 Guide for the Managing Vegetation in the Vicinity of Electrical Assets. NSW Government*
- *Rural Fire Service NSW (2005) "Standards for Asset Protection Zones"*
- *Standards Australia (2018). "AS 3959, Construction of buildings in bush fire prone areas".*
- *Standards Australia (2018). "AS/NZS 1530.8.1 Methods for fire tests on building materials, components and structures - Tests on elements of construction for buildings exposed to simulated bush fire attack - Radiant heat and small flaming sources".*
- *Standards Australia (2018). "AS/NZS 1530.8.2 Methods for fire tests on building materials, components and structures - Tests on elements of construction for buildings exposed to simulated bush fire attack - Large flaming sources".*
- *Standards Australia (2014). "AS/NZS 1596 The storage and handling of LP Gas".*


20 Appendix 1 - Plans .


FINISH SCHEDULE				* FLOOR JOISTS, FLOORING, WALL FRAMING AND ROOF FRAMING TO COMPLY WITH THE NATIONAL TIMBER FRAMING CODE																																																									
FIRST FLOOR FLOORING	TIMBER FRAMED PARTICLE BOARD	DOORS	INTERNAL	OAKFIELD HOLLOWCORE PANEL	OWNER	BUILDER																																																							
STUD WALL HEIGHTS	F/F 2440mm HIGH CEILINGS.	EXTERNAL	SUPPLY AND FIX ALUMINIUM STACKER DOOR TO NEW FIRST FLOOR ADDITION. NO FLYSCREENS.		DOOR HANDLES	SUPPLY BY																																																							
FASCIAS & BARGES	200mm X 31mm NON PRE-PAINTED FINGER JOINTED T/P				INSTALL BY	✓																																																							
EAVES	450mm WIDE EAVES FLAT LINED WITH 4.5mm FIBRE CEMENT EAVES SHEET AND PVC JOINING STRIP AND 19mm x 19mm QUAD TO WALL JUNCTION	JOINERY	F/FLOOR	66mm x 18mm FINGER JOINTED PINE BULLNOSE TO SKIRTINGS & ARCHTRAVES.	TOWEL RAIL	SUPPLY BY																																																							
EXTERNAL WALL LININGS	WEATHERTEX LIGHTWEIGHT CLADDING				INSTALL BY	✓																																																							
INTERNAL WALL LININGS	SUPPLY AND FIX GYPROCK PLASTER SHEETING TO WALLS & CEILINGS WITH SQUARE SET.	PLUMBING	1. L DRY - SINK 2. F/F SHR - SHR, VANITY. & WC. 3. F/F ENS - SHR, VANITY. & WC. 4. CONNECT TO EXISTING HOT WATER SERVICE 5. ALL SHOWERS ARE FITTED WITH SAS FLOOR WASTE GRATES.		PLUG & WASTES	SUPPLY BY																																																							
WINDOWS	SUPPLY AND FIX ALUMINIUM WINDOWS TO FIRST FLOOR ADDITION WITH ALUMINIUM FLYSCREENS.				INSTALL BY	✓																																																							
GUTTERING & DOWNPIPES	SUPPLY AND FIX ACE SLOTTED GUTTERING. 90mm DIA PVC DOWNPIPES. CONNECT TO EXISTING SYSTEM	TILING	FIRST FLOOR SHOWER & ENSUITE	PROVIDE FLOOR TILING AND FULL HEIGHT WALL TILING TO ALL WALLS.	TAPWARE	3 STAR SUPPLY BY																																																							
STORMWATER			FIRST FLOOR FRONT & REAR BALCONIES & LAUNDRY	PROVIDE FLOOR TILING.	INSTALL BY	✓																																																							
EXTERNAL STAIRCASE	TO BE SELECTED, WITHIN PC ALLOWANCE.	INSULATION	R 6.0 BRADFORD CEILING INSULATION INSTALLED IN ALL LIVING AREAS UNDER THE ROOF.		TOILET SUITE	3 STAR SUPPLY BY																																																							
ROOF COVERING	COLORBOND CORRUGATED METAL ROOF SHEETING.		R2.5 BRADFORD WALL INSULATION INSTALLED IN ALL EXTERNAL FRAMED WALLS.		INSTALL BY	✓																																																							
		ROBES & WALK IN ROBE	BY OWNER		VANITY UNIT	SUPPLY BY																																																							
					INSTALL BY	✓																																																							
					SHOWER FLOOR GRATE	SUPPLY BY																																																							
					INSTALL BY	✓																																																							
					INTERNAL & EXTERNAL PAINTING	BY OWNER																																																							
A MINIMUM 40% OF NEW LIGHT POINTS ARE TO BE FITTED WITH EITHER FLUORESCENT, COMPACT FLUORESCENT OR LED LAMPS. ALL NEW TIMBER FRAMING TO BE IN ACCORDANCE WITH AUSTRALIAN STANDARD 1684 'RESIDENTIAL TIMBER-FRAMED CONSTRUCTION'. EXTERNAL WALLS & OPENINGS TO COMPLY NCC THIS PLAN CONFORMS WITH BASIX CERTIFICATE NO. A1802356																																																													
SHEET CONTENTS <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sheet No</th> <th>Sheet Name</th> </tr> </thead> <tbody> <tr><td>1</td><td>TITLE PAGE</td></tr> <tr><td>2</td><td>SITE PLAN</td></tr> <tr><td>3</td><td>EXISTING LOWER GROUND FLOOR.</td></tr> <tr><td>4</td><td>EXISTING GROUND FLOOR. DEMOLITION & ALTERATION PLAN</td></tr> <tr><td>5</td><td>PROPOSED FIRST FLOOR</td></tr> <tr><td>6</td><td>NORTH & SOUTH ELEVATIONS</td></tr> <tr><td>7</td><td>EAST ELEVATION</td></tr> <tr><td>8</td><td>WEST ELEVATION</td></tr> <tr><td>9</td><td>SECTIONS A-A & B-B</td></tr> <tr><td>10</td><td>ELECTRICAL LAYOUT</td></tr> <tr><td>11</td><td>SHOWER AND ENSUITE LAYOUT</td></tr> <tr><td>12</td><td>WINDOW SCHEDULE</td></tr> <tr><td>13</td><td>BASIX REPORT CERTIFICATE</td></tr> <tr><td>14</td><td>NOTIFICATION PLAN</td></tr> <tr><td>15</td><td>SITE ANALYSIS PLAN</td></tr> <tr><td>16</td><td>LANDSCAPE PLAN</td></tr> <tr><td>17</td><td>STORMWATER PLAN</td></tr> <tr><td>18</td><td>SITE WORKS MANAGEMENT & SOIL EROSION CONTROL PLAN</td></tr> <tr><td>19</td><td>9am 21st JUNE DIAGRAM</td></tr> <tr><td>20</td><td>12noon 21st JUNE DIAGRAM</td></tr> <tr><td>21</td><td>3pm 21st JUNE DIAGRAM</td></tr> </tbody> </table>							Sheet No	Sheet Name	1	TITLE PAGE	2	SITE PLAN	3	EXISTING LOWER GROUND FLOOR.	4	EXISTING GROUND FLOOR. DEMOLITION & ALTERATION PLAN	5	PROPOSED FIRST FLOOR	6	NORTH & SOUTH ELEVATIONS	7	EAST ELEVATION	8	WEST ELEVATION	9	SECTIONS A-A & B-B	10	ELECTRICAL LAYOUT	11	SHOWER AND ENSUITE LAYOUT	12	WINDOW SCHEDULE	13	BASIX REPORT CERTIFICATE	14	NOTIFICATION PLAN	15	SITE ANALYSIS PLAN	16	LANDSCAPE PLAN	17	STORMWATER PLAN	18	SITE WORKS MANAGEMENT & SOIL EROSION CONTROL PLAN	19	9am 21st JUNE DIAGRAM	20	12noon 21st JUNE DIAGRAM	21	3pm 21st JUNE DIAGRAM											
Sheet No	Sheet Name																																																												
1	TITLE PAGE																																																												
2	SITE PLAN																																																												
3	EXISTING LOWER GROUND FLOOR.																																																												
4	EXISTING GROUND FLOOR. DEMOLITION & ALTERATION PLAN																																																												
5	PROPOSED FIRST FLOOR																																																												
6	NORTH & SOUTH ELEVATIONS																																																												
7	EAST ELEVATION																																																												
8	WEST ELEVATION																																																												
9	SECTIONS A-A & B-B																																																												
10	ELECTRICAL LAYOUT																																																												
11	SHOWER AND ENSUITE LAYOUT																																																												
12	WINDOW SCHEDULE																																																												
13	BASIX REPORT CERTIFICATE																																																												
14	NOTIFICATION PLAN																																																												
15	SITE ANALYSIS PLAN																																																												
16	LANDSCAPE PLAN																																																												
17	STORMWATER PLAN																																																												
18	SITE WORKS MANAGEMENT & SOIL EROSION CONTROL PLAN																																																												
19	9am 21st JUNE DIAGRAM																																																												
20	12noon 21st JUNE DIAGRAM																																																												
21	3pm 21st JUNE DIAGRAM																																																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>ISSUE</th> <th>DATE</th> <th>REVISION</th> <th>PLAN CHECK BY</th> <th>DATE CHECK</th> </tr> </thead> <tbody> <tr> <td>"A"</td> <td>19.08.25</td> <td>DRAFT PLAN</td> <td></td> <td></td> </tr> <tr> <td>"B-2"</td> <td>11.09.25</td> <td>COUNCIL PLAN</td> <td></td> <td></td> </tr> <tr> <td colspan="4" style="text-align: center;">AMENDMENTS</td> <td style="text-align: center;">DATE</td> </tr> <tr> <td>"B-1"</td> <td>ACCURATE GROUND LINES ADDED TO SHOW 8.6m BUILDING HEIGHT</td> <td></td> <td></td> <td>29.08.25</td> </tr> <tr> <td>"B-2"</td> <td>ADDITIONAL INFORMATION AND NOTATION.</td> <td></td> <td></td> <td>11.09.25</td> </tr> </tbody> </table>							ISSUE	DATE	REVISION	PLAN CHECK BY	DATE CHECK	"A"	19.08.25	DRAFT PLAN			"B-2"	11.09.25	COUNCIL PLAN			AMENDMENTS				DATE	"B-1"	ACCURATE GROUND LINES ADDED TO SHOW 8.6m BUILDING HEIGHT			29.08.25	"B-2"	ADDITIONAL INFORMATION AND NOTATION.			11.09.25																									
ISSUE	DATE	REVISION	PLAN CHECK BY	DATE CHECK																																																									
"A"	19.08.25	DRAFT PLAN																																																											
"B-2"	11.09.25	COUNCIL PLAN																																																											
AMENDMENTS				DATE																																																									
"B-1"	ACCURATE GROUND LINES ADDED TO SHOW 8.6m BUILDING HEIGHT			29.08.25																																																									
"B-2"	ADDITIONAL INFORMATION AND NOTATION.			11.09.25																																																									
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5" style="text-align: left;">NEXT STOREY HOME ADDITIONS</th> <th colspan="5" style="text-align: left;">PROPOSED ADDITION AND ALTERATIONS TO RESIDENCE</th> <th colspan="5" style="text-align: left;">COPYRIGHT: THIS PLAN IS EXCLUSIVE PROPERTY OF NEXT STOREY HOME ADDITIONS AND MUST NOT BE USED, REPRODUCED OR COPIED WHOLLY OR IN ANY WAY WITHOUT THE WRITTEN PERMISSION OF THE COMPANY</th> <th colspan="5" style="text-align: left;">MINOR VARIATIONS MAY BE NECESSARY TO FACILITATE CONSTRUCTION OR IMPROVE AESTHETICS. ALL WORK TO BE IN ACCORDANCE WITH NCC VOLUME 2 BUILDING CODE OF AUSTRALIA 2022 AND HOUSING PROVISIONS STANDARD 2022. WRITTEN DIMENSIONS TAKE PRECEDENCE TO SCALE.</th> <th colspan="5" style="text-align: left;">TITLE PAGE</th> <th colspan="5" style="text-align: left;">COUNCIL COPY</th> </tr> <tr> <td colspan="5" style="text-align: left;">  A.C.N. 629 178 689 15415 Pittwater Road, North Manly, NSW 2108. TELEPHONE: (02) 8528 0136 Builders Lic: - 3407356. </td> <td colspan="5" style="text-align: left;"> NAME: MR D. & MRS A. BHIDE ADDRESS: 52 COLLARROY STREET COLLARROY. </td> <td colspan="5" style="text-align: left;"> DATE: 11/09/2025 SCALE: SHEET NO: DRAWING JOB NO: ISSUE: </td> <td colspan="5" style="text-align: left;"> DRAWN BY: NOEL DESIGN BY: MICHAEL </td> <td colspan="5" style="text-align: left;"> SCALED TO FIT @ A3 A3-1 052-COL B-2 </td> </tr> </thead> </table>							NEXT STOREY HOME ADDITIONS					PROPOSED ADDITION AND ALTERATIONS TO RESIDENCE					COPYRIGHT: THIS PLAN IS EXCLUSIVE PROPERTY OF NEXT STOREY HOME ADDITIONS AND MUST NOT BE USED, REPRODUCED OR COPIED WHOLLY OR IN ANY WAY WITHOUT THE WRITTEN PERMISSION OF THE COMPANY					MINOR VARIATIONS MAY BE NECESSARY TO FACILITATE CONSTRUCTION OR IMPROVE AESTHETICS. ALL WORK TO BE IN ACCORDANCE WITH NCC VOLUME 2 BUILDING CODE OF AUSTRALIA 2022 AND HOUSING PROVISIONS STANDARD 2022. WRITTEN DIMENSIONS TAKE PRECEDENCE TO SCALE.					TITLE PAGE					COUNCIL COPY					 A.C.N. 629 178 689 15415 Pittwater Road, North Manly, NSW 2108. TELEPHONE: (02) 8528 0136 Builders Lic: - 3407356.					NAME: MR D. & MRS A. BHIDE ADDRESS: 52 COLLARROY STREET COLLARROY.					DATE: 11/09/2025 SCALE: SHEET NO: DRAWING JOB NO: ISSUE:					DRAWN BY: NOEL DESIGN BY: MICHAEL					SCALED TO FIT @ A3 A3-1 052-COL B-2				
NEXT STOREY HOME ADDITIONS					PROPOSED ADDITION AND ALTERATIONS TO RESIDENCE					COPYRIGHT: THIS PLAN IS EXCLUSIVE PROPERTY OF NEXT STOREY HOME ADDITIONS AND MUST NOT BE USED, REPRODUCED OR COPIED WHOLLY OR IN ANY WAY WITHOUT THE WRITTEN PERMISSION OF THE COMPANY					MINOR VARIATIONS MAY BE NECESSARY TO FACILITATE CONSTRUCTION OR IMPROVE AESTHETICS. ALL WORK TO BE IN ACCORDANCE WITH NCC VOLUME 2 BUILDING CODE OF AUSTRALIA 2022 AND HOUSING PROVISIONS STANDARD 2022. WRITTEN DIMENSIONS TAKE PRECEDENCE TO SCALE.					TITLE PAGE					COUNCIL COPY																																				
 A.C.N. 629 178 689 15415 Pittwater Road, North Manly, NSW 2108. TELEPHONE: (02) 8528 0136 Builders Lic: - 3407356.					NAME: MR D. & MRS A. BHIDE ADDRESS: 52 COLLARROY STREET COLLARROY.					DATE: 11/09/2025 SCALE: SHEET NO: DRAWING JOB NO: ISSUE:					DRAWN BY: NOEL DESIGN BY: MICHAEL					SCALED TO FIT @ A3 A3-1 052-COL B-2																																									


























WINDOW SCHEDULE												
Element ID	Orientation	Window Height (mm)	Window Width (mm)	Window Head Height (mm)	Window Sill Height (mm)	Frame	Sash	Glass	U-v	SHGC	Flyscreens	View from Outside
(W1) ASSD 2130	NORTH	2,100	3,000	2,100	0	ALUMINIUM	STACKER DOOR	CLEAR	7.63	0.75	NO	
(W2) ASSD 2130	NORTH	2,100	3,000	2,100	0	ALUMINIUM	STACKER DOOR	CLEAR	7.63	0.75	NO	
(W3) ASW 1527	EAST	1,500	2,700	2,100	600	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W4) FIX 1527	EAST	1,500	2,700	2,100	600	ALUMINIUM	FIXED	CLEAR	7.63	0.75	NO	
(W5) FIX 1527	EAST	1,500	2,700	2,100	600	ALUMINIUM	FIXED	CLEAR	7.63	0.75	NO	
(W6) ASW 1527	EAST	1,500	2,700	2,100	600	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W7) ASD 2121	SOUTH	2,100	2,100	2,100	0	ALUMINIUM	SLIDING DOOR	CLEAR	7.63	0.75	NO	
(W8) ASD 2121	SOUTH	2,100	2,100	2,100	0	ALUMINIUM	SLIDING DOOR	CLEAR	7.63	0.75	NO	
(W9) ASW 0624	WEST	600	2,400	2,100	1,500	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W10) ASW 0612	WEST	600	1,200	2,100	1,500	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W11) ASW 0612	WEST	600	1,200	2,100	1,500	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W12) ASW 0612	WEST	600	1,200	2,100	1,500	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	
(W13) ASW 0624	WEST	600	2,400	2,100	1,500	ALUMINIUM	SLIDING	CLEAR	7.63	0.75	YES	

**NOTE: DIMENSIONS IN THE WINDOW SCHEDULE ARE NOMINAL SIZES ONLY.
THE INSTALLER IS TO CONFIRM EXACT DIMENSIONS WITH THE WINDOW MANUFACTURER.**

	NEXT STOREY HOME ADDITIONS	PROPOSED ADDITION AND ALTERATIONS TO RESIDENCE	COPYRIGHT: THIS PLAN IS EXCLUSIVE PROPERTY OF NEXT STOREY HOME ADDITIONS AND MUST NOT BE USED, REPRODUCED OR COPIED WHOLLY OR IN ANY WAY WITHOUT THE WRITTEN PERMISSION OF THE COMPANY	MINOR VARIATIONS MAY BE NECESSARY TO FACILITATE CONSTRUCTION OR IMPROVE AESTHETICS. ALL WORK TO BE IN ACCORDANCE WITH NCC VOLUME 2 BUILDING CODE OF AUSTRALIA 2022 AND HOUSING PROVISIONS STANDARD 2022. WRITTEN DIMENSIONS TAKE PRECEDENCE TO SCALE.	WINDOW SCHEDULE		COUNCIL COPY	
	A.C.N. 628 178 889 15/410 Pittwater Road, North Manly, NSW 2100. TELEPHONE: (02) 8526 0136. Builders Lic - 340735C.				DATE: 11/09/2025	SCALE: SCALED TO FIT @ A3	SHEET NO: A3-12	DRAWING JOB NO: 052-COL

Fixtures and systems	
Lighting	The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light emitting diode (LED) lamps.
Fixtures	The applicant must ensure new or altered showheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. The applicant must ensure new or altered toilets have a flow rate no greater than 6 litres per average flush or a minimum 3 star toilet rating. The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.

Construction		
Insulation requirements The applicant must construct the new or altered construction (Roofs, walls, and ceilings/windows) in accordance with the specifications listed below. However, except that if additional insulation is not required where the area of new construction is less than 20%, insulation specification is not required for parts of altered construction where insulation already exists.		
Construction	Additional insulation required (R-value)	Other specifications
floor above existing dwelling or building	nil	N/A
external wall: framed (weatherboard, fibre, metal etc)	R 1.26 (or R 1.70 including construction)	
external wall: framed (weatherboard, fibre, metal etc)	R 1.26 (or R 1.70 including construction)	
external wall: framed (weatherboard, fibre, metal etc)	R 1.26 (or R 1.70 including construction)	
external wall: framed (weatherboard, fibre, metal etc)	R 1.26 (or R 1.70 including construction)	
external wall: framed (weatherboard, fibre, metal etc)	R 1.26 (or R 1.70 including construction)	
raised ceiling: phidolamium not structural	ceiling R0.80 (g) roof: full covering	dark colour absorbance > 0.70

Glazing requirements

Windows and glazed doors

The applicant must install the windows, glazed doors and sliding doors, in accordance with the specifications listed in the table below. **Relevant overhead power lines** must be avoided near the window and glazed door.

The following requirements must also be satisfied in relation to window and glazed door:

- Each window or glazed door must standard aluminium or timber frames and single clear or tinted glass may either match the decoration, or use a *Lavigne* and a *Solar Guard* Heat Coefficient (SHGC) is greater than that listed in the table below. **Not** colors and SHGC must be determined in accordance with National Performance Rating Council (NPRC) conditions.
- For pre-painted doors and windows, the finishing edge of paint, varnish, varnish, lacquer or varnish must be no less than 0.05 mm above the head of the window or glazed door and no less than 2400 mm above the sill.
- Partials with polycarbonate or of similar translucent material must have a shading coefficient of less than 0.35.

External louvers and blinds must fully shade the window or glazed door beneath when they are situated when fully drawn or closed.

Partials with fixed battens shall have battens parallel to the window or glazed door above which they are situated, unless the partial is a sliding door or window.

Windows and glazed doors glazing requirements						
Window/unit number	Orientation	Area of glass including frame (m ²)	Overhead/sloping height (m)	Overhead/sloping distance (m)	Shading device	Frame and glass type
W1	N	8.3	0	0	none vertical perpendicularity =>600 mm	standard Aluminium single glaze, or U-value 1.8, SHGC 0.75
W2	N	8.3	0	0	none vertical perpendicularity =>600 mm	standard Aluminium single glaze, or U-value 1.8, SHGC 0.75
W3	E	4.08	0	0	external louvre blind (adjustable)	standard Aluminium single glaze, or U-value 1.8, SHGC 0.75
W4	E	4.08	0	0	external louvre blind (adjustable)	standard Aluminium single glaze, or U-value 1.8, SHGC 0.75
W5	E	4.08	0	0	external louvre blind (adjustable)	standard Aluminium single glaze, or U-value 1.8, SHGC 0.75

Glazing requirements						
Window/door number	Orientation	Area of glass (m ²)	Overhang/depth (mm)	Overhang/depth (mm)	Shading device	Frame and glass type
W6	E	4.32	0	0	external louvre (adjustable)	standard aluminium, single glaze U-value: 7.0 g-value: 0.75
W7	E	4.41	0	0	external louvre (adjustable)	standard aluminium, single glaze U-value: 7.0 g-value: 0.75
W8	E	4.41	0	0	external louvre (adjustable)	standard aluminium, single glaze U-value: 7.0 g-value: 0.75
W9	W	1.44	0	0	external louvre (adjustable)	standard aluminium, single glaze U-value: 7.0 g-value: 0.75
W10	E	0.72	0	0	external louvre (adjustable)	standard aluminium, single glaze U-value: 7.0 g-value: 0.75

Glazing requirements						
Windows and glazed doors glazing requirements						
Window/door number	Orientalion	Area of glass (square metres (m ²))	Overheadshading height (m)	Overheadshading distance (m)	Shading device	Frame and glass type
W11	W	0.72	0	0	external bamboo blind (adjustable)	standard aluminium, single pane U-value 7.7 SHGC 0.7
W12	W	0.72	0	0	external bamboo blind (adjustable)	standard aluminium, single pane U-value 7.7 SHGC 0.7
W13	W	1.44	0	0	external bamboo blind (adjustable)	standard aluminium, single pane U-value 7.7 SHGC 0.7

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a  in the "Does an applicant have to comply with this commitment?" column must be shown on the plans accompanying the development application for the proposed development if a development application is to be submitted for the proposed development.

Commitments identified with a  in the "Does an applicant have to comply with this commitment?" column must be shown in the plans and specifications accompanying the application for a variation certificate complying development certificate for the proposed development.

Commitments identified with a  in the "Certificate holder" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development can be issued.



**PROPOSED ADDITION AND ALTERATIONS
TO RESIDENCE**
NAME: MR D. & MRS A. BHIDE
ADDRESS: 52 COLLAROY STREET COLLAROY.

COPYRIGHT:
THIS PLAN IS EXCLUSIVE PROPERTY OF
NEXT STOREY HOME ADDITIONS
AND MUST NOT BE USED, REPRODUCED OR
COPIED WHOLLY OR IN ANY WAY WITHOUT
THE WRITTEN PERMISSION OF THE COMPANY

MINOR VARIATIONS MAY BE NECESSARY TO FACILITATE CONSTRUCTION OR IMPROVE AESTHETICS.

ALL WORK TO BE IN ACCORDANCE WITH NCC VOLUME 2 BUILDING CODE OF AUSTRALIA 2022 AND HOUSING PROVISIONS STANDARD 2022.

Y WRITTEN DIMENSIONS TAKE PREFERENCE TO SCALE

BASIX REPORT CERTIFICATE			COUNCIL COPY		
DATE	11/09/2025	SCALE	SHEET NO	DRAWING JOB NO	ISSUE
DRAWN BY: NOEL DESIGN BY: MICHAEL		SCALED TO FIG. A-2	A3-13	052-COL	B-2

