

Natural Environment Referral Response - Coastal

Application Number:	DA2019/1007
Responsible Officer	Nick England
Land to be developed (Address):	Lot 1 DP 1205310 , 67 Marine Parade AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development.

The proposed development is in line with the objects, as set out under Clause 3 of *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

As the subject site has been identified as being within the coastal zone and therefore SEPP (Coastal Management) 2018 is also applicable to the proposed development.

The subject site has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps but not been included on the Coastal Vulnerability Area Map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

Comment:

As assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Vaughan Milligan Development Consulting Pty. Ltd dated August 2019 and Council accepts the assessment, the DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018

Pittwater LEP 2014 and Pittwater 21 DCP

The subject site is also shown to be affected by Coastline Bluf/Cliff Instability Hazard on Council's
DA2019/1007

Coastal Risk Planning Map in Pittwater LEP 2014 and the relevant provisions of the Geotechnical Risk Management Policy for Pittwater and the B3.4 Coastline (Bluff) Hazard controls in P21 DCP will apply to new development of the site.

A Geotechnical Report by White Geotechnical Group Pty. Ltd. dated 21/08/2019 assessing coastline (bluff)/ coastal cliff or slope instability has been submitted with the DA. The report assessed that 'considering the large width of the rock platform, the large volume of armouring sandstone rubble at the cliff base, and distance and elevation to the proposed works, the current accepted predicted sea level rise for the next century is not expected to lead to significant undercutting that could impact the proposed works' . .

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP. .

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Coastal Bluff Engineering Assessment Implementation

The advice and recommendations contained in the approved Geotechnical Risk Management Report prepared by White Geotechnical Group Pty. Ltd. dated 21 August 2019 submitted in support of the development application, must be incorporated as required into construction plans and structural specifications for the development.

Reason: To ensure potential hazards associated with development on a Coastal Bluff are minimised

Coastal Bluff Engineering Assessment Implementation

All development or activities must be designed and constructed such that they will not increase the level of risk from coastal processes for any people, assets or infrastructure in surrounding properties; they will not adversely affect coastal processes; they will not be adversely affected by coastal processes.

Reason: To ensure potential hazards associated with development on a Coastal Bluff are minimised

Engineers Certification of Plans

The structural design shall be prepared by and each plan/sheet signed by, a registered professional civil or structural engineer with chartered professional status (CP Eng) who has an appropriate level of professional indemnity insurance and shall be submitted to the Principal Certifying Authority prior to the release of the Construction Certificate.

Reason: To ensure structural engineering is prepared by an appropriately qualified professional