

Natural Environment Referral Response - Coastal

Application Number:	DA2023/1245
Proposed Development:	Demolition works and construction of a dwelling house including swimming pool
Date:	05/10/2023
Responsible Officer	Claire Ryan
Land to be developed (Address):	Lot 40 DP 13760 , 212 Hudson Parade CLAREVILLE NSW 2107 Lot PO 6770 , 212 Hudson Parade CLAREVILLE NSW 2107

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Resilience & Hazards) 2021 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.10, 2.11 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Nolan Planning Consultants dated August 2023, the DA satisfies requirements under clauses 2.10, 2.11 and 2.12 of the SEPP R&H. As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

Pittwater LEP 2014 and Pittwater 21 DCP

Estuarine Risk Management

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Nolan Planning Consultants dated August 2023 the ground floor level for the proposed additions and alterations is above the applicable EPL for the site. The proposed development is therefore not required to satisfy the relevant estuarine risk management requirements of P21 DCP.

Development on Foreshore Area

A section of the subject property is within the foreshore building line. Part 7, Clause 7.8 –Limited development on foreshore area of the Pittwater LEP 2014 applies for any development within the foreshore area.

The DA proposes construction of swimming pool and paving works within the foreshores area. All these proposed works are consistent with Clause 7.8(2)(b).

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Nolan Planning Consultants dated August 2023, the DA satisfies the objectives and requirements of Part 7, Clause 7.8 of the Pittwater LEP 2014.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site

are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site