

Sent:	10/03/2023 5:01:06 PM
Subject:	NSW RFS Determination - Your Reference - Mod2022/0699 CNR-50123
Attachments:	DA20200924003482-S4.55-1 - 09-03-2023 10_13_20 - Determination Letter.pdf;



NSW RURAL FIRE SERVICE

Attention: Northern Beaches Council

Your Reference: Mod2022/0699 CNR-50123

Application Details: s100B – Subdivision – S4.55

Site Address:

45 Oxford Falls Road
Beacon Hill NSW 2100

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Craig Casey on 1300 NSW RFS and quote DA20200924003482-S4.55-1.



Planning and Environment Services

NSW RURAL FIRE SERVICE

Locked Bag 17 Granville NSW 2142

P 1300 NSW RFS **E** records@rfs.nsw.gov.au

www.rfs.nsw.gov.au | www.facebook.com/nswrfs | www.twitter.com/nswrfs

PREPARE. ACT. SURVIVE.



NSW RURAL FIRE SERVICE

Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: Mod2022/0699 CNR-50123
Our reference: DA20200924003482-S4.55-1

ATTENTION: Northern Beaches Council

Date: Friday 10 March 2023

Dear Sir/Madam,

Integrated Development Application

s100B – Subdivision – Torrens Title Subdivision

45 Oxford Falls Road Beacon Hill NSW 2100, 1//DP206629, 2//DP203664, 18//DP19022, 3//DP206629, 4//DP206629, 2//DP1039953, 1//DP1039953

I refer to your correspondence dated 21/02/2023 seeking general terms of approval for the above Integrated Development in accordance with s4.55 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the submitted amended information. General Terms of Approval are now re-issued, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions.

Asset Protection Zones

Intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

1. At the issue of a subdivision certificate and until Lot 2 is developed, the lot must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover; and
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

General Advice - Consent Authority to Note

- This approval is for the subdivision of the land only. Future applications for the development of lots created within this subdivision will be subject to further assessment under the *Environmental Planning & Assessment Act 1979*.

This letter is in response to an assessment of the application based on the submitted further information and supersedes our previous general terms of approval dated 16/10/2020.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Built & Natural Environment



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

Subdivision – Torrens Title Subdivision

45 Oxford Falls Road Beacon Hill NSW 2100, 1//DP206629, 2//DP203664, 18//DP19022, 3//DP206629,
4//DP206629, 2//DP1039953, 1//DP1039953

RFS Reference: DA20200924003482-S4.55-1

Your Reference: Mod2022/0699 CNR-50123

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority supersedes the previous Bush Fire Safety Authority DA20200924003482-Original-1 issued on 16/10/2020 and confirms that, subject to the attached reissued General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Nika Fomin

Manager Planning & Environment Services
Built & Natural Environment

Friday 10 March 2023