
Sent: 11/10/2024 2:44:26 PM
Subject: NSW RFS Determination - Your Reference - (CNR-70920) DA2024/0857
Attachments: DA20240906003685-Original-1 - 11-10-2024 14_27_40 - Determination Letter.pdf;



NSW RURAL FIRE SERVICE



Attention: Northern Beaches Council

Your Reference: (CNR-70920) DA2024/0857

Application Details: s100B – Subdivision – Original

Site Address:

96 Wakehurst Parkway
Elanora Heights NSW 2101

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Craig Casey on 1300 NSW RFS and quote DA20240906003685-Original-1.



Planning and Environment Services

NSW RURAL FIRE SERVICE

Locked Bag 17 Granville NSW 2142

P 1300 NSW RFS **E** records@rfs.nsw.gov.au

www.rfs.nsw.gov.au | www.facebook.com/nswrfs | www.twitter.com/nswrfs

PREPARE. ACT. SURVIVE.



RFS



Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: (CNR-70920) DA2024/0857
Our reference: DA20240906003685-Original-1

ATTENTION: Northern Beaches Council

Date: Friday 11 October 2024

Dear Sir/Madam,

**Integrated Development Application
s100B - Subdivision - Strata Title Subdivision
96 Wakehurst Parkway Elanora Heights NSW 2101, 2//DP815540**

I refer to your correspondence dated 11/09/2024 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

Intent of measures: to provide sufficient space and maintain reduced fuel loads to ensure radiant heat levels at the buildings are below critical limits and prevent direct flame contact.

1. At the issue of a subdivision certificate, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire site, must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover; and
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

1

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au



RFS



2. At the issue of a subdivision certificate, suitably worded instrument(s) created pursuant to section 88 of the *Conveyancing Act 1919* must be placed on the proposed lot 2, (rear lot) which requires the provision of an 11m asset protection zone (APZ), within the subject lot, running parallel to the northern site boundary and prohibits the construction of buildings other than class 10b structures within the APZ. The name of authority empowered to release, vary or modify the instrument shall be Northern Beaches Council.

Construction Standards

Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

3. Both existing dwellings, located on proposed Lots 1 & 2 being retained, must be upgraded to improve ember protection by enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any sub floor areas, openable windows, vents, weepholes and eaves. External doors are to be fitted with draft excluders.

Access – Property Access

Intent of measures: to provide safe operational access to structures and water supply for emergency services, while residents are seeking to evacuate from an area.

4. Property access road (driveway) must comply with the general requirements of Table 5.3b of *Planning for Bush Fire Protection 2019* and the following:

- property access roads are two-wheel drive, all-weather roads;
- minimum 4m carriageway width;
- a minimum vertical clearance of 4m to any overhanging obstructions, including tree branches;
- maximum grades for sealed roads do not exceed 15 degrees and not more than 10 degrees for unsealed roads;
- provide a suitable turning area in accordance with Appendix 3; and
- Some short constrictions in the access may be accepted where they are not less than 3.5m wide, extend for no more than 30m and where the obstruction cannot be reasonably avoided or removed.

Water and Utility Services

Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

5. The provision of water, electricity and gas must comply with the following in accordance with Table 5.3c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
 - a) lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and



RFS



b) no part of a tree is closer to a power line than the distance set out in accordance with the specifications in *ISSC3 Guideline for Managing Vegetation Near Power Lines*.

- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - The storage and handling of LP Gas, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

General Advice - Consent Authority to Note

- This assessment is based on the applicants proposed subdivision plan, as prepared by Paul Barry Byrne, Surveyor, Reference No: 11263SD and Issue A; and,
- Council is advised that this approval is for the subdivision of the land only. Any further development application for class 1,2 & 3 buildings as identified by the *National Construction Code of Australia* may be subject to separate application under section 4.14 of the *EP & A Act* and address the requirements of *Planning for Bush Fire Protection 2019*.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Adam Small
Manager Planning & Environment Services
Built & Natural Environment



RFS



BUSH FIRE SAFETY AUTHORITY

Subdivision – Strata Title Subdivision

96 Wakehurst Parkway Elanora Heights NSW 2101, 2//DP815540

RFS Reference: DA20240906003685-Original-1

Your Reference: (CNR-70920) DA2024/0857

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Adam Small

Manager Planning & Environment Services
Built & Natural Environment

Friday 11 October 2024

