

Water Management Referral Response

Application Number:	DA2024/1091
Proposed Development:	Demolition works and construction of a mixed use development with basement parking comprising of retail uses and a childcare centre, including signage
Date:	26/06/2025
To:	Claire Ryan
Land to be developed (Address):	Lot 5 S/P 32656 , 5 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 5 S/P 32656 , 5 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot B DP 385973 , 3 Careel Head Road AVALON BEACH NSW 2107 Lot 3 S/P 32656 , 3 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 3 S/P 32656 , 3 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 7 S/P 32656 , 7 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 7 S/P 32656 , 7 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 1 S/P 32656 , 1 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 1 S/P 32656 , 1 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 4 S/P 32656 , 4 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 4 S/P 32656 , 4 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 6 S/P 32656 , 6 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 6 S/P 32656 , 6 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 2 S/P 32656 , 2 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot 2 S/P 32656 , 2 / 1 Careel Head Road AVALON BEACH NSW 2107 Lot CP SP 32656 , 1 Careel Head Road AVALON BEACH NSW 2107

Reasons for referral

Council's Water Management Officers are required to consider the likely impacts.

Officer comments

Supported

This application has been reviewed with reference to the following:

- Supplied plans and supporting documentation
- Northern Beaches Water Management for Development Policy (WMD Policy)
- Applicable clauses of the Local Environmental Plan (LEP) and Development Control Plan (DCP)

The proposed stormwater treatment system integrates water conservation measures, including harvesting, reuse, and filtration components. The design has been assessed as satisfactory and complies with the General Stormwater Quality requirements set out in Table 5 of the Water Management Development (WMD) Policy.

The development includes a basement level. According to the submitted geotechnical report, groundwater interception is anticipated; accordingly, a tanked basement design is recommended to mitigate potential impacts.

WaterNSW has issued a General Terms of Approval (Reference: IDAS1161280), which specifies the conditions to be satisfied as part of the development.

Additionally, a dewatering permit must be obtained from Council prior to the commencement of any construction activities.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Water Management Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Erosion and Sediment Control Plan

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities)
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls that must include sediment fences, stabilised site access, materials and waste stockpiles locations, location of any stormwater pits on the site and how they are going to be protected.
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifier for approval prior to the issue of

the Construction Certificate.

Reason: Protection of the receiving environment.

Detailed Design of Stormwater Treatment Measures - Major

A certificate from a Civil Engineer, stating that the stormwater treatment measures have been designed in accordance with the stormwater concept plans from CIVIL & STORMWATER ENGINEERING SERVICES PTY LTD PLANS (rev.05 dated 17/06/25) and Council's Water Management for Development Policy.

The certificate shall be submitted to the Certifier prior to the release of the Construction Certificate.

Reason: Protection of the receiving environment.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Certification for the Installation of Stormwater Treatment Measures

A certificate from a Civil Engineer, who has membership to Engineers Australia and the National Engineers Register must be provided, stating that the stormwater treatment measures have been installed in accordance with construction certificate approved plans. The certificate must confirm that stormwater treatment measures are completed, online, in good condition and are not impacted by sediment.

The certificate shall be submitted to the Principal Certifier prior to the release of an Occupation Certificate.

Reason: Protection of the receiving environment.

Positive Covenant, Restriction as to User and Registration of Encumbrances for Stormwater Treatment Measures

A positive covenant shall be created on the title of the land requiring the proprietor of the land to maintain the stormwater treatment measures in accordance with the standard requirements of Council, the manufacturer and as required by the Stormwater Treatment Measures Operation and Maintenance Plan.

A restriction as to user shall be created on the title over the stormwater treatment measures, restricting

any alteration to the measures.

The terms of the positive covenant and restriction as to user are to be prepared to Council's standard requirements (available from Council) at the applicant's expense and endorsed by the Northern Beaches Council's delegate prior to lodgement with the Department of Lands. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user is to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To identify encumbrances on land, ensure ongoing maintenance, and ensure modification to the stormwater treatment measures is not carried out without Council's approval.

Stormwater Treatment Measures Operation and Maintenance Plan

An Operation and Maintenance Plan is to be prepared to ensure the proposed stormwater treatment measures remain effective.

The Plan must be attached to the Positive Covenant (and the community or strata management statement if applicable) and contain the following:

1. Detail on the stormwater treatment measures:
 - a) Work as executed drawings
 - b) Intent of the stormwater treatment measures including modelled pollutant removal rates
 - c) Site detail showing catchment for each device
 - d) Vegetation species list associated with each type of vegetated stormwater treatment measure
 - e) Impervious area restrictions to maintain the water balance for the site
 - f) Funding arrangements for the maintenance of all stormwater treatment measures
 - g) Identification of maintenance and management responsibilities
 - h) Maintenance and emergency contact information
2. Maintenance schedule and procedure - establishment period of one year following commissioning of the stormwater treatment measure:
 - a) Activity description, and duration and frequency of visitsAdditionally for vegetated devices:
 - b) Monitoring and assessment to achieve an 80 percent survival rate for plantings
 - c) Management of weeds, pests and erosion, with weed and sediment cover limited to a maximum of 5 percent of the total area of the stormwater treatment measure
3. Maintenance schedule and procedure - ongoing
 - a) Activity description, and duration and frequency of visits
 - b) Routine maintenance requirements
 - c) Work Health and Safety requirements
 - d) Waste management and disposal
 - e) Traffic control (if required)

- f) Renewal, decommissioning and replacement timelines and activities of all stormwater treatment measures (please note that a DA may be required if an alternative stormwater treatment measure is proposed)
- g) Requirements for inspection and maintenance records, noting that these records are required to be maintained and made available to Council upon request.

Details demonstrating compliance shall be submitted to the Principal Certifier prior to the release of the Occupation Certificate.

Reason: Protection of the receiving environment.

Works as Executed Drawings - Stormwater Treatment Measures

Works as Executed Drawings for the stormwater treatment measures must be prepared in accordance with Council's Guideline for Preparing Works as Executed Data for Council Stormwater Assets.

The drawings shall be submitted to the Principal Certifier prior to the release of the Occupation Certificate.

Reason: Protection of the receiving environment.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Maintenance of Stormwater Treatment Measures

Stormwater treatment measures must be maintained at all times in accordance with the Stormwater Treatment Measure Operation and Maintenance Plan, manufacturer's specifications and as necessary to achieve the required stormwater quality targets for the development.

Where replacement cartridges or other necessary components for the system become unavailable, an alternative system is required to be retrofitted into the development to achieve an equivalent pollutant reduction outcome. Evidence supporting the replacement must be retained on site and made available to Council as required.

Northern Beaches Council reserves the right to enter the property and carry out appropriate maintenance of the device at the cost of the property owner.

Reason: Protection of the receiving environment.