FLOWER POWER, TERREY HILLS

CIVIL ENGINEERING PACKAGE DEVELOPMENT APPLICATION





DRAWING SCHEDULE

DRG No. DRAWING TITLE

DAC1.01 COVER SHEET, DRAWING SCHEDULE AND LOCALITY PLAN

DAC1.11 SPECIFICATION NOTES

DAC2.01 SEDIMENT AND SOIL EROSION CONTROL PLAN

DAC2.11 SEDIMENT AND SOIL EROSION CONTROL DETAILS

SITEWORKS AND GRADING PLAN

DAC3.01 BULK EARTHWORKS CUT AND FILL PLAN

DAC4.02 STORMWATER MANAGEMENT PLAN

DAC5.01 STORMWATER CATCHMENT PLAN

DAC6.01 STORMWATER MANAGEMENT DETAILS - SHEET 01

DAC6.03 STORMWATER MANAGEMENT DETAILS - SHEET 03

STORMWATER MANAGEMENT DETAILS - SHEET 02

NOT FOR CONSTRUCTION

KE AISION	DESCRIPTION	122050	VERD	APP
01	ISSUED FOR INFORMATION	MM		A
02	ISSUED FOR INFORMATION	MM		A


DRAWING NOT TO BE USED FOR CONSTRUCTION UNLESS VERIFICATION

23.05.23

15.06.23

LEFFLER SIMES ARCHITECTS

THE COPYRIGHT OF THIS DRAWING REMAINS WITH NORTHROP





Sydney
Level 11 345 George Street, Sydney NSW 2000
Ph (02) 9241 4188 Fax (02) 9241 4324
mail sydney@northrop.com.au ABN 81 094 433 100

FLOWER POWER 277 MONA VALE ROAD, TERREY HILLS NSW CIVIL ENGINEERING PACKAGE

COVER SHEET, DRAWING SCHEDULE AND LOCALITY PLAN

DRAWING NUMBER

REVIS

DRAWING NUMBER REVISION

DACO1.01 02

DRAWING SHEET SIZE = A1

GENERAL NOTES

THESE DRAWINGS SHALL BE READ IN CONJUNCTION WITH OTHER CONSULTANTS' DRAWINGS AND SPECIFICATIONS AND WITH OTHER SUCH WRITTEN INSTRUCTIONS AS MAY BE ISSUED DURING THE COURSE OF THE CONTRACT. ANY DISCREPANCY SHALL BE REFERRED TO THE ENGINEER BEFORE PROCEEDING WITH THE WORK.

ALL DIMENSIONS ARE IN MILLIMETRES & ALL LEVELS ARE IN METRES, UNO (UNLESS NOTED OTHERWISE).

NO DIMENSION SHALL BE OBTAINED BY SCALING THE DRAWINGS.

ALL LEVELS AND SETTING OUT DIMENSIONS SHOWN ON THE DRAWINGS SHALL BE CHECKED ON SITE PRIOR TO THE COMMENCEMENT OF THE WORK.

DETAIL SURVEY DATA WAS SUPPLIED BY: BOXALL SURVEYORS

REF. NUMBER: 10115-002 REVISION DATE: 01.06.2021

REVISION NUMBER: A GEOCENTRIC DATUM OF AUSTRALIA: GDA94

SURVEYOR: BC APPROVED: SL

EXISTING SERVICES WHERE SHOWN HAVE BEEN PLOTTED FROM SUPPLIED DATA AND SUCH THEIR ACCURACY CAN NOT BE GUARANTEED. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ESTABLISH THE LEVEL OF ALL EXISTING SERVICES PRIOR TO THE COMMENCEMENT OF WORK.

ON COMPLETION OF STORMWATER INSTALLATION, ALL DISTURBED AREAS MUST BE RESTORED TO ORIGINAL CONDITION, INCLUDING KERBS, FOOTPATHS, CONCRETE AREAS, GRAVEL AND GRASSED AREAS AND ROAD PAVEMENTS, UNLESS DIRECTED OTHERWISE.

ALL STORMWATER MANAGEMENT MEASURES SHOWN ON THIS DRAWING HAVE BEEN PREPARED FOR DEVELOPMENT APPLICATION PURPOSES TO DEMONSTRATE FEASIBILITY. ALL MEASURES WILL BE SUBJECT TO DETAIL DESIGN AT THE CONSTRUCTION CERTIFICATE STAGE AND MAY BE SUBJECT TO VARIATION PROVIDED THAT THE DESIGN INTENT IS MAINTAINED.

STORMWATER DRAINAGE

- 1. ALL DRAINAGE LINES SHALL BE UPVC (CLASS SN4) SEWER GRADE DRAINAGE PIPE, U.N.O.
- 2. ALL DRAINAGE LINES SHALL BE LAID AT 1% MIN. FALL, UNO.
- 3. ALL LEVELS ARE AUSTRALIAN HEIGHT DATUM (AHD).
- 4. ALL DOWNPIPES GUTTERS TO BE DESIGNED IN ACCORDANCE WITH AS/NZS 3500.3.2 - 2003 'STORMWATER' DRAINAGE
- THE STORMWATER DRAINAGE DESIGN HAS BEEN CARRIED OUT IN ACCORDANCE WITH AS/NZS 3500.3.2-2003 'STORMWATER' DRAINAGE.
- 6. ANY VARIATIONS TO THE NOMINATED LEVELS SHALL BE REFERRED TO ENGINEER IMMEDIATELY.
- SUBSOIL DRAINAGE SHALL BE PROVIDED TO ALL RETAINING WALLS & EMBANKMENTS, WITH THE LINES FEEDING INTO THE STORMWATER DRAINAGE SYSTEM.
- 8. ALL GRATES TO BE GALVANISED STEEL WITH HINGES AND CHILD PROOF LOCK.
- 9. THE STORMWATER DRAINAGE IS DESIGNED IN ACCORDANCE WITH NORTHERN BEACHES COUNCIL WATER MANAGEMENT FOR DEVELOPMENT POLICY 2021.

RAINWATER RE-USE

- PROVIDE RAINWATER RE-USE SYSTEM TO SUPPLY WATER FOR TOILET FLUSHING AND IRRIGATION
- 2. GUTTER GUARD TO BE INSTALLED ON ALL EAVES GUTTERS.
- A PERMANENT SIGN IS TO BE LOCATED IN THE VICINITY OF THE TANK STATING THE WATER IS "NON POTABLE WATER" WITH APPROPRIATE HAZARD IDENTIFICATION.
- 4. PIPEWORK USED FOR RAINWATER SERVICES SHALL BE COLOURED LILAC IN ACCORDANCE WITH AS1345.
- ALL VALVES AND APERTURES SHALL BE CLEARLY AND PERMANENTLY LABELLED WITH SAFETY SIGNS TO COMPLY WITH AS1319.
- 6. RAINWATER TANK RETICULATION SYSTEM AND MAINS WATER BYPASS ARRANGEMENT TO BE INSTALLED IN ACCORDANCE WITH AS/NZS 3500.1.2-2003 AND THE NSW CODE OF PRACTICE: PLUMBING AND DRAINING.
- 7. A FIRST FLUSH FILTRATION DEVICE IS TO BE PROVIDED AT RAINWATER TANK.

DESIGN SUMMARY

SITE DISCHARGE CALCULATIONS:

l			20% AEP	<u>5% AEP</u>	<u>1% AEP</u>
	PRE-DEVELOPMENT	0.364 m³/s	0.688 m³/s	1.115 m³/s	
	POST-DEVELOPMENT	0.284 m³/s	0.495 m³/s	0.937 m ³ /s	

ON-SITE DETENTION:

PRE TO POST DEVELOPMENT CONDITIONS

ON-SITE DETENTION SUMMARY: BELOW GROUND BLOCK WORK TANK

TOP WATER LEVEL = RL196.150 OVERFLOW LEVEL = RL195.900 ORIFICE CENTERLINE = RL194.345 ORIFICE DIAMETER = Ø350mm

RAINWATER RE-USE:

IN ACCORDANCE WITH BASIX/COUNCIL REQUIREMENTS. RAINWATER RE-USE STORAGE PROVIDED IS TO BE DESIGNED

RAINWATER RE-USE TO BE USED FOR THE FOLLOWING;

 TOILET FLUSHING; IRRIGATION.

STORMWATER MANAGEMENT REQUIREMENTS HAVE BEEN CALCULATED IN ACCORDANCE WITH NORTHERN BEACHES COUNCIL WATER MANAGEMENT PLAN FOR DEVELOPMENT POLICY 2021: PART 9.0 ONSITE STORMWATER MANAGEMENT.

WATER QUALITY:

MUSIC MODEL SUMMARY (REFER NORTHROP REPORT FOR FURTHER DETAILS).

TREATMENT NODES:

- RAINWATER RE-USE TANK
- 'OCEANGUARD' PIT INSERTS (OR SIMILAR)
- FILTER CARTRIDGES

MUSIC MODEL PARAMETERS IN ACCORDANCE WITH NORTHERN BEACHES COUNCIL'S MUSIC MODELLING GUIDELINES 2016.

CONCEPT SOIL & WATER MANAGEMENT

- 1. ALL WORK IS TO BE CARRIED OUT IN ACCORDANCE WITH RELEVANT ORDINANCES AND REGULATIONS; NOTE IN PARTICULAR THE REQUIREMENTS OF LANDCOMS MANAGING URBAN STORMWATER, SOILS AND CONSTRUCTION' (THE 'BLUE BOOK'). THIS SOIL AND WATER MANAGEMENT PLAN DETAILS THE ACTIONS TO BE TAKEN FOR THE MANAGEMENT AND DEWATERING OF STORMWATER DURING CONSTRUCTION OF THE PROPOSED BUILDING.
- INSTALL SEDIMENT PROTECTION FILTERS ON ALL NEW AND EXISTING STORMWATER INLET PITS IN ACCORDANCE WITH EITHER THE MESH AND GRAVEL INLET FILTER DETAIL SD6-11 OR THE GEOTEXTILE INLET
- FILTER DETAIL SD6-12 OF THE 'BLUE BOOK'. 3. ESTABLISH ALL REQUIRED SEDIMENT FENCES IN ACCORDANCE WITH DETAIL SD6-8 OF THE 'BLUE BOOK'.
- 4. INSTALL SEDIMENT FENCING AROUND INDIVIDUAL BUILDING ZONES/AREAS AS REQUIRED AND AS DIRECTED BY THE
- SUPERINTENDENT. 5. ALL TRENCHES INCLUDING ALL SERVICE TRENCHES AND SWALE EXCAVATION SHALL BE SIDE-CAST TO THE HIGH SIDE AND CLOSED AT THE END OF EACH DAYS WORK.
- THE CONTRACTOR SHALL ENSURE THAT ALL VEGETATION (TREE, SHRUB & GROUND COVER) WHICH IS TO BE RETAINED SHALL BE PROTECTED DURING THE DURATION OF CONSTRUCTION. REFER ARCHITECTS PLANS FOR TREES TO BE KEPT.
- 7. ALL VEGETATION TO BE REMOVED SHALL BE MULCHED ONSITE AND SPREAD/STOCKPILED AS DIRECTED BY THE SUPERINTENDENT.
- 8. STRIP TOPSOIL IN AREAS DESIGNATED FOR STRIPPING AND STOCKPILE FOR RE-USE AS REQUIRED. ANY SURPLUS MATERIAL SHALL BE REMOVED FROM SITE AND DISPOSED OF IN ACCORDANCE
- WITH EPA GUIDELINES. 9. CONSTRUCT AND MAINTAIN ALL MATERIAL STOCKPILES IN ACCORDANCE WITH DETAIL SD4-1 OF THE 'BLUE BOOK' (INCLUDING CUT-OFF SWALES TO THE HIGH SIDE AND SEDIMENT FENCES TO THE
- LOW SIDE). 10. ENSURE STOCKPILES DO NOT EXCEED 2.0m HIGH. PROVIDE WIND AND
- RAIN EROSION PROTECTION AS REQUIRED IN ACCORDANCE WITH THE 'BLUE BOOK'.
- 11. PROVIDE WATER TRUCKS OR SPRINKLER DEVICES DURING CONSTRUCTION AS REQUIRED TO SUPPRESS DUST.
- 12. ONCE CUT/FILL OPERATIONS HAVE BEEN FINALIZED ALL DISTURBED AREAS THAT ARE NOT BEING WORKED ON SHALL BE RE-VEGETATED AS SOON AS IS PRACTICAL.
- 13. THE CONTRACTOR SHALL BE RESPONSIBLE FOR KEEPING A DETAILED WRITTEN RECORD OF ALL EROSION & SEDIMENT CONTROLS ON-SITE DURING THE CONSTRUCTION PERIOD. THIS RECORD SHALL BE UPDATED ON A DAILY BASIS & SHALL CONTAIN DETAILS ON THE CONDITION OF CONTROLS AND ANY/ ALL MAINTENANCE, CLEANING & BREACHES. THIS RECORD SHALL BE KEPT ON-SITE AT ALL TIMES AND SHALL BE MADE AVAILABLE FOR INSPECTION BY THE PRINCIPAL CERTIFYING AUTHORITY AND THE SUPERINTENDENT DURING NORMAL WORKING
- 14. GROUNDWATER SEEPAGE RATES AND QUALITY TO BE MONITORED AND TREATED IF REQUIRED DURING CONSTRUCTION IN ACCORDANCE WITH REQUIREMENTS OF SUPERVISING GEOTECHNICAL ENGINEER.

NOT FOR CONSTRUCTION

CIVIL ENGINEERING PACKAGE

SPECIFICATION NOTES

FLOWER POWER

277 MONA VALE ROAD,

TERREY HILLS NSW

211979

DRAWING NUMBER DRAWING SHEET SIZE = A1


DESCRIPTION ISSUED FOR INFORMATION 23.05.23 AC 15.06.23 ISSUED FOR INFORMATION

DRAWING NOT TO BE USED FOR CONSTRUCTION UNLESS VERIFICATION

SIGNATURE HAS BEEN ADDED

ARCHITECT


LEFFLER SIMES ARCHITECTS




DIMENSIONS TO BE VERIFIED WITH THE ARCHITECT

Level 11 345 George Street, Sydney NSW 2000 Ph (02) 9241 4188 Fax (02) 9241 4324 sydney@northrop.com.au ABN 81 094 433 100

THE COPYRIGHT OF THIS DRAWING REMAINS WITH NORTHROP





GENERAL NOTES

- ALL WORKS TO BE CARRIED OUT IN ACCORDANCE WITH COUNCIL / RELEVANT AUTHORITY SPECIFICATIONS AND
- 2. ALL SEDIMENT AND SOIL EROSION CONTROL MEASURES TO BE INSTALLED IN ACCORDANCE WITH THE 'BLUE BOOK'.
 CONTRACTOR TO ENSURE THESE MEASURES ARE IN PLACE AND MAINTAINED AT ALL TIMES DURING CONSTRUCTION
- 3. CONTRACTOR TO PROVIDE 'WIRE MESH AND GRAVEL SEDIMENT FILTER' TO ALL PAVED / ROAD AREAS (BOTH PROPOSED AND EXISTING) IN ACCORDANCE WITH THE 'BLUE
- BOOK'.

 4. CONTRACTOR TO PROVIDE 'GEOTEXTILE INLET FILTER TRAPS'
 TO ALL STORMWATER DRAINAGE INLETS (BOTH PROPOSED

AND EXISTING) IN ACCORDANCE WITH THE 'BLUE BOOK'

SEDIMENT BASIN C	ALCULATIONS			
PARAMETER	ADOPTED VALUE			
TOTAL DISTURBED AREA (ha)	2.3644			
SOIL TEXTURE GROUP	D OR F			
DESIGN RAINFALL DEPTH (DAYS)	5			
DESIGN RAINFALL DEPTH (PERCENTILE)	80%			
x-DAY, y-PERCENTILE RAINFALL EVENT	35.2			
Cv	0.42			
SETTLING ZONE VOLUME (m³)	349.550			
SEDIMENT STORAGE VOLUME (m³)	174.775			
TOTAL BASIN VOLUME REQUIRED (m³)	524.325			


NOT FOR CONSTRUCTION

01	ISSUED FOR INFORMATION	MM	AC	23.05.23	
02	ISSUED FOR INFORMATION	MM	AC	15.06.23	
					i



LEFFLER SIMES ARCHITECTS

THE COPYRIGHT OF THIS DRAWING REMAINS WITH NORTHROP





Sydney

Level 11 345 George Street, Sydney NSW 2000
Ph (02) 9241 4188 Fax (02) 9241 4324

Email sydney@northrop.com.au ABN 81 094 433 100

FLOWER POWER 277 MONA VALE ROAD, TERREY HILLS NSW CIVIL ENGINEERING PACKAGE

SEDIMENT AND SOIL EROSION CONTROL PLAN

JOB NUMBER
211979

DRAWING NUMBER REV

DAC02.01 02


DRAWING NUMBER REVISION

DAC02.01 02

CONSTRUCTION NOTES

- 1. THE TEMPORARY ACCESS SHALL BE MAINTAINED IN A CONDITION THAT PREVENTS TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS OF WAY,
- THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL GRAVEL AS CONDITIONS DEMAND AND REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT,
- 2. ALL SEDIMENT SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS OF WAY MUST BE REMOVED IMMEDIATELY.
- 3. INSTALL BARRIER ON EITHER SIDE OF SHAKER PAD. TO ENSURE VEHICLES ARE GUIDED ON TO THE PAD.
- 4. INVERT OF SHAKER PAD TO BE DRAINED VIA AGRICULTURAL PIPE WRAPPED IN GEOTEXTILE FABRIC.


STABILISED SITE ACCESS



CONSTRUCTION NOTES

- 1. INSTALL FILTERS TO KERB INLETS ONLY AT SAG POINTS.
- 2. FABRICATE A SLEEVE MADE FROM GEOTEXTILE OR WIRE MESH LONGER THAN THE LENGTH OF THE INLET PIT
- AND FILL IT WITH 25mm TO 50mm GRAVEL. 3. FORM AN ELLIPTICAL CROSS-SECTION ABOUT 150mm HIGH x 400mm WIDE.
- 4. PLACE THE FILTER AT THE OPENING LEAVING AT LEAST A 100mm SPACE BETWEEN IT AND THE KERB INLET. MAINTAIN THE OPENING WITH SPACER BLOCKS.
- FORM A SEAL WITH THE KERB TO PREVENT SEDIMENT BYPASSING THE FILTER.
- 6. SANDBAGS FILLED WITH GRAVEL CAN SUBSTITUTE FOR THE MESH OR GEOTEXTILE PROVIDING THEY ARE PLACED SO THAT THEY FIRMLY ABUT EACH OTHER AND SEDIMENT-LADEN WATERS CANNOT PASS BETWEEN.


WIRE MESH AND GRAVEL SEDIMENT FILTER



CONSTRUCTION NOTES

- CONSTRUCT SEDIMENT FENCES AS CLOSE AS POSSIBLE TO BEING PARALLEL TO THE CONTOURS OF THE SITE. BUT WITH SMALL RETURNS AS SHOWN IN THE DRAWING TO LIMIT THE CATCHMENT AREA OF ANY ONE SECTION. THE CATCHMENT AREA SHOULD BE SMALL ENOUGH TO LIMIT WATER FLOW IF CONCENTRATED AT ONE POINT TO 50 LITRES PER SECOND IN THE DESIGN STORM EVENT, USUALLY THE 10-YEAR EVENT.
- 2. CUT A 150mm DEEP TRENCH ALONG THE UPSLOPE LINE OF THE FENCE FOR THE BOTTOM OF THE FABRIC TO BE ENTRENCHED.
- 3. DRIVE 1.5 METRE LONG STAR PICKETS INTO GROUND AT 2.5 METRE INTERVALS (MAX) AT THE DOWNSLOPE EDGE OF THE TRENCH. ENSURE ANY STAR PICKETS ARE FITTED WITH SAFETY CAPS.
- 4. FIX SELF-SUPPORTING GEOTEXTILE TO THE UPSLOPE SIDE OF THE POSTS ENSURING IT GOES TO THE BASE OF THE TRENCH. FIX THE GEOTEXTILE WITH WIRE TIES OR AS RECOMMENDED BY THE MANUFACTURER. ONLY USE GEOTEXTILE SPECIFICALLY PRODUCED FOR SEDIMENT FENCING. THE USE OF SHADE CLOTH FOR THIS PURPOSE IS NOT SATISFACTORY.
- 5. JOIN SECTIONS OF FABRIC AT A SUPPORT POST WITH A 150mm OVERLAP.
- 6. BACKFILL THE TRENCH OVER THE BASE OF THE FABRIC AND COMPACT IT THOROUGHLY OVER THE GEOTEXTILE.


SEDIMENT FENCE



CONSTRUCTION NOTES

- 1. FABRICATE A SEDIMENT BARRIER MADE FROM GEOTEXTILE OR STRAW BALES.
- 2. FOLLOW STANDARD DRAWING 6-7 AND STANDARD DRAWING 6-8 FOR INSTALLATION PROCEDURES FOR THE STRAW BALES OR GEOFABRIC. REDUCE THE PICKET SPACING TO 1 METRE CENTRES.
- 3. IN WATERWAYS, ARTIFICIAL SAG POINTS CAN BE CREATED WITH SANDBAGS OR EARTH BANKS AS SHOWN IN THE DRAWING.
- 4. DO NOT COVER THE INLET WITH GEOTEXTILE UNLESS THE DESIGN IS ADEQUATE TO ALLOW FOR ALL WATERS TO BYPASS IT.


GEOTEXTILE INLET FILTER TRAPS



CONSTRUCTION NOTES

- BUILD WITH GRADIENTS BETWEEN 1 AND 5 PERCENT.
- 2. AVOID REMOVING TREES AND SHRUBS IF POSSIBLE WORK AROUND THEM.
- 3. ENSURE THE STRUCTURES ARE FREE OF PROJECTIONS OR OTHER IRREGULARITIES THAT COULD IMPEDE WATER FLOW.
- 4. BUILD THE DRAINS WITH CIRCULAR, PARABOLIC OR TRAPEZOIDAL CROSS SECTIONS, NOT V SHAPED.
- 5. ENSURE THE BANKS ARE PROPERLY COMPACTED TO PREVENT FAILURE.
- 6. COMPLETE PERMANENT OR TEMPORARY STABILISATION WITHIN 10 DAYS OF CONSTRUCTION.


NOTE: ONLY TO BE USED AS TEMPORARY BANK WHERE MAXIMUM UPSLOPE LENGTH IS 80 METRES. TEMPORARY DRAINAGE SWALE



CONSTRUCTION NOTES

- 1. PLACE STOCKPILES MORE THAN 2m (PREFERABLY 5m) FROM EXISTING VEGETATION, CONCENTRATED WATER FLOW, ROADS AND HAZARD AREAS.
- 2. CONSTRUCT ON THE CONTOUR AS LOW, FLAT, ELONGATED MOUNDS.
- 3. WHERE THERE IS SUFFICIENT AREA, TOPSOIL STOCKPILES SHALL BE LESS THAN 2m IN HEIGHT.
- 4. WHERE THEY ARE TO BE IN PLACE FOR MORE THAN 10 DAYS, STABILISE FOLLOWING THE APPROVED ESCP OR SWMP TO REDUCE THE C-FACTOR TO LESS THAN 0.10.
- 5. CONSTRUCT EARTH BANKS (STANDARD DRAWING 5-5) ON THE UPSLOPE SIDE TO DIVERT WATER AROUND STOCKPILES AND SEDIMENT FENCES (STANDARD DRAWING 6-8) 1 TO 2m DOWNSLOPE.

STOCKPILE



- 1. REMOVE ALL VEGETATION AND TOPSOIL FROM UNDER THE DAM WALL AND FROM WITHIN THE STORAGE AREA. 2. CONSTRUCT A CUT-OFF TRENCH 500mm DEEP AND 1200mm WIDE ALONG THE CENTRELINE OF THE EMBANKMENT
- EXTENDING TO A POINT ON THE GULLY WALL LEVEL WITH THE RISER CREST.
- MAINTAIN THE TRENCH FREE OF WATER AND RECOMPACT THE MATERIALS WITH EQUIPMENT AS SPECIFIED IN THE SWMP TO 95 PER CENT STANDARD PROCTOR DENSITY.
- 4. SELECT FILL FOLLOWING THE SWMP THAT IS FREE OF ROOTS, WOOD, ROCK, LARGE STONE OR FOREIGN MATERIAL.
- 5. PREPARE THE SITE UNDER THE EMBANKMENT BY RIPPING TO AT LEAST 100mm TO HELP BOND COMPACTED FILL TO THE EXISTING SUBSTRATE.
- 6. SPREAD THE FILL IN 100mm TO 150mm LAYERS AND COMPACT IT AT OPTIMUM MOISTURE CONTENT FOLLOWING THE
- 7. CONSTRUCT THE EMERGENCY SPILLWAY.
- 8. REHABILITATE THE STRUCTURE FOLLOWING THE SWMP.

(APPLIES TO 'TYPE D' AND 'TYPE F' SOILS ONLY) SEDIMENT BASIN

NOT FOR CONSTRUCTION

REVISION	DESCRIPTION	ISSUED	VER'D	APP'D	DATE
01	ISSUED FOR INFORMATION	MM		AC	23.05.23
02	ISSUED FOR INFORMATION	MM		AC	15.06.23

DRAWING NOT TO BE USED FOR CONSTRUCTION UNLESS VERIFICATION

SIGNATURE HAS BEEN ADDED

ARCHITECT

LEFFLER SIMES ARCHITECTS

THE COPYRIGHT OF THIS DRAWING REMAINS WITH NORTHROP

CONSULTING ENGINEERS PTY LTD.

LL SETOUT TO ARCHITECT'S DRAWINGS, DIMENSIONS TO BE VERIFIED WITH THE ARCHITECT AND ON SITE BEFORE MAKING SHOP DRAWINGS OF COMMENCING WORK. NORTHROP ACCEPTS NO RESPONSIBILITY FOR THE USABILITY, COMPLETENESS OR SCALE OF DRAWINGS TRANSFERRED ELECTRONICALLY.

NOT TO SCALE

Level 11 345 George Street, Sydney NSW 2000 Ph (02) 9241 4188 Fax (02) 9241 4324 Email sydney@northrop.com.au ABN 81 094 433 100



FLOWER POWER 277 MONA VALE ROAD, **TERREY HILLS NSW**


CIVIL ENGINEERING PACKAGE


SEDIMENT AND SOIL EROSION **CONTROL DETAILS**


211979


DRAWING NUMBER


DRAWING SHEET SIZE = A1














NOT FOR CONSTRUCTION

211979

DRAWING SHEET SIZE = A1

DRAWING NUMBER

DRAWING TITLE

CIVIL ENGINEERING PACKAGE

STORMWATER MANAGEMENT

DETAILS - SHEET 02

FLOWER POWER

277 MONA VALE ROAD,

TERREY HILLS NSW

TRENCH WIDTH = 0.D. + 300mm

TYPICAL PIPE TRENCH - GENERAL AREAS

1. TRENCH WIDTH MAY NEED TO BE INCREASED SUBJECT TO ACHIEVING COMPACTION. ENSURE MINIMUM 300mm CLEARANCE BETWEEN, WHEN USING MULTIPLE PIPES TO

3. THE CONTRACTOR SHALL ENSURE THAT SHORING OF TRENCHES IS INSTALLED AS

SCALE 1:10

DATE

15.06.23

4. ENSURE BACKFILLING COMPACTION MEETS THE FOLLOWING STANDARDS;
4.1. TRENCHES UNDER PAVED AREAS / BUILDING – 100% SMDD

COMPACTED BACKFILL -

OVERLAY ZONE, COMPACTED —

REINFORCED CONCRETE PIPE

- NOM 10mm AGGREGATE

BED ZONE, SELECT FILL -- NOM 10mm AGGREGATE

SUBGRADE MATERIAL –

HAUNCH ZONE, COMPACTED SELECT FILL-

ACHIEVE ADEQUATE COMPACTION.

DESCRIPTION

ISSUED FOR INFORMATION

REQUIRED BY STATUTORY REQUIREMENTS.

4.2. TRENCHES NOT UNDER PAVEMENTS – 95% SMDD

2. MINIMUM PIPE COVER NOT UNDER ROADS TO BE 300mm U.N.O.

ORDINARY FILL

