

## Environmental Health Referral Response - Solid Fuel Heaters

<b>Application Number:</b>	DA2025/0681
<b>Proposed Development:</b>	Alterations and additions to a dwelling house including a swimming pool
<b>Date:</b>	07/07/2025
<b>Responsible Officer</b>	Lachlan Rose
<b>Land to be developed (Address):</b>	Lot 26 DP 6413 , 2 Cecil Street FAIRLIGHT NSW 2094

### Reasons for referral

This application requires detailed consideration of solid fuel heaters. And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

### Officer comments General Comments

The development proposes to incorporate a fireplace chimney into the dwelling on the eastern side.

The position of this chimney is appropriate and supported by Environmental Health with a recommendation of a number of conditions of consent.

### Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Environmental Investigations Conditions:

#### **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

#### **Installation and certification of solid/fuel burning heater**

The solid fuel heater must be certified to comply with Australian Standards 4012 and 4013.

Provide to the Principal Certifier certification that the solid fuel heater has been installed by an appropriately experienced and qualified person, in accordance with the relevant provisions of AS2918 – Domestic Solid Fuel Burning Appliances – Installation.

Reason: To ensure the installation is completed in a legislatively compliant manner.

#### **Installation of solid/fuel burning heaters**

Installation work must be carried out by an appropriately experienced and qualified person and in

accordance with the relevant provisions of AS2918 – Domestic Solid Fuel Burning Appliances – Installation

Reason: To ensure the installation is completed in a legislatively compliant manner.

## **ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES**

### **Maintenance of solid fuel heaters**

The owner/occupier shall ensure servicing of the heater is maintained according to the manufacturer's specifications.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

### **Operation of solid fuel burning heaters**

The owner/operator must take all practicable measures to prevent the likelihood of causing smoke and/or odour nuisances. Such measures must include:

- Using dry seasoned hardwood
- Storing wood in a dry well-ventilated place
- Having a hot and well oxygenated fire
- Ensuring that the chimney flue is clean
- Checking the chimney at different stages of the fire to see if there is any smoke
- Maintenance according to the manufacturer's specifications

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.