

DEVELOPMENT APPLICATION ASSESSMENT REPORT

Application Number:	DA2021/1399
----------------------------	-------------

Responsible Officer:	Clare Costanzo
Land to be developed (Address):	Lot 1 DP 1068612, 776 - 780 Pittwater Road BROOKVALE NSW 2100
Proposed Development:	Construction of business identification signage
Zoning:	Warringah LEP2011 - Land zoned B5 Business Development
Development Permissible:	Yes
Existing Use Rights:	No
Consent Authority:	Northern Beaches Council
Land and Environment Court Action:	No
Owner:	AMHA Properties Pty Ltd
Applicant:	Camden Signage And Building Services Pty Ltd

Application Lodged:	17/08/2021
Integrated Development:	No
Designated Development:	No
State Reporting Category:	Commercial/Retail/Office
Notified:	24/08/2021 to 07/09/2021
Advertised:	Not Advertised
Submissions Received:	0
Clause 4.6 Variation:	Nil
Recommendation:	Approval

Estimated Cost of Works:	\$ 205,000.00
---------------------------------	---------------

PROPOSED DEVELOPMENT IN DETAIL

The proposal comprises of the replacement of five existing fascia business identification signs with seven like for like new business identification signs. The signage will be illuminated, with the illumination level to be the same as the existing signage.

The following signs are proposed to be replaced (approx. dimensions):

- Sign 1 (26.3m²) - south eastern elevation of south eastern building
- Sign 2 (88m²) - south eastern elevation of south eastern building
- Sign 4 (19.7m²) - southern elevation of north western building
- Sign 5 (13.5m²) - south western elevation of south eastern building
- Sign 7 13.5m²) - north eastern elevation of south eastern building

- Sign 8 (1.5m²) - southern elevation of north western building
- Sign 9 (1.5m²) - southern elevation of western building

The new signage will be visible for vehicles and pedestrians along Pittwater Road and Carter Street. The flanking elements of the proposed signage along Pittwater Road will be supported by structural steel supports in the ground.

The existing awning on the southern portion of the building fronting Pittwater Road will be removed as part of the development application to facilitate the new signage.

ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral to relevant internal and external bodies in accordance with the Act, Regulations and relevant Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

SUMMARY OF ASSESSMENT ISSUES

Warringah Local Environmental Plan 2011 - Zone B5 Business Development
 Warringah Local Environmental Plan 2011 - 4.3 Height of buildings
 Warringah Development Control Plan - C9 Waste Management
 Warringah Development Control Plan - D10 Building Colours and Materials
 Warringah Development Control Plan - D12 Glare and Reflection

SITE DESCRIPTION

Property Description:	Lot 1 DP 1068612 , 776 - 780 Pittwater Road BROOKVALE NSW 2100
Detailed Site Description:	<p>The subject allotment is located on the south eastern side of Pittwater Road and is on land zoned B5 Business Development as per the Warringah Local Environment Plan 2011.</p> <p>The site has a surveyed area of 6,871m² with a frontage to Pittwater Road of 115.58 metres and 146.04 metres to</p>

Carter Road.

Surrounding development generally consists of other vehicle sale premises and industrial uses. The general character of the area is dated architecture however surrounding sites are gradually being updated.

The site does not have any evident contour or topographical features. There is some landscaping on site with planter beds consisting of small shrubs fronting to Pittwater Road.

Map:



SITE HISTORY

The land has been used for commercial purposes for an extended period of time. A search of Council's records has revealed the following relevant history:

- Development Application DA2013/0594 for the construction of a vehicle sales showroom was approved by Council under delegation on the 17 July 2013
- Mod2016/0107 Modification of Development Consent DA2013/0594 granted for construction of a vehicle sales showroom
- Mod2016/0133 Modification of Development Consent DA2013/0594 granted for construction of a vehicle sales showroom was approved by Council under delegation on the 8 August 2016
- Development Application DA2016/0994 for the installation of new signage was approved by Council under delegation on the 8 November 2016

ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

Section 4.15 Matters for Consideration'	Comments
Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument	See discussion on “Environmental Planning Instruments” in this report.
Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument	Draft State Environmental Planning Policy (Remediation of Land) seeks to replace the existing SEPP No. 55 (Remediation of Land). Public consultation on the draft policy was completed on 13 April 2018. The subject site has been used for residential purposes for an extended period of time. The proposed development retains the residential use of the site, and is not considered a contamination risk.
Section 4.15 (1) (a)(iii) – Provisions of any development control plan	Warringah Development Control Plan applies to this proposal.
Section 4.15 (1) (a)(iiia) – Provisions of any planning agreement	None applicable.
Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2000 (EP&A Regulation 2000)	<p><u>Division 8A</u> of the EP&A Regulation 2000 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.</p> <p><u>Clause 50(1A)</u> of the EP&A Regulation 2000 requires the submission of a design verification certificate from the building designer at lodgement of the development application. This clause is not relevant to this application.</p> <p><u>Clauses 54 and 109</u> of the EP&A Regulation 2000 allow Council to request additional information. No additional information was requested in this case.</p> <p><u>Clause 92</u> of the EP&A Regulation 2000 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.</p> <p><u>Clauses 93 and/or 94</u> of the EP&A Regulation 2000 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This clause is not relevant to this application.</p> <p><u>Clause 98</u> of the EP&A Regulation 2000 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This clause is not relevant to this application.</p> <p><u>Clause 98</u> of the EP&A Regulation 2000 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.</p> <p><u>Clause 143A</u> of the EP&A Regulation 2000 requires the submission</p>

Section 4.15 Matters for Consideration'	Comments
	of a design verification certificate from the building designer prior to the issue of a Construction Certificate. This clause is not relevant to this application.
Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in the locality	<p>(i) Environmental Impact The environmental impacts of the proposed development on the natural and built environment are addressed under the Warringah Development Control Plan section in this report.</p> <p>(ii) Social Impact The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.</p> <p>(iii) Economic Impact The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.</p>
Section 4.15 (1) (c) – the suitability of the site for the development	The site is considered suitable for the proposed development.
Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs	See discussion on “Notification & Submissions Received” in this report.
Section 4.15 (1) (e) – the public interest	No matters have arisen in this assessment that would justify the refusal of the application in the public interest.

EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

NOTIFICATION & SUBMISSIONS RECEIVED

The subject development application has been publicly exhibited from 24/08/2021 to 07/09/2021 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2000 and the Community Participation Plan.

As a result of the public exhibition of the application Council received no submissions.

REFERRALS

Internal Referral Body	Comments
Environmental Health (Industrial)	<p>General Comments</p> <p>The proposal is for replacement new site identification illuminated signage at a car dealership.</p> <p>There are no immediate affected residential premises.</p> <p>Impact on street scape or traffic is not considered adverse.</p> <p>Recommendation</p>

Internal Referral Body	Comments
	APPROVAL - subject to conditions

External Referral Body	Comments
NSW Roads and Maritime Services - (SEPP 64 signage cl 17(3)(c))	<p>TfNSW has reviewed the development application and raises no objections subject to the following condition:</p> <ul style="list-style-type: none"> All buildings and structures including signage together with any improvements integral to the future use of the site are wholly within the freehold property unlimited in height or depth along the Pittwater Road boundary. <p>A condition requiring compliance with TfNSW requirements has been included as part of the development consent.</p>

ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)*

All, Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

SEPP 55 - Remediation of Land

Clause 7 (1) (a) of SEPP 55 requires the Consent Authority to consider whether land is contaminated. Council records indicate that the subject site has been used for commercial purposes for a significant period of time with no prior land uses. In this regard it is considered that the site poses no risk of contamination and therefore, no further consideration is required under Clause 7 (1) (b) and (c) of SEPP 55 and the land is considered to be suitable for the commercial land use.

SEPP 64 - Advertising and Signage

Clauses 8 and 13 of SEPP 64 require Council to determine consistency with the objectives stipulated under Clause 3(1)(a) of the aforementioned SEPP and to assess the proposal against the assessment criteria of Schedule 1.

The objectives of the policy aim to ensure that the proposed signage is compatible with the desired amenity and visual character of the locality, provides effective communication and is of high quality having regards to both design and finishes.

In accordance with the provisions stipulated under Schedule 1 of SEPP 64, the following assessment is provided:

Matters for Consideration	Comment	Complies
1. Character of the area Is the proposal compatible with the existing or desired future character of the area or locality in which it is proposed to be located?	Yes, the signage is compatible with the character of the site and its immediate surrounds and will support the operation of the existing vehicle sales premises on site.	YES
Is the proposal consistent with a particular theme for outdoor advertising in the area or locality?	Yes, it is compatible with the theme for outdoor advertising in the immediate locality.	YES
2. Special areas Does the proposal detract from the amenity or visual quality of any environmentally sensitive areas, heritage areas, natural or other conservation areas, open space areas, waterways, rural landscapes or residential areas?	The signage will be of high quality design and finish and will improve the visual amenity of the site through effective business identification. The proposed signage will not be located within proximity to heritage items.	YES
3. Views and vistas Does the proposal obscure or compromise important views?	No, the proposed signage respects the scale of the existing built form. The signage will be setback from the road frontage and would not obscure or comprise any important views.	YES
Does the proposal dominate the skyline and reduce the quality of vistas?	No, the signage respects the height and scale of the existing built form and streetscape. The proposal does not change the existing street form and therefore will not dominate the skyline, nor would it reduce the quality of vistas.	YES
Does the proposal respect the viewing rights of other advertisers?	Yes, the signage will not obstruct any other signage.	YES
4. Streetscape, setting or landscape Is the scale, proportion and form of the proposal appropriate for the streetscape, setting or landscape?	Yes, the signage has been designed to be compatible with the business character of the immediate neighbouring properties. The signage has been designed to respect the proposed built form on the site and broader streetscape.	YES
Does the proposal contribute to the visual interest of the streetscape, setting or landscape?	Yes, the sign will positively contribute to the streetscape and setting by effectively distinguishing the business from others operating nearby.	YES
Does the proposal reduce clutter by rationalising and simplifying existing advertising?	Yes, the existing signage will seek to integrate with the existing built form of the site, remaining consistent with the existing signage pattern along Pittwater Road whilst also improving the legibility on site.	YES
Does the proposal screen unsightliness?	No, the signage is not used as a visual screen or filter.	YES
Does the proposal protrude above buildings, structures or tree canopies in	Yes, the proposed signage will protrude above the existing awning and building by 600mm. The	YES

the area or locality?	signage is considered acceptable as it will be replacing like for like.	
5. Site and building Is the proposal compatible with the scale, proportion and other characteristics of the site or building, or both, on which the proposed signage is to be located?	The majority of the proposed signs are respectful to the existing form of the buildings. However, Sign 2 does not align with the existing eave/parapet, and the two flanking elements significantly alter the architectural form of the building.	NO See discussion
Does the proposal respect important features of the site or building, or both?	No, Sign 2 is unsympathetic to the existing architecture of the building fronting Pittwater Road.	NO See discussion
Does the proposal show innovation and imagination in its relationship to the site or building, or both?	No, Sign 2 is not considered to be an innovative design solution for the existing building.	NO See discussion
6. Associated devices and logos with advertisements and advertising structures Have any safety devices, platforms, lighting devices or logos been designed as an integral part of the signage or structure on which it is to be displayed?	No, the proposed signage will not require safety devices or platforms for external access. The main awning sign comprises of two flanking elements supported with structural steel supports in the ground.	YES
7. Illumination Would illumination result in unacceptable glare, affect safety for pedestrians, vehicles or aircraft, detract from the amenity of any residence or other form of accommodation?	No, the illumination from the proposed signage will not result in an unacceptable glare (remains as presently set up).	YES
Can the intensity of the illumination be adjusted, if necessary?	The proposed illumination can be adjusted if required. The proposed sign will be internally lit and the brightness will remain relatively low. The proposed illumination will remain consistent with the existing streetscape.	YES
Is the illumination subject to a curfew?	The proposed illumination will not create any disturbance for the surrounding properties due to its location within a main road corridor. There are no sensitive properties near the site. Due to this, the implementation of a curfew is not necessary for the proposed illumination.	YES
8. Safety Would the proposal reduce the safety for any public road, pedestrians or bicyclists?	No, the proposed signage is located within the site boundaries and is set back from both street frontages.	YES
Would the proposal reduce the safety for pedestrians, particularly children, by obscuring sightlines from public areas?	No, the proposed signage will not obscure any sightlines from public areas frequented by pedestrians. Neither will the proposed signs obstruct any vehicle sight lines from public roads.	YES

8 of the 9 proposed signs are consistent with the provisions of SEPP 64. However, concern is raised in relation to Sign 2.

Sign 2 works against the architecture of the building, eroding the façade of the building, as follows:

- The “flanking” elements erode the architectural expression of the projecting eaves of the building, but only on the Pittwater Road front façade. They are to be retained on both sides. This inconsistency results in an irregular and inconsistent architectural expression, in a highly visible location.
- The upper portion of the signage will not align with the height of the eaves or the side eave signage. The plan view seems to suggest that they are all the same height, which would mean that Sign 2 would drop down and obscure the illuminated phone number on the front façade, however this is not shown in the montage.
- The flanking elements would require the demolition of the existing awning, however this is not proposed in the application and would also impact upon the architectural expression of the building. I note the application does not propose alterations and additions to the existing building.

As proposed, Sign 2 is inconsistent with the provisions of SEPP 64. Signage should not alter the architecture of the building. To alleviate these concerns, the following amendments are recommended:

- Sign 2 is to be rectangular in shape, with dimensions of 1,200mm x 26,400mm. Sign 2 is to run along the existing projecting eave of the building presenting to Pittwater Road, consistent with Sign 5 and Sign 7. The size of the Ford Logo is to be adjusted accordingly, so as to be maintained within the amended size of Sign 2.
- The Ford Logo on Sign 1 may be increased to that previously proposed for Sign 2.

Subject to conditions of consent, the proposed signage is considered to be of a scale and design suitable for the locality. The proposal is therefore deemed to be consistent with the provisions of the SEPP and its underlying objectives.

SEPP (Infrastructure) 2007

Roads and Maritime Service (RMS)

Clause 101 - Development with frontage to classified road states:

The consent authority must not grant consent to development on land that has a frontage to a classified road unless it is satisfied that—

- (a) where practicable and safe, vehicular access to the land is provided by a road other than the classified road, and*
- (b) the safety, efficiency and ongoing operation of the classified road will not be adversely affected by the development as a result of—*
 - (i) the design of the vehicular access to the land, or*
 - (ii) the emission of smoke or dust from the development, or*
 - (iii) the nature, volume or frequency of vehicles using the classified road to gain access to the land, and*
- (c) the development is of a type that is not sensitive to traffic noise or vehicle emissions, or is*

appropriately located and designed, or includes measures, to ameliorate potential traffic noise or vehicle emissions within the site of the development arising from the adjacent classified road.

Comment:

The proposal was referred to RMS who raised no objections subject to the inclusion of a condition. This condition has been included as part of the development consent.

Warringah Local Environmental Plan 2011

Is the development permissible?	Yes
After consideration of the merits of the proposal, is the development consistent with:	
aims of the LEP?	Yes
zone objectives of the LEP?	Yes

Principal Development Standards

Standard	Requirement	Proposed	% Variation	Complies
Height of Buildings:	11m	Sign: 7.2m	N/A	Yes

Compliance Assessment

Clause	Compliance with Requirements
4.3 Height of buildings	Yes

Detailed Assessment

Zone B5 Business Development

Proposed Use	Permitted or Prohibited
Business Identification Signage	Permitted with consent

The underlying objectives of the B5 Business Development zone

- To enable a mix of business and warehouse uses, and bulky goods premises that require a large floor area, in locations that are close to, and that support the viability of, centres.*

Comment:

The proposal comprises of replacement business identification signage to support an existing vehicle showroom to effectively identify the tenancy and enhance the visibility for customers.

- To provide for the location of vehicle sales or hire premises.*

Comment:

The proposal will support an existing vehicle sales premise.

- *To create a pedestrian environment that is safe, active and interesting by incorporating street level retailing and business uses.*

Comment:

The proposal will support an existing vehicle sales premise. Existing street level business use on site will be retained.

4.3 Height of buildings

The proposed new signage will protrude 600mm above the existing awning and building. The proposal readily complies with the maximum building height.

Warringah Development Control Plan

Compliance Assessment

Clause	Compliance with Requirements	Consistency Aims/Objectives
A.5 Objectives	Yes	Yes
C8 Demolition and Construction	Yes	Yes
C9 Waste Management	N/A	N/A
D7 Views	Yes	Yes
D10 Building Colours and Materials	Yes	Yes
D12 Glare and Reflection	Yes	Yes
D20 Safety and Security	Yes	Yes
D23 Signs	Yes	Yes

Detailed Assessment

C9 Waste Management

A detailed waste management plan has not been submitted with the application. To ensure proper disposal of demolition and builders' wastes, a condition has been included in the consent requiring details prior to the issue of a construction certificate.

D10 Building Colours and Materials

The content and colours of the sign reflect the logo and corporate colours of Ford in order to effectively identify the tenancy and for site identification. The design and colours of the sign will complement the existing development as they are like for like to the existing signage. The signage elements and dimensions are also consistent with that of development within the surrounding locality.

Dealer name and Service 3D letters will be light grey alucobond signage with 100mm deep aluminium letters and blue acrylic faces. The Ford logo will be an aluminium oval with blue acrylic faces. All signs will be internally LED illuminated.

D12 Glare and Reflection

The proposal seeks to replace existing illuminated signage with like for like signage. The content and colours of the sign reflect the logo and corporate colours of Ford for business identification. The design and colours of the sign are of a similar to the existing signage. The signage specifications are included in the master set of plans.

The signage illumination shall be operated so as not to create glare and to comply with AS 4282 - 1997 Control of the obtrusive effects of outdoor lighting.

THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

POLICY CONTROLS

Northern Beaches Section 7.12 Contributions Plan 2021

The proposal is subject to the application of Northern Beaches Section 7.12 Contributions Plan 2021.

A monetary contribution of \$2,050 is required for the provision of new and augmented public infrastructure. The contribution is calculated as 1% of the total development cost of \$205,000.

CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2000;
- All relevant and draft Environmental Planning Instruments;
- Warringah Local Environment Plan;
- Warringah Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP

- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2021/1399 for Construction of business identification signage on land at Lot 1 DP 1068612, 776 - 780 Pittwater Road, BROOKVALE, subject to the conditions printed below:

DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

a) Approved Plans

Architectural Plans - Endorsed with Council's stamp		
Drawing No.	Dated	Prepared By
Plan View	15 July 2021	Camden Signage & Building Services
Sign List	15 July 2021	Camden Signage & Building Services
Sign Specs	15 July 2021	Camden Signage & Building Services

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

2. Compliance with Other Department, Authority or Service Requirements

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

Other Department, Authority or Service	EDMS Reference	Dated
Transport for NSW	TfNSW	9 September 2021

(NOTE: For a copy of the above referenced document/s, please see Application Tracking on Council's website www.northernbeaches.nsw.gov.au)

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other departments, authorities or bodies.

3. **Prescribed Conditions**

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
 - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
 - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.
- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
 - (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.
- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
 - (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
 - (iii) must, at least 7 days before excavating below the level of the base of the

footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.

- (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

4. **Limited Timeframe**

In accordance with the provisions of clause 14 of SEPP 64, this consent ceases to be in force on the expiration of 15 years after the date on which the consent becomes effective.

Reason: To ensure compliance with SEPP 64.

5. **General Requirements**

- (a) Unless authorised by Council:
Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (c) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (d) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (e) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (f) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments

Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.

- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (k) Prior to the commencement of any development onsite for:
 - i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.
- (l) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (m) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
 - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2018
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools

- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

6. **Signage Approval**

No approval is granted under this Development Consent for any signs (as defined under Warringah Local Environment Plan 2011 and State Environmental Planning Policy No. 64) other than signage 1, 2, 4, 5, 7, 8 and 9 referenced in the stamped plans and Condition 1 of this consent. For the avoidance of doubt the existing or any future signage on the glazing fronting Pittwater Road is not approved under this application.

A separate development application for any signage (other than signage previously approved or approved under this development consent or permitted under the State Environmental Planning Policy Exempt and Complying Development Codes) must be submitted for the approval prior to the erection or display of any such signs.

Reason: Control of Signage

FEES / CHARGES / CONTRIBUTIONS

7. **Policy Controls**

Northern Beaches 7.12 Contributions Plan 2021

A monetary contribution of \$2,050.00 is payable to Northern Beaches Council for the provision of local infrastructure and services pursuant to section 7.12 of the Environmental Planning & Assessment Act 1979 and the Northern Beaches Section 7.12 Contributions Plan 2021. The monetary contribution is based on a development cost of \$205,000.00.

The monetary contribution is to be paid prior to the issue of the first Construction Certificate or Subdivision Certificate whichever occurs first, or prior to the issue of the Subdivision Certificate where no Construction Certificate is required. If the monetary contribution (total or in part) remains unpaid after the financial quarter that the development consent is issued, the amount unpaid (whether it be the full cash contribution or part thereof) will be adjusted on a quarterly basis in accordance with the applicable Consumer Price Index. If this situation applies, the cash contribution payable for this development will be the total unpaid monetary contribution as adjusted.

The proponent shall provide to the Certifying Authority written evidence (receipt/s) from Council that the total monetary contribution has been paid.

The Northern Beaches Section 7.12 Contributions Plan 2021 may be inspected at 725 Pittwater Rd, Dee Why and at Council's Customer Service Centres or alternatively, on Council's website at www.northernbeaches.nsw.gov.au

This fee must be paid prior to the issue of the Construction Certificate. Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To provide for contributions in accordance with the Contribution Plan to fund the provision of new or augmented local infrastructure and services.

8. Security Bond

A bond (determined from cost of works) of \$1,500 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at www.northernbeaches.nsw.gov.au).

Reason: To ensure adequate protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

9. Amendments to the approved plans

The following amendments are to be made to the approved plans:

- a. Sign 2 is to be rectangular in shape, with dimensions of 1,200mm x 26,400mm. Sign 2 is to run along the existing projecting eave of the building presenting to Pittwater Road, consistent with Sign 5 and Sign 7. The size of the Ford Logo is to be adjusted accordingly, so as to be maintained within the amended size of Sign 2.
- b. The Ford Logo on Sign 1 may be increased to that previously proposed for Sign 2.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the construction certificate.

Reason: To ensure development minimises unreasonable impacts upon surrounding land.

10. Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

11. Waste Management Plan

A Waste Management Plan must be prepared for this development. The Plan must be in accordance with the Development Control Plan.

Details demonstrating compliance must be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that any demolition and construction waste, including excavated material, is reused, recycled or disposed of in an environmentally friendly manner.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

12. Waste Management During Development

The reuse, recycling or disposal of waste during works must be done generally in accordance with the Waste Management Plan for this development.

Details demonstrating compliance must be submitted to the Principal Certifying Authority.

Reason: To ensure demolition and construction waste is recycled or reused and to limit landfill.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

13. Glare Prevention

Signage illumination shall be operated so as not to create glare and comply with AS 4282—1997 Control of the obtrusive effects of outdoor lighting.

Reason: To prevent glare to adjacent receivers.

14. Illumination Intensity and design

The level of illumination and/or lighting intensity used to illuminate the signage is to be minimised and the design is to be such to ensure that excessive light spill or nuisance is not caused to any nearby premises.

Reason: To ensure appropriate forms of signage that are consistent with Council's controls and those that are desired for the locality, and do not interfere with amenity of nearby properties.

In signing this report, I declare that I do not have a Conflict of Interest.

Signed



Clare Costanzo, Planner

The application is determined on 18/10/2021, under the delegated authority of:

REnglund.

Rebecca Englund, Acting Development Assessment Manager