

Natural Environment Referral Response - Coastal

Application Number:	DA2025/0181
Proposed Development:	Demolition works and construction of a dwelling house attached to an existing restaurant/cafe
Date:	03/07/2025
Responsible Officer	Kye Miles
Land to be developed (Address):	Lot 1 DP 1005148 , 1 Narrabeen Park Parade NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The applicant seeks development consent to undertake the following:

- Demolition of part of an existing dwelling and construction of a new one adjacent to an existing café.

This application was assessed in consideration of:

- Supplied plans and reports;
- Coastal Management Act (2016)
- State Environmental Planning Policy (Resilience and Hazards) 2021 (section 2.10, 2.12);
- Relevant LEP and DCP clauses.

Comment: SUPPORTED WITH CONDITIONS
Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore Coastal Management Act 2016 is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the Coastal Management Act 2016.

This referral has focused on the impact of the proposal on coastal processes and hazards. The assessment of compliance with controls applying to visual amenity, scenic qualities or aesthetic appearance of the foreshore or surrounding coastal environment will be undertaken by the development assessment officer assessing this development application.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'coastal environmental' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.10 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment, the proposed development satisfies requirements under clauses 2.10 and 2.12 of the SEPP R&H. As such, it is considered that the application is consistent with the

requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

It should be noted that the assessment of compliance with controls applying to visual amenity, scenic qualities or aesthetic appearance of the foreshore or surrounding coastal environment will be undertaken by the development assessment officer assessing this development application

Pittwater LEP 2014 and Pittwater 21 DCP

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Erosion and Sediment Control Plan

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities);
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls;
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifier for approval prior to the issue of the Construction Certificate.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Stockpiling materials

During construction, all material associated with works is to be contained at source, covered and must be within the construction area. All material is to be removed off site and disposed of according to local regulations. The property is to be kept clean and any building debris removed as frequently as required to ensure no debris enters receiving waters.

Reason: To ensure pollution control measures are effective to protect the aquatic habitats within receiving waters throughout the construction period.