

Natural Environment Referral Response - Coastal

Application Number:	DA2025/0508
Proposed Development:	Construction of an inclinor and associated works
Date:	25/06/2025
Responsible Officer	Phil Lane
Land to be developed (Address):	Lot 40 DP 13760 , 212 Hudson Parade CLAREVILLE NSW 2107 Lot LIC 635271 , 212 Hudson Parade CLAREVILLE NSW 2107

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application was assessed in consideration of:

- Supplied plans and reports;
- Coastal Management Act 2016;
- State Environmental Planning Policy (Resilience and Hazards) 2021 (section 2.10, 2.11 & 2.12);
- Relevant LEP and DCP clauses.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore Coastal Management Act 2016 is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the Coastal Management Act 2016.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.10, 2.11 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Nolan Planning Consultants dated January 2025, the DA satisfies satisfy requirements under clauses 2.10, 2.11 and 2.12 of the SEPP R&H.

As such, it is considered that the application is generally consistent with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

Pittwater LEP 2014 and Pittwater 21 DCP

Estuarine Risk Management

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for

Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL 2.78m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.08m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m.

The proposed development is subject to conditions to satisfy the relevant estuarine risk management requirements of P21 DCP.

Development on Foreshore Area

A section of the subject property is within the foreshore building line. This referral has not assessed the compliance of the proposal, for any potential impact on the scenic value of the area in accordance with Part 7, Clause 7.8 –Limited development on foreshore area of the Pittwater LEP 2014.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Estuarine Planning Level Requirements

An Estuarine Planning Level (EPL) of 2.78m AHD has been adopted by Council for the subject site and shall be applied to all development proposed below this level as follows:

1. All structural elements below 2.78m AHD shall be of flood compatible materials;
2. All electrical equipment, wiring, fuel lines or any other service pipes and connections must be located either above 2.78m AHD or waterproofed to this level; and

Reason: To ensure vulnerable components of the development are built at the appropriate level.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from

the site