

Building Assessment Referral Response

Application Number:	DA2025/0151
Proposed Development:	Use of a tenancy in approved mixed use and seniors housing development as a centre-based child care facility including internal fit-out and landscaping
Date:	24/03/2025
To:	Thomas Burns
Land to be developed (Address):	Lot 11 DP 1258355 , 5 Skyline Place FRENCHS FOREST NSW 2086

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no concerns with the application subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

National Construction Code (BCA) upgrade requirements and Fire Safety upgrade

The National Construction Code works and fire upgrading measures to upgrade the building as detailed and recommended in the National Construction Code (NCC) Report prepared by Tamara

Blyth - Jensen Hughes Pty Limited, dated 16 December 2024, Report Ref No. Project Number: 119909

Report Type: BCA - Revision: 2, are to be carried out in full to the building OR considered as part of the assessment of the Construction Certificate.

Details demonstrating compliance are to be provided to the Certifier prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, Access & Fire Safety for building occupant health & safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate. Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Parts 10, 11 & 12 of the Environmental Planning and Assessment (Development Certification and Fire Safety) Regulation 2021.