

Waste Referral Response

Application Number:	Mod2014/0117
To:	Kevin Short
Land to be developed (Address):	Part Lot 394 DP752038 , 5 Lawrence Street FRESHWATER NSW 2096 Lot 9 DP 10321 , 18 Marmora Street FRESHWATER NSW 2096 Part Lot 394 DP 752038 , 5 A Lawrence Street FRESHWATER NSW 2096

Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

Officer comments

Waste Services Assessment

The bin room design and location are acceptable.

The application is required to adhered to the conditions of consent.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Waste Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Waste/Recycling Requirements (Waste Plan Submitted)

During demolition and/or construction the proposal/works shall be generally consistent with the submitted

Waste Management Plan titled [INSERT] and dated [INSERT].

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided. (DACWTE01)

Waste/Recycling Requirements (Materials)

During demolition and/or construction the following materials are to be separated for recycling – timber – bricks – tiles – plasterboard – metal – concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible. (DACWTE02)

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Garbage and Recycling Facilities

All internal walls of the storage area shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate cleaning.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To prevent pollution of the environment and to protect the amenity of the area.(DACPLF03)

Waste/Recycling Compliance Documentation

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste is minimised and recycled. (DACWTF02)

Positive Covenant for Waste Services

A positive covenant shall be created on the title of the land requiring the proprietor of the land to provide access to the waste storage facilities prior to the issue of an Interim/Final Occupation Certificate. The terms of the positive covenant are to be prepared to Council's standard requirements, (available from Warringah Council), at the applicant's expense and endorsed by Council prior to lodgment with the Department of Lands. Warringah Council shall be nominated as the party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities (DACWTF03)

Authorisation of Legal Documentation Required for Waste Services

The original completed request form (Department of Lands standard form 13PC) must be submitted to Council for authorisation prior to the issue of the Interim/Final Occupation Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. Where required by Council or the Certifying Authority, a Compliance Certificate shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land. (DACWTF04)