

Natural Environment Referral Response - Flood

Application Number:	DA2025/1006
Proposed Development:	Demolition works and construction of a dwelling house
Date:	13/08/2025
To:	Fathima Shajar
Land to be developed (Address):	Lot 33 DP 15141 , 7 Ross Street NORTH CURL CURL NSW 2099

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This proposal is for construction of a new two-storey dwelling, including an enclosed garage. The proposal is assessed against Section E11 of the Warringah DCP and Clause 5.21 of the Warringah LEP. The proposed FFL of the building is 10.95m AHD which is at the FPL and the proposed enclosed garage is above the 1% AEP level.

The proposed building footprint is smaller than the existing building.

Subject to the following conditions the proposal generally complies with Section E11 of the Warringah DCP and Clause 5.21 of the Warringah LEP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Flood effects caused by development

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level of 10.45m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Building components and structural soundness

B1 - All new development below the Flood Planning Level of 10.95m AHD shall be designed and constructed from flood compatible materials.

B2 - All new development must be designed to ensure structural integrity up to the Flood Planning Level of 10.95m AHD, taking into account the forces of floodwater, debris load, wave action, buoyancy and immersion.

B3 - All new and existing electrical equipment, power points, wiring and connections must be located above the Flood Planning Level of 10.95m AHD, protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Floor levels

C1 - New floor levels within the development shall be set at or above the Flood Planning Level of 10.95m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Car parking

D5 - The floor level of the proposed garage shall be set at or above the 1% AEP flood level of 10.45m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE****Certification of Works as Executed**

A suitably qualified engineer and/or registered surveyor is to certify that the completed works have been constructed in accordance with this consent and the approved plans with respect to the following:

1. Floor levels for ground floor, shelter in place refuge and garage are set at or above the required level
2. There has been no filling on the land other than what has been approved

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Building Components and Structural Soundness

B2 - A suitably qualified structural engineer is to certify the structural integrity of the new development up to the Flood Planning Level of 10.95m AHD. The depth, velocity, debris load, wave action, buoyancy and immersion must all be considered.

B3 - A suitably qualified electrician or contractor is to certify that all new and existing electrical equipment, power points, wiring and connections are located above the Flood Planning Level of 10.95m AHD, are protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.