

CONSENT NO: N0541/17
ENVIRONMENTAL PLANNING & ASSESSMENT ACT, 1979 (AS AMENDED)
NOTICE TO APPLICANT OF DETERMINATION
OF A DEVELOPMENT APPLICATION

Applicant's Name and Address:

O FAINBAUM & M MORIKI
C/- VAUGHAN MILLIGAN DEVELOPMENT CONSULTING P/L
PO BOX 49
NEWPORT NSW 2106

Being the applicant in respect of Development Application No N0541/17

Pursuant to section 80(1) of the Act, notice is hereby given of the determination by Northern Beaches Council, as the consent authority, of Development Application No **N0541/17** for:

Construction of a new two storey dwelling and driveway

At: 8 Orchard Street, WARRIEWOOD NSW 2102 (Lot 204 DP 1212459)

Decision:

The Development Application has been determined by the granting of consent based on information provided by the applicant in support of the application, including the Statement of Environmental Effects, and in accordance with

- **Architectural Drawings:**
- **Sheet 2 Rev G through to 7 Rev G, prepared by Clarendon Homes, all dated 19/09/2016;**
- **Landscape Plan L-01 Rev C and L-02 Rev C, prepared by Ecodesign, dated 19/10/2017;**
- **External Colour Selections, prepared by Clarendon Homes, dated 21/10/2016;**
- **BASIX Certificate, 872281S, dated 24/10/2017.**

as amended in red (shown clouded) or as modified by any conditions of this consent.

The reason for the imposition of the attached conditions is to ensure that the development consented to is carried out in such a manner as to achieve the objectives of the Environmental Planning and Assessment Act 1979 (as amended), pursuant to section 5(a) of the Act, having regard to the relevant matters for consideration contained in section 79C of the Act and the Environmental Planning Instruments applying to the land, as well as section 80A of the Act which authorises the imposing of the consent conditions.

Endorsement of date of consent 29-Jan-2018

Mark Ferguson
CHIEF EXECUTIVE OFFICER
Per:

Conditions of Approval

This consent is not an approval to commence building work. The works associated with this consent can only commence following the issue of the Construction Certificate.

Note: Persons having the benefit of development consent may appoint either a council or an accredited certifier as the principal certifying authority for the development or for the purpose of issuing certificates under Part 4A of the Environmental Planning and Assessment Act. When considering engaging an accredited certifier a person should contact the relevant accreditation body to ensure that the person is appropriately certified and authorised to act in respect of the development.

A. Prescribed Conditions:

1. All works are to be carried out in accordance with the requirements of the Building Code of Australia.
2. In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, that such a contract of insurance is in force before any building work authorised to be carried out by the consent commences.
3. A sign must be erected in a prominent position onsite only showing:
 - a) the name, address and telephone number of the Principal Certifying Authority for the work, and
 - b) the name of the principal contractor or the person responsible for the works and a telephone number on which that person may be contacted outside working hours, and
 - c) that unauthorised entry to the work site is prohibited.The sign must to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.
4. Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
 - a) in the case of work for which a principal contractor is required to be appointed:
 - i) The name and licence number of the principal contractor, and
 - ii) The name of the insurer by which the work is insured under Part 6 of that Act.
 - b) in the case of work to be done by an owner-builder:
 - i) The name of the owner-builder, and
 - ii) If the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.
 - c) If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under a or b above becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information

5. This approval/consent relates only to the new work nominated on the approved consent plans and does not approve or regularise any existing buildings or structures within the property boundaries or within Council's road reserve.

B. Matters to be incorporated into the development and maintained over the life of the development:

1. The commitments identified in the BASIX Certificate and on the plans or specifications are to be fulfilled and maintained for the life of the development.
2. If any Aboriginal Engravings or Relics are unearthed all work is to cease immediately and the Aboriginal Heritage Office (AHO) and Office of Environment and Heritage (OEH) are to be notified.
3. No environmental weeds are to be planted on the site. Refer to Council website http://www.pittwater.nsw.gov.au/environment/noxious_weeds for environmental weed lists.
4. To satisfy the off-street parking requirements for development, the minimum number of two vehicle space requirements shall be provided.

These spaces are to be provided and retained over the life of the development.

5. Landscaping is approved as per provided Landscape Plan authored by Ecodesign, L-01 & L-02 Revision C dated 19/10/17 with the addition of the planting of a medium (min 8.5m in mature height) canopy tree (species as per Warriewood Valley Master Plan) within the north-western corner of the rear yard.

Additionally a Street Tree is to be planted as per specifications set out within the Warriewood Valley Landscape Master Plan. All planting is subject to Council's Street Tree Officer's approval.

6. No water pollution shall result from the operation of any plant or equipment or activity carried out.
7. Noise from the operation of any plant or equipment at the premises shall comply with the noise provisions of the Protection of the Environment Operations Act, 1997.
8. No emissions causing air pollution shall be created by the operation of any plant equipment or any procedure carried out at the premise.
9. Materials and colour schemes are to be in accordance with the samples submitted to Council with the application. No white or light coloured roofs are permitted.

C. Matters to be satisfied prior to the issue of the Construction Certificate:

Note: All outstanding matters referred to in this section are to be submitted to the accredited certifier together. Incomplete Construction Certificate applications / details cannot be accepted.

1. Submission of construction plans and specifications and documentation which are consistent with the approved Development Consent plans, the requirements of Building Code of Australia and satisfy all conditions shown in Part B above are to be submitted to the Principal Certifying Authority.
2. The Principal Certifying Authority must be provided with a copy of plans that a Quick Check agent/Sydney Water has stamped before the issue of any Construction Certificate.
3. The person having the benefit of this consent is required to notify the Principal Certifying Authority to ensure that the following critical stage inspections are undertaken, as required under clause 162A(4) of the Environmental Planning and Assessment Regulation 2000:
 - a) after excavation for, and prior to the placement of, any footings, and
 - b) prior to pouring any in-situ reinforced concrete building element, and
 - c) prior to covering of the framework for any floor, wall, roof or other building element, and
 - d) prior to covering waterproofing in any wet areas, and
 - e) prior to covering any stormwater drainage connections, and
 - f) after building work has been completed and prior to any occupation certificate being issued in relation to the building.

To allow a Principal Certifying Authority to carry out critical stage inspections, at least 48 hours notice must be given before building work is commenced and prior to further work being undertaken.

4. Construction works approved by this consent must not commence until:
 - a) Construction Certificate has been issued by a Principal Certifying Authority
 - b) a Principal Certifying Authority has been appointed and Council has been notified in writing of the appointment, and
 - c) at least 2 days notice, in writing has been given to Council of the intention to commence work.
5. In accordance with section 34 of the Building and Construction Industry Long Service Payments Act 1986, the applicant must pay a long service levy at the prescribed rate of 0.0035 of the total cost of the work to either the Long Service Payment Corporation or Council for any work costing \$25,000 or more.
6. Structural Engineering details relating to the development are to be submitted to the Accredited Certifier or Council prior to release of the Construction Certificate. Each plan/sheet is to be signed by a qualified practising Structural Engineer with corporate membership of the Institute of Engineers Australia (M.I.E), or who is eligible to become a corporate member and has appropriate experience and competence in the related field.

7. Plans and details demonstrating that the commitments identified in the BASIX Certificate that apply to the construction certificate plans and specifications are fulfilled.
8. An application for driveway levels and formwork inspections shall be made with Council subject to the payment of the fee applicable which includes all Council inspections relating to the crossing construction. Approval is to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

D. Matters to be satisfied prior to the commencement of works and maintained during the works:

Note: It is an offence to commence works prior to issue of a Construction Certificate.

1. The hours of construction are restricted to between the hours of 7.00am and 5.00pm Monday - Friday and 7.00am to 1.00pm on Saturdays. No works are to be carried out on Sundays or Public Holidays. Internal building work may be carried out at any time outside these hours, subject to noise emissions from the building or works not being audible at any adjoining boundary.

Note: This condition does not apply in relation to Crown building work that is certified, in accordance with Section 116G of the Act, to comply with the technical provisions of the States building laws.

2. Any proposed demolition works shall be carried out in accordance with the requirements of AS2601-2001 The Demolition of Structures.

Amongst others, precautions to be taken shall include compliance with the requirements of the WorkCover Authority of New South Wales, including but not limited to:

- a) Protection of site workers and the general public.
- b) Erection of hoardings where appropriate.
- c) Asbestos handling and disposal where applicable.
- d) Any disused service connections shall be capped off.

Council is to be given 48 hours written notice of the destination/s of any excavation or demolition material. The disposal of refuse is to be to an approved waste disposal depot.

3. A stamped copy of the approved plans is to be kept on the site at all times, during construction.
4. The following facilities must be provided on the site:
 - a) toilet facilities in accordance with WorkCover NSW requirements, at a ratio of one toilet per every 20 employees, and
 - b) a garbage receptacle for food scrapes and papers, with a tight fitting lid.

Toilet facilities are to be provided in a location which will not detrimentally affect the amenity of any adjoining residents at or in the vicinity of the work site during the duration of the development.

5. Where excavations extend below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation must give the owner of the adjoining property at least seven (7) days written notice of their intention to excavate below the level of the base of the footing and furnish the adjoining property owner with particulars of the proposed work.
6. The provision of normal vehicle crossing 3.0 metres wide in accordance with Northern Beaches Council Drawing No A4-3330/1 and specifications. An Authorised Vehicle Crossing Contractor shall construct the vehicle crossing and associated works within the road reserve in plain concrete. All redundant laybacks and crossings are to be restored to footpath/grass. Prior to the pouring of concrete, the vehicle crossing is to be inspected by Council and a satisfactory "Vehicle Crossing Inspection" card issued.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

7. A layback 3.0 metres wide (excluding the wings) is to be constructed in accordance with Northern Beaches Council Drawing No A4-2276 and specifications.
8. Waste materials generated through demolition, excavation and construction works are to be minimised by re-use on site, recycling or where re-use or recycling is not practical, disposal at an appropriate authorised waste facility.

All waste dockets and receipts regarding demolition, excavation and construction waste are to be retained on site to confirm which facility received the material for recycling or disposal.

The ongoing operation of Recycling and Waste Management Services is to be undertaken in accordance with the Waste Management Plan.

9. The site must be fenced throughout construction and must comply with WorkCover New South Wales requirements and be a minimum of 1.8m in height.
10. A site fence and silt and sediment control fence is to be erected and maintained during the course of works along any street boundary and park/reserve boundary to the site.
11. A clearly legible *Site Management Sign* is to be erected and maintained throughout the course of the works. The sign is to be centrally located on the main street frontage of the site and is to clearly state in legible lettering the following:
 - a) The builder's name, builder's telephone contact number both during work hours and after hours.
 - b) That no works are to be carried out in Council's Road Reserve without prior application and approval of a Road Opening Permit from Council.
 - c) That a Road Opening Permit issued by Council must be obtained for any road openings or excavation within Council's Road Reserve associated with development of the site, including stormwater drainage, water, sewer, electricity, gas and

communication connections. During the course of the road opening works the Road Opening Permit must be visibly displayed at the site.

- d) That no skip bins or materials are to be stored on Council's Road Reserve.
- e) That the contact number for Northern Beaches Council for permits is 9970 1111.

12. Construction access to the property is to be via the approved driveway only.

E. Matters to be satisfied prior to the issue of Occupation Certificate:

Note: Prior to the issue of an Occupation Certificate the principal certifying authority is to ensure that Council's assets, including road, kerb and gutter and drainage facilities adjacent or near to the site have not been damaged as a result of the works. Where such damage has occurred, it is to be repaired to Council's written satisfaction prior to the issue of an Occupation Certificate or suitable arrangements put in place to effect those repairs at a future date to Council's written satisfaction. Should this process not be followed, Council will pursue action against the principal accredited certifier in relation to the recovery of costs to effect such works.

Note: It is an offence to occupy the building or part thereof to which this consent relates prior to the issue of an Occupation Certificate.

1. An Occupation Certificate application stating that the development complies with the Development Consent, the requirements of the Building Code of Australia and that a Construction Certificate has been issued must be obtained before the building is occupied or on completion of the construction work approved by this Development Consent.
2. All existing and /or proposed dwellings/sole occupancy units are to have approved hard-wired smoke alarms installed and maintained over the life of the development. All hard-wired smoke alarms are to be Australian Standard compliant and must be installed and certified by any appropriately qualified electrician prior to the issue of any Occupation Certificate.
3. Certification is to be provided that the commitments identified in the BASIX Certificate have been fulfilled.
4. The NPER registered Civil Engineer responsible for the supervision of the civil drainage works (Rainwater reuse, On-site Detention tank and rain garden) shall certify that the completed works have been constructed in accordance with this consent and the approved Construction Certificate. Works as Executed data certified by a registered surveyor prepared in accordance with Council's requirements is to be provided to Council. The Works as Executed information is to be verified by the Principal Certifying Authority prior to submission of any documentation to Council prior to issue of any occupancy certificate.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

5. Prior to the issuing of any Occupation Certificate, the applicant must provide details of sewer connection to an approved system.

Reason: Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

6. Restoration of all damaged public infrastructure caused as a result of the development to Council's satisfaction. Council's written approval that all restorations have been completed satisfactorily must be obtained and provided to the Private Certifying Authority with the Occupation Certificate application.

G. Advice:

1. Failure to comply with the relevant provisions of the *Environmental Planning and Assessment Act, 1979* (as amended) and/or the conditions of this Development Consent may result in the serving of penalty notices (on-the-spot fines) under the summary offences provisions of the above legislation or legal action through the Land and Environment Court, again pursuant to the above legislation.
2. Dial before you dig: Prior to excavation the applicant is advised to contact Australia's National Referral Service for Information on Underground Pipes and Cables telephone 1100 or www.1100.com.au
3. It is the Project Managers responsibility to ensure that all of the Component Certificates/certification issued during the course of the project are lodged with the Principal Certifying Authority. Failure to comply with the conditions of approval or lodge the Component Certificates/certification will prevent the Principal Certifying Authority issuing an Occupation Certificate.
4. In accordance with Section 95(1) of the EPA Act 1979, this development consent lapses 5 years after the date from which this consent operates if the development is not commenced.
5. To ascertain the date upon which a consent operates, refer to Section 83 of the *Environmental Planning and Assessment Act, 1979* (as amended).
6. Should any of the determination not be acceptable, you are entitled to request reconsideration under Section 82A of the Environmental Planning and Assessment Act, 1979. Such request to Council must be made in writing, together with appropriate fees as advised at the time of lodgement of such request, within 6 months of the determination.
7. If you are dissatisfied with this decision, Section 97 of the Environmental Planning and Assessment Act, 1979, gives you a right of appeal to the Land and Environment Court within 6 months of the date of endorsement of this Consent.
8. The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Waters sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. The approved plans will be appropriately stamped. For Quick Check agent details please refer to the web site at www.sydneywater.com.au then see Building Developing and Plumbing then Quick Check, or telephone 13 20 92.
9. This approval does not prejudice any action in respect of upgrading the building pursuant to the provisions of the Section 121B of the *Environmental Planning and Assessment (Amendment) Act, 1997*.

