

Waste Referral Response

Application Number:	Mod2024/0705
Proposed Development:	Modification of Development Consent REV2021/0034 granted for Review of Determination of Application DA2020/0442 for demolition works and construction of a Mixed Use Development comprising Shop Top Housing and retail premises, with associated carparking, landscaping and strata subdivision
Date:	08/04/2025
To:	Anaiis Sarkissian
Land to be developed (Address):	Lot B DP 316404 , 231 Whale Beach Road WHALE BEACH NSW 2107

Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

Officer comments

Supported, subject to conditions

Supported with conditions as imposed per Consent Annexure B to Judgement - Consolidated Conditions for MOD 2021/0983

Construction Managment Plan dated February 2020, Waste Management Plan dated 23/4/2020 and updated plans registered 6/12/2024

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Waste Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Waste/Recycling Requirements (Waste Plan Submitted)

During demolition and/or construction the proposal/works shall be generally consistent with the

submitted Construction Waste Management Plan Prepared by Auswide Consulting dated February 2020

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided.

Waste/Recycling Requirements (Materials)

During demolition and/or construction the following materials are to be separated for recycling: timber, bricks, tiles, plasterboard, metal, concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Pathway, access and door Requirements to bin storage room

The pathway and access between the Waste Storage Area and Collection Point will be:

- a) Solid, concrete, continuous, non-slip and clear of any obstructions and steps.
- b) A maximum ramp gradient of 1 in 8.
- c) Hazard free and not via a pathway with vehicular traffic.
- d) A minimum width of 1200mm. Any doors fitted on the Waste Storage Area, pathway and access will be:
 - e) A minimum width of 1200mm.
 - f) Able to be latched in an open position.
 - g) Unobstructed by any locks and security devices.
 - h) Openable in an outward direction.

Reason: To ensure clear and unobstructed access to the bin storage room for service requirements.

Garbage and Recycling Facilities

All internal walls of the waste rooms shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate cleaning.

Waste room floors shall be graded and drained to an approved Sydney Water drainage system.

Waste rooms shall be clear of any other services or utilities infrastructure such as gas, electricity air-conditioning, plumbing, piping ducting or equipment.

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.

Waste/Recycling Compliance Documentation

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Reason: To ensure waste is minimised and recycled.

Positive Covenant for Council and Contractor Indemnity

A positive covenant shall be created on the title of the land prior to the issue of an Occupation Certificate requiring the proprietor of the land to provide access to the waste storage facilities. The terms of the positive covenant are to be prepared to Council's requirements, (Appendix E of the Waste

Management Guidelines), at the applicant's expense and endorsed by Council prior to lodgement with NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities.

Authorisation of Legal Documentation Required for Waste Services

The original completed request form (NSW Land Registry Services form 13PC) must be submitted to Council for authorisation prior to the issue of an Occupation Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. A Compliance Certificate, issued by the Certifying Authority, shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Commercial Waste and Recycling Storage

Commercial waste and recycling material/storage bins must be stored in a separate area to the residential waste and recycling material/storage bins as shown on the approved plans.

Reason: To ensure that commercial waste and residential waste is not mixed and is properly managed.