

DEVELOPMENT APPLICATION ASSESSMENT REPORT

	-
Application Number:	DA2022/0614
Responsible Officer:	Phil Lane
Land to be developed (Address):	Lot B DP 404486, 116 Elimatta Road MONA VALE NSW 2103
Proposed Development:	Construction of a pool, cabana and pergola and associated landscape works
Zoning:	C4 Environmental Living
Development Permissible:	Yes
Existing Use Rights:	No
Consent Authority:	Northern Beaches Council
Land and Environment Court Action:	No
Owner:	Edward Ben Fitzpatrick Erin Louise Fitzpatrick
Applicant:	Shaun Douglas Wright
Application Lodged:	06/05/2022
Integrated Development:	No
Designated Development:	No
State Reporting Category:	Residential - Alterations and additions
Notified:	17/05/2022 to 31/05/2022
Advertised:	Not Advertised
Submissions Received:	1
Clause 4.6 Variation:	Nil

Estimated Cost of Works: \$ 270,000.00

Approval

PROPOSED DEVELOPMENT IN DETAIL

The proposed development consists of construction of a concrete swimming pool, a timber pergola and area extended off the existing alfresco level. Additionally, a cabana is proposed in the rear southwestern corner of the site.

ASSESSMENT INTRODUCTION

Recommendation:

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

• An assessment report and recommendation has been prepared (the subject of this report)

DA2022/0614 Page 1 of 28



taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;

- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral
 to relevant internal and external bodies in accordance with the Act, Regulations and relevant
 Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination):
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

SUMMARY OF ASSESSMENT ISSUES

Pittwater Local Environmental Plan 2014 - 7.1 Acid sulfate soils

Pittwater Local Environmental Plan 2014 - 7.2 Earthworks

Pittwater Local Environmental Plan 2014 - 7.7 Geotechnical hazards

Pittwater Local Environmental Plan 2014 - 7.10 Essential services

Pittwater 21 Development Control Plan - D9.7 Side and rear building line

Pittwater 21 Development Control Plan - D9.11 Landscaped Area - Environmentally Sensitive Land


SITE DESCRIPTION

Property Description:	Lot B DP 404486 , 116 Elimatta Road MONA VALE NSW 2103			
Detailed Site Description:	The subject site consists of one (1) allotment located on the western side of Elimatta Road.			
	The site is battleaxe allotment with a frontage of 4.2585m along Elimatta Road and a depth of 118.79m. The site has a surveyed area of 1707m ² .			
	The site is located within the C4 Environmental Living zone and accommodates two storey rendered dwelling.			
	The driveway handle slopes up before levelling out at the existing residence level then slopes down significantly throughout the rear garden toward the boundary.			
	The site has a number of native and exotic species of plants, shrubs and trees.			
	Detailed Description of Adjoining/Surrounding Development			
	Adjoining and surrounding development is characterised by one and two storey dwellings with associated outbuildings/structures with landscaped gardens.			

Map:

DA2022/0614 Page 2 of 28





SITE HISTORY

N0137/06 - Demolition and construction of new dwelling approved 8 May 2006

ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

ale.	
Section 4.15 Matters for Consideration	Comments
Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument	See discussion on "Environmental Planning Instruments" in this report.
Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument	Draft State Environmental Planning Policy (Remediation of Land) seeks to replace the existing SEPP No. 55 (Remediation of Land). Public consultation on the draft policy was completed on 13 April 2018. The subject site has been used for residential purposes for an extended period of time. The proposed development retains the residential use of the site, and is not considered a contamination risk.
Section 4.15 (1) (a)(iii) – Provisions of any development control plan	Pittwater 21 Development Control Plan applies to this proposal.
Section 4.15 (1) (a)(iiia) – Provisions of any planning agreement	None applicable.
Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2000 (EP&A Regulation 2000)	<u>Division 8A</u> of the EP&A Regulation 2000 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.
	Clauses 54 and 109 of the EP&A Regulation 2000 allow Council

DA2022/0614 Page 3 of 28



Section 4.15 Matters for Consideration	Comments
	to request additional information. No additional information was requested.
	Clause 92 of the EP&A Regulation 2000 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.
	Clauses 93 and/or 94 of the EP&A Regulation 2000 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This matter has been addressed via a condition of consent.
	Clause 98 of the EP&A Regulation 2000 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.
	Clause 98 of the EP&A Regulation 2000 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.
Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in	(i) Environmental Impact The environmental impacts of the proposed development on the natural and built environment are addressed under the Pittwater 21 Development Control Plan section in this report.
the locality	(ii) Social Impact The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.
	(iii) Economic Impact The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.
Section 4.15 (1) (c) – the suitability of the site for the development	The site is considered suitable for the proposed development.
Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs	See discussion on "Notification & Submissions Received" in this report.
Section 4.15 (1) (e) – the public interest	No matters have arisen in this assessment that would justify the refusal of the application in the public interest.

EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

BUSHFIRE PRONE LAND

DA2022/0614 Page 4 of 28



The site is not classified as bush fire prone land.

NOTIFICATION & SUBMISSIONS RECEIVED

The subject development application has been publicly exhibited from 17/05/2022 to 31/05/2022 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2000 and the Community Participation Plan.

As a result of the public exhibition process council is in receipt of 1 submission/s from:

Name:	Address:
Mr Sam Mansfield Hailes	116 A Elimatta Road MONA VALE NSW 2103

The following issues were raised in the submissions:

- Water tanks
- Swimming pool construction

The above issues are addressed as follows:

Water tanks

The submissions raised concerns that about the installation of water tanks on the subject site and water runnoff on the downstream property (116A Elimatta Road)

<u>Comment:</u> These issues are currently been investigated by Council's Building Compliance Department via BLD2022/00477 and has no bearing on this assessment of this application. It was noted that Council's Planner during his site inspection on 3 June 2022 did not sight any water tanks on the subject site.

It is considered that these issues have been adequately addressed and do not warrant refusal and/or further amendment via condition(s).

Swimming pool construction

The submissions raised concerns that crane in the swimming pool and the land has no structurally set of such weight.

<u>Comment:</u> The application was lodged with a Preliminary Geotechnical Assessment which recommends methodology and construction processes and recommendations. Additionally it is noted that the swimming pool is a concrete swimming pool and therefore will be constructed on site.

It is considered that these issues have been adequately addressed and do not warrant refusal and/or further amendment via condition(s).

REFERRALS

DA2022/0614 Page 5 of 28



Internal Referral Body	Comments
Landscape Officer	The development application is for construction of a pool, cabana, pergola, and associated works, as described and illustrated in the reports and plans.
	Council's Landscape Referral is assessed against the Pittwater Local Environment Plan clause C4 zone Environmental Living, and the following Pittwater 21 DCP controls (but not limited to): • B4.22 Preservation of Trees and Bushland Vegetation • C1.1 Landscaping • D9 Mona Vale Locality
	The site is located in the C4 Environmental Living zone, requiring development to achieve a scale integrated with the landform and landscape, and to minimise impact on the natural environment, including the retention of natural landscape features and existing trees, to satisfy the landscape objectives of the C4 Environmental Living zone. It is noted there is a non-compliance with the landscaped area requirements, however this matter shall be determined by the Assessing Planner.
	An Arboricultural Impact Assessment (AIA) and Landscape Plan are included in the application and will be assessed as part of the Landscape Referral. The application proposes to remove three moderate to high significant trees (T6-T8) as identified in the AIA. A further four trees (T2-T5) are proposed to be removed which are exempt due to species or size, thus do not require consent for removal. Three high significant trees (T9-T11) in the rear of the property will be retained, and the tree protection measures, outlined in the AIA, are supported subject to the imposed conditions. Any works around T1 shall be supervised by the Project Arborist subject to the imposed conditions. The lower lawn area shall maintain existing levels in the tree protection zone of T9-T11 and cabana works shall not extend beyond its footprint. No replacement trees are shown on the Landscape Plan, however to offset canopy loss three trees must be installed, within the property boundary, subject to the imposed conditions.
	The Statement of Environmental Effects proposes additional soft landscaping along the northern and southern boundaries, however no species or locations are shown on the Landscape Plan. The proposed pool coping finish level will be approximately 1.5 metres above the natural ground level of the neighbouring property, to the south, and this matter shall be determined by the Assessing Planner. Should the application be approved, screen planting shall be installed adjacent to the pool subject to the imposed conditions. The Project Arborist shall provide recommendations should any fill, to be installed as part of the works, be identified as an impact to any neighbouring trees not assessed in the AIA.

External Referral Body	Comments	

DA2022/0614 Page 6 of 28



External Referral Body	Comments
	The proposal was referred to Ausgrid. No response has been received within the 21 day statutory period and therefore, it is assumed that no objections are raised and no conditions are recommended.

ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)*

All, Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

SEPP (Building Sustainability Index: BASIX) 2004

A BASIX certificate has been submitted with the application (see Certificate No. A449262 dated 18 February 2022). A condition has been included in the recommendation of this report requiring compliance with the commitments indicated in the BASIX Certificate.

SEPP (Transport and Infrastructure) 2021

<u>Ausgrid</u>

Section 2.48 of Chapter 2 requires the Consent Authority to consider any development application (or an application for modification of consent) for any development carried out:

- within or immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).
- immediately adjacent to an electricity substation.
- within 5.0m of an overhead power line.
- includes installation of a swimming pool any part of which is: within 30m of a structure supporting an overhead electricity transmission line and/or within 5.0m of an overhead electricity power line.

Comment:

The proposal was referred to Ausgrid. No response has been received within the 21 day statutory period and therefore, it is assumed that no objections are raised and no conditions are recommended.

SEPP (Resilience and Hazards) 2021

DA2022/0614 Page 7 of 28



Chapter 4 – Remediation of Land

Sub-section 4.6 (1)(a) of Chapter 4 requires the Consent Authority to consider whether land is contaminated. Council records indicate that the subject site has been used for residential purposes for a significant period of time with no prior land uses. In this regard it is considered that the site poses no risk of contamination and therefore, no further consideration is required under sub-section 4.6 (1)(b) and (c) of this Chapter and the land is considered to be suitable for the residential land use.

Pittwater Local Environmental Plan 2014

Is the development permissible?	Yes		
After consideration of the merits of the proposal, is the development consistent with:			
aims of the LEP?			
zone objectives of the LEP?	Yes		

Principal Development Standards

Standard	Requirement	Proposed	% Variation	Complies
Height of Buildings:	8.5m	3.5m	-	Yes

Compliance Assessment

Clause	Compliance with Requirements
Part 1 Preliminary	Yes
1.9A Suspension of covenants, agreements and instruments	Yes
Part 4 Principal development standards	Yes
4.3 Height of buildings	Yes
Part 5 Miscellaneous provisions	Yes
5.10 Heritage conservation	Yes
5.21 Flood planning	Yes
Part 7 Additional local provisions	Yes
7.1 Acid sulfate soils	Yes
7.2 Earthworks	Yes
7.7 Geotechnical hazards	Yes
7.10 Essential services	Yes

Detailed Assessment

7.1 Acid sulfate soils

Clause 7.1 Acid Sulfate Soils requires Council to ensure that development does not disturb, expose or drain acid sulfate soils and cause environmental damage. In this regard, development consent is required for the carrying out of works described on land shown on the Acid Sulfate Soils Map as being of the class specified for those works. The site is located in an area identified as Acid Sulfate Soil Class 5, as indicated on Council's Acid Sulfate Soils Planning Map. The proposal is acceptable in relation to

DA2022/0614 Page 8 of 28



acid sulfate soils.

7.2 Earthworks

The objective of Clause 6.2 Earthworks requires development to ensure that earthworks for which development consent is required will not have a detrimental impact on environmental functions and processes, neighbouring uses, cultural or heritage items or features of the surrounding land.

In this regard, before granting development consent for earthworks, Council must consider the following matters:

(a) the likely disruption of, or any detrimental effect on, existing drainage patterns and soil stability in the locality of the development

Comment:

The proposal is unlikely to unreasonably disrupt existing drainage patterns and soil stability in the locality.

(b) the effect of the proposed development on the likely future use or redevelopment of the land Comment:

The proposal will not unreasonably limit the likely future use or redevelopment of the land.

(c) the quality of the fill or the soil to be excavated, or both Comment:

The excavated material will be processed according to the Waste Management Plan for the development. A condition has been included in the recommendation of this report requiring any fill to be of a suitable quality.

(d) the effect of the proposed development on the existing and likely amenity of adjoining properties Comment:

The proposed earthworks will not result in unreasonable amenity impacts on adjoining properties. Conditions have been included in the recommendation of this report to limit impacts during excavation/construction.

(e) the source of any fill material and the destination of any excavated material Comment:

The excavated material will be processed according to the Waste Management Plan for the development. A condition has been included in the recommendation of this report requiring any fill to be of a suitable quality.

(f) the likelihood of disturbing relics

Comment:

The site is not mapped as being a potential location of Aboriginal or other relics.

(g) the proximity to, and potential for adverse impacts on, any waterway, drinking water catchment or environmentally sensitive area

Comment:

The site is not located in the vicinity of any watercourse, drinking water catchment or environmentally sensitive areas.

(h) any appropriate measures proposed to avoid, minimise or mitigate the impacts of the development. Comment:

Conditions are included in the recommendation of this report that will minimise the impacts of the development.

DA2022/0614 Page 9 of 28



(i) the proximity to and potential for adverse impacts on any heritage item, archaeological site or heritage conservation area.

Comment:

The site is not a heritage item, in the vicinity of a heritage item or in a conservation area or archaeological site.

7.7 Geotechnical hazards

Under Clause 7.7 Geotechnical Hazards, before determining a development application for development on land to which this clause applies, the consent authority must consider the following matters to decide whether or not the development takes into account all geotechnical risks:

- (a) site layout, including access,
- (b) the development's design and construction methods,
- (c) the amount of cut and fill that will be required for the development,
- (d) waste water management, stormwater and drainage across the land,
- (e) the geotechnical constraints of the site,
- (f) any appropriate measures proposed to avoid, minimise or mitigate the impacts of the development. Comment:

The proposed development is supported by a geotechnical risk assessment and architectural plans that demonstrate all geotechnical risks have been taken into account. The application has been reviewed and is supported, subject to conditions of consent.

Development consent must not be granted to development on land to which this clause applies unless:

(a) the consent authority is satisfied that the development will appropriately manage waste water, stormwater and drainage across the land so as not to affect the rate, volume and quality of water leaving the land, and

Comment:

The proposed development is supported by a geotechnical risk assessment and plans that demonstrate waste water, stormwater and drainage are suitably managed on site. The application has been reviewed and is supported, subject to conditions of consent.

- (b) the consent authority is satisfied that:
- (i) the development is designed, sited, and will be managed to avoid any geotechnical risk and significant adverse impact on the development and the land surrounding the development, or (ii) if that risk or impact cannot be reasonably avoided the development is designed, sited and will be managed to minimise that risk or impact, or
- (iii) if that risk or impact cannot be minimised the development will be managed to mitigate that risk or impact.

Comment:

Council can be satisfied that the proposed development has been designed, sited, and will be managed to avoid any geotechnical risk and significant adverse impact on the development and the land surrounding the development subject to conditions.

7.10 Essential services

Under this clause, development consent must not be granted to development unless the consent authority is satisfied that any of the following services that are essential for the development are available or that adequate arrangements have been made to make them available when required:

DA2022/0614 Page 10 of 28



- (a) the supply of water,
- (b) the supply of electricity,
- (c) the disposal and management of sewage,
- (d) stormwater drainage or on-site conservation,
- (e) suitable vehicular access.

Comment:

The subject site is supplied with the above essential services. The proposed development retains and relies upon these services.

Pittwater 21 Development Control Plan

Built Form Controls

Built Form Control	Requirement	Proposed	% Variation*	Complies
Rear building line	6.5m	2.593m	60.1%	No
Side building line	2.5m	S: 1.65m	34%	No
	1m	N: 1.507m	-	Yes
Building envelope	3.5m	S: Within envelope	-	Yes
		N: Within envelope	-	Yes
Landscaped area	Min. 60% (1024.2sqm)	56.2% (960.1sqm)	6.3%	No

Compliance Assessment

Clause	Compliance with Requirements	Consistency Aims/Objectives
Section A Shaping Development in Pittwater	Yes	Yes
A1 Introduction	Yes	Yes
A1.7 Considerations before consent is granted	Yes	Yes
A4 Localities	Yes	Yes
A4.9 Mona Vale Locality	Yes	Yes
Section B General Controls	Yes	Yes
B1 Heritage Controls	Yes	Yes
B1.3 Heritage Conservation - General	Yes	Yes
B1.4 Aboriginal Heritage Significance	Yes	Yes
B3 Hazard Controls	Yes	Yes
B3.1 Landslip Hazard	Yes	Yes
B3.6 Contaminated Land and Potentially Contaminated Land	Yes	Yes
B4 Controls Relating to the Natural Environment	Yes	Yes
B4.5 Landscape and Flora and Fauna Enhancement Category 3 Land	Yes	Yes
B5 Water Management	Yes	Yes
B5.15 Stormwater	Yes	Yes
B6 Access and Parking	Yes	Yes
B6.3 Off-Street Vehicle Parking Requirements	Yes	Yes

DA2022/0614 Page 11 of 28



Clause	Compliance with Requirements	Consistency Aims/Objectives
B6.7 Transport and Traffic Management	Yes	Yes
B8 Site Works Management	Yes	Yes
B8.1 Construction and Demolition - Excavation and Landfill	Yes	Yes
B8.3 Construction and Demolition - Waste Minimisation	Yes	Yes
B8.4 Construction and Demolition - Site Fencing and Security	Yes	Yes
Section C Development Type Controls	Yes	Yes
C1 Design Criteria for Residential Development	Yes	Yes
C1.1 Landscaping	Yes	Yes
C1.2 Safety and Security	Yes	Yes
C1.3 View Sharing	Yes	Yes
C1.4 Solar Access	Yes	Yes
C1.5 Visual Privacy	Yes	Yes
C1.6 Acoustic Privacy	Yes	Yes
C1.7 Private Open Space	Yes	Yes
C1.12 Waste and Recycling Facilities	Yes	Yes
C1.13 Pollution Control	Yes	Yes
C1.14 Separately Accessible Structures	Yes	Yes
C1.17 Swimming Pool Safety	Yes	Yes
C1.23 Eaves	Yes	Yes
C1.25 Plant, Equipment Boxes and Lift Over-Run	Yes	Yes
Section D Locality Specific Development Controls	Yes	Yes
D9 Mona Vale Locality	Yes	Yes
D9.1 Character as viewed from a public place	Yes	Yes
D9.2 Scenic protection - General	Yes	Yes
D9.3 Building colours and materials	Yes	Yes
D9.6 Front building line	Yes	Yes
D9.7 Side and rear building line	No	Yes
D9.11 Landscaped Area - Environmentally Sensitive Land	No	Yes
D9.12 Fences - General	Yes	Yes

Detailed Assessment

D9.7 Side and rear building line

Detailed description of non-compliance

Side building line

The control requires structures to be setback 2.5m from at least one side boundary and 1.0m to the other side.

The proposed swimming pool and cabana is set back 1.507m from the southern boundary resulting in a 34% variation of the 2.5m side setback requirement.

DA2022/0614 Page 12 of 28



Rear building line

The proposed pool is set back 2.593m from the rear boundary resulting in a 60.1% variation of rear set back of 6.5m.

Merit Consideration

With regard to the consideration for a variation, the development is considered against the underlying objectives of the control as follows:

To achieve the desired future character of the Locality.

Comment:

Under A4.9 of P21 DCP, the proposal is consistent with the objectives of the desired future character of Mona Vale. The abovementioned works are low-lying and well below the 8.5m development standard. The bulk and scale of the development is minor in nature and is unlikely to impact upon the amenity of adjoining properties.

• The bulk and scale of the built form is minimised.

Comment:

The proposed roofs is a lightweight single storey structure, which will not result in any adverse building bulk. In addition, the proposed swimming pool will be excavated in-ground and does not contribute to the bulk and scale of the built form.

• Equitable preservation of views and vistas to and/or from public/private places.

Comment:

The works are low-lying and will not result in the loss of views.

 To encourage view sharing through complimentary siting of buildings, responsive design and well-positioned landscaping.

Comment:

As discussed above, the proposal will not result in the loss of views.

• To ensure a reasonable level of privacy, amenity and solar access is provided within the development site and maintained to residential properties.

Comment:

The proposal will provide adequate separation between the adjoining boundary fences. Adjoining properties will not be adversely affected by this proposal, as the proposed pool and cabana will be low-lying and is appropriately setback from adjoining buildings to minimise the noise impacts associated with its use. It is noted that conditions from Council's Landscape Officer requires continuous screen planting along the southern boundary to ensure reasonable amenity is maintained. Furthermore, these works are unlikely to cause significant overshadowing to adjoining properties given the low-lying nature.

Substantial landscaping, a mature tree canopy and an attractive streetscape.

Comment:

The proposed development does not involve the removal of any significant vegetation and will

DA2022/0614 Page 13 of 28



allow for substantive landscaping across the site. Council's Landscape Officer has reviewed the proposal and raised no objection subject to conditions.

Flexibility in the siting of buildings and access.

Comment:

The development has been sited appropriately in accordance with the site constraints and the surrounding residential context, ensuring reasonable amenity can be maintained for the dwelling occupants and those of adjoining and surrounding properties. Access to the site will remain relatively unaltered from existing.

• Vegetation is retained and enhanced to visually reduce the built form.

Comment:

The proposal does not include the removal of any significant vegetation and will not result in an unreasonable built form within the locality.

• To ensure a landscaped buffer between commercial and residential zones is established.

Comment:

This clause is not applicable.

Having regard to the above assessment, it is concluded that the proposed development is consistent with the relevant objectives of P21DCP and the objectives specified in s1.3 of the Environmental Planning and Assessment Act, 1979. Accordingly, this assessment finds that the proposal is supported, in this particular circumstance.

D9.11 Landscaped Area - Environmentally Sensitive Land

Description of non-compliance

The application proposes a total landscaped area of 56.2% (960.1m2), which fails to comply with the 60% (1024sqm) requirement representing a variation of 6.3% (64.1sqm).

Merit consideration

With regard to the consideration for a variation, the development is considered against the underlying objectives of the Control as follows:

Achieve the desired future character of the locality.

Comment:

The proposed development is generally consistent with the desired character statement of the Mona Vale locality.

The bulk and scale of the built form is minimised.

Comment:

The proposal achieves general compliance with the relevant development controls used to assess the bulk and scale of a development, including; building envelope and maximum building height. It is considered that the bulk and scale of the development is appropriately integrated into the landform and landscape.

DA2022/0614 Page 14 of 28



A reasonable level of amenity and solar access is provided and maintained.

Comment:

The proposal will allow for sufficient provisions of privacy, amenity and solar access to be maintained throughout the subject site and adjoining properties.

Vegetation is retained and enhanced to visually reduce the built form.

Comment:

As discussed elsewhere in this report, the proposal's design is adequately sited to maintain ample landscaped areas around the development that will assist in visually reducing the built form.

Conservation of natural vegetation and biodiversity.

Comment:

The proposed development will enhance the site's natural features with a high quality landscape design; therefore, providing adequate opportunities for natural vegetation and biodiversity.

• Stormwater runoff is reduced, preventing soil erosion and siltation of natural drainage channels.

Comment:

The proposal is subject to conditions which will ensure that stormwater runoff will be appropriately controlled, preventing soil erosion and siltation of natural drainage channels.

• To preserve and enhance the rural bushland character of the area.

Comment:

Development within the subject streetscape and surrounding locale consists of low density residential developments of varying styles and scales within altered landscaped settings, such that the character of the area would not be classified as rural or bushland. However, the site is sufficiently landscaped and the proposed development being within the rear yard will remain unseen as viewed from the streetscape.

• Soft surface is maximised to provide for infiltration of water to the water table, minimise run-off and assist with stormwater management.

Comment:

The site will remain afforded with sufficient soft surface so as to provide for infiltration of water to the water table, minimise run-off and assist with stormwater management.

Having regard to the above assessment, it is concluded that the proposed development is consistent with the relevant objectives of PLEP 2014 / P21DCP and the objectives specified in s1.3 of the Environmental Planning and Assessment Act, 1979. Accordingly, this assessment finds that the proposal is supported, in this particular circumstance.

THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

DA2022/0614 Page 15 of 28



CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

POLICY CONTROLS

Northern Beaches Section 7.12 Contributions Plan 2021

The proposal is subject to the application of Northern Beaches Section 7.12 Contributions Plan 2021.

A monetary contribution of \$2,700 is required for the provision of new and augmented public infrastructure. The contribution is calculated as 1% of the total development cost of \$270,000.

CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2000;
- All relevant and draft Environmental Planning Instruments;
- Pittwater Local Environment Plan;
- Pittwater Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2022/0614 for Construction of a pool, cabana and pergola and associated landscape works on land at Lot B DP 404486, 116 Elimatta Road, MONA VALE, subject to the conditions printed below:

DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

DA2022/0614 Page 16 of 28



1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

a) Approved Plans

Architectural Plans - Endorsed with Council's stamp			
Drawing No.	Dated	Prepared By	
C1	17 February 2022	Contour Landscape Architecture	
C2	17 February 2022	Contour Landscape Architecture	
C3	17 February 2022	Contour Landscape Architecture	
C4	17 February 2022	Contour Landscape Architecture	
C5	17 February 2022	Contour Landscape Architecture	
C6	17 February 2022	Contour Landscape Architecture	
C7	17 February 2022	Contour Landscape Architecture	
C8	17 February 2022	Contour Landscape Architecture	

Reports / Documentation – All recommendations and requirements contained within:			
Report No. / Page No. / Section No.	Dated	Prepared By	
Preliminary Geotechnical Assessment	4 April 2022	Ascent Geo	
Arboricultural Impact Appraisal and Method Statement	25 February 2022	Ezigrow	

- b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.
- c) The development is to be undertaken generally in accordance with the following:

Waste Management Plan			
Drawing No/Title.	Dated	Prepared By	
C9	17 February 2022	Contour Landscape Architecture	
Waste Management Plan	20 February 2022	Shaun Wright	

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

DA2022/0614 Page 17 of 28



2. Prescribed Conditions

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
 - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
 - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
 - (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
 - (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
 - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
 - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

DA2022/0614 Page 18 of 28



In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

3. General Requirements

(a) Unless authorised by Council:Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (c) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (d) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (e) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (f) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) No trees or native shrubs or understorey vegetation on public property (footpaths,

DA2022/0614 Page 19 of 28



roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.

- (k) Prior to the commencement of any development onsite for:
 - i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (I) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (m) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
 - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2018
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

DA2022/0614 Page 20 of 28



Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

FEES / CHARGES / CONTRIBUTIONS

4. Policy Controls

Northern Beaches 7.12 Contributions Plan 2021

A monetary contribution of \$2,700.00 is payable to Northern Beaches Council for the provision of local infrastructure and services pursuant to section 7.12 of the Environmental Planning & Assessment Act 1979 and the Northern Beaches Section 7.12 Contributions Plan 2021. The monetary contribution is based on a development cost of \$270,000.00.

The monetary contribution is to be paid prior to the issue of the first Construction Certificate or Subdivision Certificate whichever occurs first, or prior to the issue of the Subdivision Certificate where no Construction Certificate is required. If the monetary contribution (total or in part) remains unpaid after the financial quarter that the development consent is issued, the amount unpaid (whether it be the full cash contribution or part thereof) will be adjusted on a quarterly basis in accordance with the applicable Consumer Price Index. If this situation applies, the cash contribution payable for this development will be the total unpaid monetary contribution as adjusted.

The proponent shall provide to the Certifying Authority written evidence (receipt/s) from Council that the total monetary contribution has been paid.

The Northern Beaches Section 7.12 Contributions Plan 2021 may be inspected at 725 Pittwater Rd, Dee Why and at Council's Customer Service Centres or alternatively, on Council's website at www.northernbeaches.nsw.gov.au

This fee must be paid prior to the issue of the Construction Certificate. Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To provide for contributions in accordance with the Contribution Plan to fund the provision of new or augmented local infrastructure and services.

5. Security Bond

A bond (determined from cost of works) of \$1,500 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is

DA2022/0614 Page 21 of 28



located on Council's website at www.northernbeaches.nsw.gov.au).

Reason: To ensure adequate protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

6. Stormwater Drainage Disposal

The stormwater drainage systems for the development are to be designed, installed and maintained in accordance with Council's Water Management for Development Policy.

All stormwater drainage systems must comply with the requirements of Council's Water Management for Development Policy. Any recommendations identified within a Geotechnical Report relevant to the development are to be incorporated into the design of the stormwater drainage system. Details demonstrating compliance from a qualified and practising Civil Engineer and where relevant a Geotechnical Engineer must be submitted to and approved by the Certifying Authority prior to the issue of a Construction Certificate.

When the proposed discharge point for the development in this consent cannot strictly comply with the Water Management for Development Policy, the Applicant must apply to verify the proposed discharge point by gaining Council approval via a Stormwater Drainage Application. Council approval must be provided to the Certifying Authority prior to the issue of a Construction Certificate when a Stormwater Drainage Application is required. The Stormwater Drainage Application form can be found on Council's website.

Compliance with this condition must not result in variations to the approved development or additional tree removal.

Reason: To ensure satisfactory management of stormwater.

7. Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report referenced in Condition 1 of this consent are to be incorporated into the construction plans.

Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

8. Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

DA2022/0614 Page 22 of 28



9. External Finishes to Roof

The external finish to the roof shall have a medium to dark range (BCA classification M and D) in order to minimise solar reflections to neighbouring properties. Any roof with a metallic steel finish is not permitted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that excessive glare or reflectivity nuisance does not occur as a result of the development. (DACPLC03)

10. Sydney Water "Tap In"

The approved plans must be submitted to the Sydney Water Tap in service, prior to works commencing, to determine whether the development will affect any Sydney Water assets and/or easements. The appropriately stamped plans must then be submitted to the Certifying Authority demonstrating the works are in compliance with Sydney Water requirements.

Please refer to the website www.sydneywater.com.au for:

- "Tap in" details see http://www.sydneywater.com.au/tapin
- Guidelines for Building Over/Adjacent to Sydney Water Assets.

Or telephone 13 000 TAP IN (1300 082 746).

Reason: To ensure compliance with the statutory requirements of Sydney Water.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

11. **Project Arborist**

A Project Arborist with minimum AQF Level 5 in arboriculture shall be engaged to provide tree protection measures in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites, and the recommendations of the Arboricultural Impact Assessment.

The Project Arborist shall be in attendance and supervise all works as nominated in the Arboricultural Impact Assessment, and in particular:

- i) tree protection measures under section 4 Arboricultural Method Statement, in particular 4.2, 4.4, 4.5 and 4.6,
- ii) works under Appendix 7 Schedule of works and responsibilities,
- iii) any works which will impact neighbouring trees not identified in the Arboricultural Impact Assessment,
- iv) any landscaping works within the TPZ of existing trees to be retained.

Existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by the Project Arborist.

All tree protection measures specified must:

- a) be in place before work commences on the site, and
- b) be maintained in good condition during the construction period, and
- c) remain in place for the duration of the construction works.

The Project Arborist shall provide certification to the Certifying Authority that all recommendations listed for the protection of the existing tree(s) have been carried out

DA2022/0614 Page 23 of 28



satisfactorily to ensure no impact to the health of the tree(s). Photographic documentation of the condition of all trees to be retained shall be recorded, including at commencement, during the works and at completion.

Note:

- i) A separate permit or development consent may be required if the branches or roots of a protected tree on the site or on an adjoining site are required to be pruned or removed.
- ii) Any potential impact to trees as assessed by the Project Arborist will require redesign of any approved component to ensure existing trees upon the subject site and adjoining properties are preserved and shall be the subject of a modification application where applicable.

Reason: Tree protection.

12. Tree Removal Within the Property

This consent approves the removal of the following tree(s) within the property (as recommended and identified by tree number in the Arboricultural Impact Assessment):

- i) T6 Eucalyptus punctata, T7 Macadamia tetraphylla and T8 Syncarpia glomulifera,
- ii) a qualified AQF level 5 Arborist shall identify these trees on site and tag or mark prior to removal.

Reason: To enable authorised development works.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

13. Tree and Vegetation Protection

- a) Existing trees and vegetation shall be retained and protected, including:
- i) all trees and vegetation within the site, excluding exempt trees and vegetation under the relevant planning instruments of legislation,
- ii) all trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation,
- b) Tree protection shall be undertaken as follows:
- i) tree protection shall be in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites, including the provision of temporary fencing to protect existing trees within 5 metres of development,
- ii) existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by an Arborist with minimum AQF Level 5 in arboriculture,
- iii) removal of existing tree roots at or >25mm (\emptyset) diameter is not permitted without consultation with an Arborist with minimum AQF Level 5 in arboriculture,
- iv) no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) structures are to bridge tree roots at or >25mm (\emptyset) diameter unless directed by an Arborist with minimum AQF Level 5 in arboriculture on site,
- vi) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with an Arborist with minimum AQF Level 5 in arboriculture including advice on root protection measures,
- vii) should either or all of v) or vi) occur during site establishment and construction works, an Arborist with minimum AQF Level 5 in arboriculture shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,

DA2022/0614 Page 24 of 28



viii) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of Australian Standard 4970-2009 Protection of Trees on Development Sites,

ix) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with Australian Standard 4373-2007 Pruning of Amenity Trees, and should additional pruning be required an application to Council's Tree Services shall be submitted for approval or otherwise.

The Certifying Authority must ensure that:

c) The activities listed in section 4.2 of Australian Standard 4970-2009 Protection of Trees on Development Sites, do not occur within the tree protection zone of any tree, and any temporary access to, or location of scaffolding within the tree protection zone of a protected tree, or any other tree to be retained on the site during the construction, is undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of that standard.

Note: All street trees within the road verge and trees within private property are protected under Northern Beaches Council development control plans, except where Council's written consent for removal has been obtained. The felling, lopping, topping, ringbarking, or removal of any tree (s) is prohibited.

Reason: Tree and vegetation protection.

14. Condition of Trees

During the construction period the applicant is responsible for ensuring all existing trees required to be retained are maintained in a healthy and vigorous condition. This is to be done by ensuring that all identified tree protection measures are adhered to, or by seeking arboricultural advice from the Project Arborist during the works. In this regard all protected trees shall not exhibit:

- i) a general decline in health and vigour,
- ii) damaged, crushed or dying roots due to poor pruning techniques,
- iii) more than 10% loss or dieback of roots, branches and foliage,
- iv) mechanical damage or bruising of bark and timber of roots, trunk and branches,
- v) yellowing of foliage or a thinning of the canopy untypical of its species,
- vi) an increase in the amount of deadwood not associated with normal growth,
- vii) an increase in kino or gum exudation,
- viii) inappropriate increases in epicormic growth that may indicate that the plants are in a stressed condition,
- ix) branch drop, torn branches and stripped bark not associated with natural climatic conditions.

Any mitigating measures and recommendations required by the Project Arborist are to be implemented.

The owner of the adjoining allotment of land is not liable for the cost of work carried out for the purpose of this clause.

Reason: Protection of trees.

15. Survey Certificate

A survey certificate prepared by a Registered Surveyor is to be provided demonstrating all perimeter walls columns and or other structural elements, floor levels and the finished roof/ridge

DA2022/0614 Page 25 of 28



height are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To demonstrate the proposal complies with the approved plans.

16. Installation and Maintenance of Sediment Control

Prior to any works commencing on site, including demolition, sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

17. Required Tree Planting

Three (3) locally native trees shall be planted within the property boundary, with at least two trees planted within the rear setback, to achieve at least 6 metres height at maturity, and shall be selected from Northern Beaches Council's Native Plant Species Guide - Pittwater Ward, and in accordance with the following:

- i) at least two trees shall be an Angophora, Corymbia or Eucalyptus species,
- ii) tree planting shall be a minimum planting size of 75 litres, and shall meet the requirements of Natspec Specifying Trees,
- iii) planted into a prepared planting hole 1m x 1m x 600mm depth, backfilled with a sandy loam mix or approved similar, mulched to 75mm depth minimum and maintained, and watered until established, and shall be located at least 3.0 metres from buildings and other trees, and at least 1.5 metres from common boundaries, and located either within garden bed or within a prepared bed within lawn.
- iv) tree planting shall be positioned in locations to minimise significant impacts on neighbours in terms of blocking winter sunlight to living rooms, private open space and where the proposed location of trees may otherwise be positioned to minimise any significant loss of views from neighbouring and nearby dwellings and from public spaces.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate.

Reason: To maintain environmental amenity.

18. Required Screen Planting

Screen planting shall be installed in accordance with the following:

- i) create a continuous screen adjacent to the pool along the south-eastern boundary, from the existing residence to at least the retaining wall which divides the lawn area and lower lawn area,
- ii) be a suitable pot size so that plant height is at least 1.5 metres at installation,
- iii) selected planting shall comply with the requirement of Australian Standard AS 1926.1 for a Non Climbable Zone.

DA2022/0614 Page 26 of 28



The selected planting is to comprise of native species capable of attaining a height of 2 metres above pool coping finish level at maturity.

Plants are to be installed at intervals, appropriate to the selected species, so that individual plants knit together to form a continuous screen. Plants are to be installed in a garden bed prepared with a suitable free draining soil mix and minimum 50mm depth of mulch.

Reason: To maintain environmental amenity.

19. Condition of Retained Vegetation - Project Arborist

Prior to the issue of an Occupation Certificate, a report prepared by the project arborist shall be submitted to the Certifying Authority, assessing the health and impact on all existing trees required to be retained, including the following information:

- i) compliance to any Arborist recommendations for tree protection generally and during excavation works.
- ii) extent of damage sustained by vegetation as a result of the construction works,
- iii) any subsequent remedial works required to ensure the long term retention of the vegetation.

Reason: Tree protection.

20. Geotechnical Certification Prior to Occupation Certificate

The Applicant is to submit the completed Form 3 of the Geotechnical Risk Management Policy (Appendix 5 of P21 DCP) to the Principal Certifying Authority prior to issue of the Occupation Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

21. Landscape Maintenance

If any landscape materials/components or planting under this consent fails, they are to be replaced with similar materials/components. Trees and shrubs required to be planted under this consent are to be mulched, watered and fertilised as required at the time of planting.

If any tree or shrub required to be planted under this consent fails, they are to be replaced with similar species to maintain the landscape theme and be generally in accordance with any conditions of consent.

All weeds are to be removed and controlled in accordance with the NSW Biosecurity Act 2015.

Reason: To maintain local environmental amenity.

22. Geotechnical Recommendations

Any ongoing recommendations of the risk assessment required to manage the hazards identified in the Geotechnical Report referenced in Condition 1 of this consent are to me maintained and adhered to for the life of the development.

DA2022/0614 Page 27 of 28



Reason: To ensure geotechnical risk is mitigated appropriately.

23. Swimming Pool/Spa Motor Noise

The swimming pool / spa motor shall not produce noise levels that exceed 5dB(A) above the background noise when measured from the nearest property boundary.

Reason: To ensure that the development does not impact on the acoustic privacy of surrounding residential properties.

In signing this report, I declare that I do not have a Conflict of Interest.

Signed

Phil Lane, Principal Planner

The application is determined on 06/06/2022, under the delegated authority of:

Rodney Piggott, Manager Development Assessments

DA2022/0614 Page 28 of 28