



All pipes unless otherwise specified on the plan to be 100 dia. UPVC pipe.  
Inspection openings will be required at even spacings not more than 30 metres apart and at any change of direction greater than 45 degrees.  
HP - High Points in the guttering  
DP - Downpipes  
Drainage Pipe Notes.  
Slope of pipes to be a minimum of 1:100 i.e. 1%  
All levels and dimensions to be checked and confirmed on site.

All design work and works to be in accordance with AS/NZS 3500.5 (2000) and AS/NZS 3500.3.2 (1998)  
The Eaves Gutter minimum of 125mm D Gutter with a cross sectional area of 6300 sq. mm (as taken from Lysaght Pty Ltd), or similar. Downpipes attached to the eaves gutter to have a minimum diameter of 90mm or similar.  
Downpipes can be connected to existing stormwater pipes. However, existing pipelines need to be checked and repaired in accordance to AS3500.  
Dimensions and slope of existing need to be checked in accordance with AS3500 to ensure adequacy.  
Tank dimensions shown in drawing is not to scale. Tanks sizes should be determined with consideration on height limits.