

## Natural Environment Referral Response - Flood

Application Number:	DA2021/2605
Date:	20/01/2022
To:	Penny Wood
Land to be developed (Address):	Lot 5 DP 31077 , 10 Evelyn Place BELROSE NSW 2085

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The proposed DA generally complies with the flood controls in the LEP and DCP. A new house is proposed above the FPL. The second storey is above the PMF level.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Flooding

In order to protect property and occupants from flood risk the following is required:

##### Flood Effects Caused by Development – A2

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level of 163.40m AHD.

##### Building Components and Structural Soundness – B1

All new development below the Flood Planning Level of shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

##### Building Components and Structural Soundness – B2

All new development must be designed to ensure structural integrity up to the Probable Maximum Flood

(164.0m AHD), taking into account the forces of floodwater, wave action, flowing water with debris, buoyancy and immersion.

#### Building Components and Structural Soundness – B3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed to cut electricity supply during flood events.

#### Floor Levels – C1

New floor levels within the development shall be set at or above the Flood Planning Level of 163.40m AHD plus 500mm.

#### Car parking – D5

The floor level of the proposed garage shall be set at or above the 1% AEP flood level of 163.40m AHD.

#### Fencing – F1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level. Openings should be a minimum of 75mm x 75mm.

#### Storage of Goods – G1

Storage areas for hazardous or potentially polluting materials shall not be located below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

#### Recommendations

The development must comply with the recommendation outlined in the Flood Impact & Risk Assessment at 10 Evelyn Place, Belrose prepared by Ibrahim Stormwater Consultants dated December 2021.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.