

Development Application **ACCESS REPORT**

Reference Number: 22250

Client: Pyco at Greenslopes Pty Ltd

Site Address: 27 Waine St, Freshwater



Vista Access Architects Pty. Ltd.

www.accessarchitects.com.au

admin@accessarchitects.com.au

PO Box 353, Kingswood NSW 2747

ABN: 82124411614

Executive Summary and Design Compliance Statement

This Access Compliance Report is to accompany a Development Application (DA) for the development proposed at **27 Waine St, Freshwater**

The development is within Northern Beaches Council LGA and proposes a **New Building**. The Council requires 10% of Adaptable units to a **Class C** level.

The development proposes the following:

Residential units	4
Adaptable units	1
Livable Housing Units	1 required, however all 4 are capable of compliance
Accessible parking spaces	1

The development has building classification as detailed below:

- Class 2 (building containing more than 2 SOUs i.e., sole-occupancy units)
- Class 7a (car park)

This report is based on the relevant components of:

- Building Code of Australia (BCA) 2022, Volume 1- Performance requirements of D1P1, D1P2, D1P8, D1P9, E3P4, F4P1 and Parts D4, E3 and F4 (where applicable)
- Disability (Access to Premises-Building) Standards 2010 (henceforth referred to as APS)
- AS1428.1-2009 Part 1: General requirements for access, including any amendments
- AS1428.4.1-2009 Part 4.1: TGSIs (Tactile ground surface indicators), including any amendments
- AS2890.6-2009 Part 6: Off-street parking for people with disabilities.
- AS4299-1995 Adaptable Housing
- AS1735-1999 Lift types included in the BCA including Part 12: Facilities for persons with disabilities
- State Environmental Planning Policy 65 (SEPP 65), Objective 4Q1, relating to requirements of the provision of Livable Housing Australia's Silver Level Apartments
- Livable Housing Australia's Livable Housing Design Guidelines- Fourth Edition

The assessment of the proposed development has been undertaken to the extent necessary to issue DA consent under the Environmental Planning and Assessment Act. The proposal achieves the spatial requirements to provide access for people with a disability and it is assumed that assessment of the detailed requirements such as assessment of internal fit-out, details of stairs, ramps and other features will occur at CC (Construction Certificate) stage.

By compliance with the recommendation in this report, the development complies with the requirements of Access Code of Disability (Access to Premises-Building) Standards 2010, the Disability Access relevant sections of Building Code of Australia, the essential criteria of AS4299-Adaptable Housing and the requirements of SEPP 65 related to Objective 4Q1 - Livable Housing

The information contained in this statement is true and accurate to the best of our knowledge. Our qualifications and accreditations are listed below.

Assessed by



Jenny Desai

Accredited Access Consultant and LHA Assessor
ACAA Accredited Membership number 572
Qualified- Certificate IV in Access Consulting
LHA Assessor Licence number 20242

Peer reviewed by



Farah Madon

Accredited Access Consultant and LHA Assessor
ACAA Accredited Membership number 281
Qualified- Diploma in Access Consulting
LHA Assessor Licence number 10032

Vista Access Architects Pty. Ltd.

Relevant Dates:

Fee proposal, number FP-22550 dated **4-07-2022**. Fee proposal was accepted by Client on **15-07-2022**

Assessed Drawings:

The following drawings by Fuse Architects have been assessed for compliance.

Drawing no	Issue	Date	Details
DA004	P3	14-06-2023	Site plan
DA101	P3	14-06-2023	Basement & Ground Floor Plan
DA102	P3	14-06-2023	Level 01 & 02 Floor Plans
DA103	P3	14-06-2023	Level 3 & Roof Plans
DA602	P2	14-06-2023	Adaptable cum livable unit

Document Issue:

Issue	Date	Details
Draft 1	01-08-2022	Issued for Architect's review
Draft 3	26-09-2022	Issued for Architect's review
Issue A	29-09-2022	Issued for Architect's review
Issue B	07-06-2023	Issued for Architect's review
Issue C	30-06-2023	Issued for DA

Limitations and Copyright information:

This report is based on discussions with the project architect and a review of drawings and other relevant documentation provided to us. No site visit was undertaken for the purposes of this report.

This assessment is based on the provided drawings and not based on constructed works; hence the assessment will provide assurance of compliance only if all the recommendations as listed in this report are complied with and constructed in accordance with the requirements of the current BCA, AS1428.1, AS2890.6 and other latest, relevant standards and regulations applicable at the time of construction.

Assessment is based on classification/use of the building. If the class of the building changes to any other building class, this access report will have to be updated accordingly.

Unless stated otherwise, all dimensions mentioned in the report are net (CLEAR) dimensions and are not to be reduced by projecting skirting, kerbs, handrails, lights, fire safety equipment, door handles less than 900mm above FFL (finished floor level) or any other fixtures/fit out elements. When we check drawings, we assume that the dimensions noted are CLEAR dimensions and therefore the Architect / Builder shall allow for construction tolerances.


Only some numerical requirements from relevant AS (Australian Standards) have been noted in the report and for further details and for construction purposes refer to the latest relevant AS.

This report and all its contents including diagrams are a copyright of Vista Access Architects Pty Ltd (VAA) and can only be used for the purposes of this specific project. Copy-pasting diagrams from this report to Architectural plans will constitute copyright infringement.

This report does not assess compliance matters related to WHS, Structural design, Services design, Parts of DDA other than those related to APS or Parts of BCA or Parts of AS other than those directly referenced in this report. VAA gives no warranty or guarantee that this report is correct or complete and will not be liable for any loss arising from the use of this report. We will use our best judgement regarding LHA assessments. However, we are not to be held responsible if another licenced LHA assessor comes to a different conclusion about compliance, certification, or allocation of a particular Quality mark to us as several items in LHA are subject to interpretation.

We have no ability to check for slip resistance of surfaces. All wet areas, parking areas, pavement markings shall have the appropriate slip resistance for the location. We also have no ability to check for wall reinforcements once the walls have already been constructed. The builder shall take full responsibility that the requirements listed in this report are met and the construction and slip resistance shall be as per requirements of AS1428.1/ AS4299 / AS2890.6/ AS3661/ AS4586/ HB197/ HB198 and any other applicable regulation and Australian Standard

Hierarchy of Access-related Legislation and Standards



The Federal Disability Discrimination Act 1992 (DDA) provides protection for everyone in Australia against discrimination based on disability. Section 32 of the DDA focuses on the provision of equitable and dignified access to services and facilities for people with mobility, sensory and cognitive disabilities.

Disability discrimination happens when people with a disability and their relatives, friends, carers, co-workers or associates are treated less fairly than people without a disability.

Compliance with Access to Premises Standards give certainty to building certifiers, building developers and building managers that, if access to (new parts) of buildings is provided in accordance with these Standards, the provision of that access, to the extent covered by these Standards, will not be unlawful under the DDA. This however applies only to the new building or new parts of an existing building and its affected part. All areas outside the scope of these areas are still subject to the DDA. We cannot guarantee or certify for DDA compliance because DDA compliance can only be assessed by the Courts.

Scope of DDA extends beyond the building fabric and also includes furniture and fittings.

Compliance assessment with Access related requirements of BCA and Disability (Access to Premises-Building) Standards 2010 (APS)

Development consists of new building/s and therefore compliance is required to full development

BCA 2022 Part D4 Access for People with a Disability D4D2 General building Access requirements

SOU refers to a Sole Occupancy Unit

Requirement

Class 2 - building containing more than 2 SOUs i.e. sole-occupancy units
For residential use components, access is required:

- From a required accessible pedestrian entrance to at least 1 floor with SOUs and till the entry of door of each SOU on that level.
- To and within 1 of each type of room or space in common use.
- Where floor is accessed by an AS1428.1 ramp or lift, access is required to the entry doorway of each SOU on that level and to and within all common use areas on that level.

Compliance

Complies

Comments

- Access has been provided from the main pedestrian entry doorway to the entry doors of all SOUs on all levels by means of accessible pathways and lifts.
- Access has been provided to at least 1 of each common use areas
- Access has been provided to common use garbage storage rooms
- Where common use areas are on a floor that is accessible by means of a ramp or lift (Ground floor level and Levels 3 in this case), access has been provided to the same.
- Access is provided to common use letterbox area with min 1540x2070mm flat circulation space in front of the letterboxes.
- All common use accessway widths are to be a minimum of 1M clear measured from skirting to skirting (increases to comply with door circulation spaces where doorways provided) with vertical clearance of at least 2M

Details to be verified at CC stage of works.

Requirement

Class 7a - Covered car park.

- To and within any level containing accessible carparking spaces.

Compliance

Capable of compliance (Subject to performance solution for accessible car parking space design at CC stage)

Comments

Access has been provided to basement level containing Accessible carparking spaces.
All Accessway widths are to be a minimum of 1M clear (measured from skirting to skirting) with vertical clearance of at least 2M

Details to be verified at CC stage of works.

BCA 2022 Part D4D3 Access to buildings

Requirement

Accessway is required from:

- Main pedestrian entry at the site boundary for new buildings.
- Any other accessible building connected by a pedestrian link.
- Accessible car parking spaces.

Compliance

Complies

Comments

- Level Access has been provided from the main pedestrian entry at the site boundary.
- Access has been provided from accessible car parking spaces by means of lifts.

Details to be verified at the CC stage of works.

Requirement

Common use External Walkway / Pedestrian access requirements as per AS1428-2009:


- Accessible path of travel to have a gradient no steeper than 1 in 20 and a cross fall no steeper than 1:40 (1:33 for bitumen).
- For 1:20 grade walkways, landings are required every 15M.
- The floor surface abutting the sides of the walkway to be provided with a firm and level surface (of a different material) at the same level and grade of the walkway and extend horizontally for a minimum of 600mm unless one of the following is provided: kerb, kerb-rail and handrail or wall of minimum 450mm height.
- Curved walkways to be min 1500mm width with crossfall towards the centre of curvature.
- At 90-degree bends in pathways provide a 1500mmx1500mm space with maximum 500mm splay permitted at internal corner.

Compliance

Complies with spatial requirements

Comments

Details to be verified at the CC stage of works.



[Image description: Spatial requirements of walkways with bends as per AS1428.1]

Requirement

Common use floor or ground surfaces

- Use slip-resistant surfaces
- The texture of the surface is to be traversable by people who use a wheelchair and those with an ambulant or sensory disability.
- Abutment of surfaces is to have a smooth transition.
- Construction tolerances to be +/- 3mm vertical or +/-5mm, provided the edges have a bevelled or rounded edge (See diagrams below)

Grates if used in the accessible path of travel are required to comply with the following:

- Circular openings maximum of 13 mm in diameter
- Slotted openings maximum of 13 mm wide and be oriented so that the long dimension is transverse to the dominant direction of travel

Where slotted openings are less than 8 mm, the length of the slots may continue across the width of paths of travel

Compliance

Capable of compliance

Comments

Details to be verified at the CC stage of works.

Requirement

Accessway is required through:

- Principal pedestrian entry; and
- Not less than 50% of all pedestrian entrances; and
- In building with floor area over 500m², a non-accessible entry must not be located more than 50M from an accessible entry.

Compliance

Complies

Comments

The building has only 1 pedestrian entry, which has been designed to be accessible.

Requirement

All common use doorways and doorways to and within Adaptable units to comply with AS1428.1. Where accessible pedestrian entry has Multiple doorways:

- At least 1 to be accessible if 3 provided
- At least 50% to be accessible, if more than 3 provided
- Where doorway has multiple leaves, at least 1 leaf is to have clear opening of 850mm (excluding automatic doors)

Doorway requirements

- All common use doorways in the development within accessible path of travel (other than non-accessible sanitary facilities) to have a clear opening of at least 850mm with appropriate door circulation spaces in accordance with AS1428.1. In case of multiple leaf doorways, at least 1 operable leaf is required to provide a clear opening of 850mm with the door circulations spaces as per AS1428.1.
- Ambulant toilet cubicle door to have a clear door opening of 700mm.
- Space required for door circulation spaces to have a maximum floor grade of 1:40 (doorway threshold ramps are permitted within the circulation space).


- Door thresholds are to be level, or they can incorporate a doorway threshold ramp with a maximum grade of 1:8, for maximum rise of 35mm and a maximum length of 280mm and located within 20mm of the door leaf, with edges to be tapered or splayed at a minimum of 45° where it does not abut a wall.
- Sliding doorways to be provided with recessed floor tracks to enable flush transition from the inside of the building.
- Distance between successive doorways in airlocks to be 1450mm which is measured when the door is in open position in case of swinging doors.
- Door hardware including door handles, door closers and the in-use indicators / snibs in accessible and ambulant toilets are required to comply with requirements of AS1428.1.
- Luminance contrast requirements to doorways and other glazed areas to comply with AS1428.1

Compliance

Complies with spatial requirements


Comments

Details to be verified at the CC stage of works.



[Image description: Diagram showing requirements for door circulation spaces and door threshold requirements as per AS1428.1 for clear opening (D)=850mm]

For surface mounted sliding doors, circulation space on the opposite side of the door face will increase by the value of the wall thickness to the face of the door.



Requirement

Step ramp if provided in common use areas is to be compliant with AS1428.1-2009 including;

- Max grade of 1:10, max height of 190mm, max length of 1.9M
- Slip resistance of ramp and landings to comply with BCA Table D2.14.

A landing for a step ramp must not overlap a landing for another step ramp or ramp

Compliance N/A

Comments

No step ramps have been identified on plans.

Requirement

Kerb ramp if provided in common use areas is to be compliant with AS1428.1-2009

Compliance N/A

Comments

No kerb ramps have been identified in the development.

Requirement

Every **Stairway** in common use areas (excluding fire-isolated stairway) is to be compliant with:

- Clause 11 of AS1428.1-2009 (including but not limited to opaque risers, handrails on both sides including appropriate handrail extensions between 1M clear width and compliant nosing strips).
- Diameter of handrails to be between 30mm-50mm and located not less than 50mm from adjacent walls with no obstructions to top 270° arc.
- Slip resistance to comply with BCA Table D2.14 when tested in accordance with AS4586.

Compliance Complies with spatial requirements


Comments

Where non-fire-isolated stairways have been provided, the features of the stairway will be assessed with the requirements of AS1428.1-2009 at the CC stage of works


Note: In some cases, the stairway from the basement to the ground floor level is considered to be non-fire-isolated, in which case full compliance will be required as per AS1428.1-2009. Verify with the BCA consultant if this is the case.

Note: For stairways with 90° to 180° turns at landings, in order for the handrails to comply with the consistent height requirement, the risers have to be offset at the mid-landings so that no vertical sections are created in the handrails. This applies to both non-fire-isolated and fire-isolated stairways.

Option A- extend handrail by 1 tread at midlanding
Option B- offset first riser going up at midlanding



[Image description: Diagram showing the requirements of a non-fire-isolated stairway as per AS1428.1]



600-800 TGSIs are required where the distance of the landing is 3000mm or more. For landings less than 3000mm, reduce the width of TGSIs to 300-400

Requirement

Every **Fire-isolated Stairway** is to be compliant with AS1428.1-2009 in the following aspects:

- Handrail on one side (requirement under D2.17) with 1M clear space. Handrail extensions are not required however since the handrails cannot have any vertical sections and since handrail is required to be at a consistent height throughout the stairway including at landings, it may be essential to either provide handrail extensions or offset first riser going up at mid landings to achieve this at 90° to 180° turns. Handrails to both sides of the stairway are required if the total width of the stairway is 2M or more.
- Diameter of handrails to be between 30mm-50mm and located not less than 50mm from adjacent walls with no obstructions to top 270° arc.
- Slip resistance to comply with BCA Table D2.14 when tested in accordance with AS4586.


Compliance

Complies with spatial requirements

Comments

Where fire-isolated stairways have been provided, the features of the stairway will be assessed with the requirements of AS1428.1-2009 at the CC stage of works
Handrails to both sides are not required, however the internal handrail is to be continuous and to comply with all requirements of non-fire-isolated stairways.

Option A- extend handrail by 1 tread at midlanding
Option B- offset first riser going up at midlanding



[Image description: Diagram showing the requirements of a fire-isolated stairway as per AS1428.1]

Requirement

Nosing for common use fire-isolated and non-fire-isolated stairways require the following:

- Each tread to have a nosing strip between 50mm-75mm depth (of any one colour) for the full width of the stair, which can be setback for a maximum of 15mm from the front of the nosing.
- Multiple strips making up the 50mm-75mm depth is NOT permitted.
- This strip is to have a minimum luminance contrast of 30% to the background and to comply with any change in level requirements if attached on the treads.
- Where the nosing strip is not set back from the front of the nosing then any area of luminance contrast shall not extend down the riser more than 10mm
- Slip resistance to comply with BCA Table D2.14 when tested in accordance with AS4586.

Compliance

Capable of compliance

Comments

Detailed features of the nosing strips will be assessed with the requirements of AS1428.1 at the CC stage of works.

Requirement

Slip resistance to comply with BCA 2022, Table D3D15 when tested in accordance with AS4586.

BCA 2022, Table D3D15 Slip –resistance requirements when tested in accordance with AS4586:

Application	Surface conditions	
	Dry	Wet
Ramp steeper than 1:14	P4 or R11	P5 or R12
Ramp steeper than 1:20 but not steeper than 1:14	P3 or R10	P4 or R11
Tread or landing surface	P3 or R10	P4 or R11
Nosing or landing edge strip	P3	P4

Slip resistance requirements as per AS4299

AS4299 has slip resistance requirements based on requirements of AS3661 (Slip resistance of pedestrian surfaces) for the following areas:

- Floor surfaces in sanitary facilities including all toilets and bathrooms (essential feature).
- Floor surfaces in the kitchens and Laundries (essential feature).
- Pathways / walkways within the site, within landscaped areas, balconies and other external paved areas (desirable feature for Class A or B developments).
- AS3661.1-1993 is an old Australian standard which has been superseded with AS4586:2013 (Slip resistance classification of new pedestrian surface materials).

HB 197/ HB198 An introductory guide to the slip resistance of pedestrian surface materials provides guidelines for the selection of slip-resistant pedestrian surfaces

Compliance

Capable of compliance

Comments

For Slip resistance of surfaces the builder is required to provide a Certificate stating that the Slip resistance of the surfaces comply with the above listed requirements when tested as per AS4586 at CC stage of works.

Requirement

Every **Passenger lift** is to comply with the requirements of BCA E3.6.

Compliance

Complies with spatial requirements

Comments

This has been assessed further in the report in the Lifts section. Refer to Lifts section.

Requirement

Passing spaces requirement

It is a requirement to provide passing spaces in common use accessways complying with AS1428.1 at maximum 20 M intervals, where a direct line of sight is not available. Space required is 1800x2800mm (in the direction of travel). Chamfer of 400x400mm is permitted at corners.

Compliance N/A

Comments

There are no accessways over 20M lengths in the development where a direct line of sight is not available.

Requirement

Turning spaces requirement

It is a requirement to provide turning spaces in common use accessways complying with AS1428.1-2009 within 2M of the end of accessways where it is not possible to continue travelling and at every 20M intervals. CLEAR Space required is 1540mmx2070mm in the direction of travel (measured from skirting to skirting).

Compliance Complies

Comments

- Adequate turning spaces have been provided with minimum common use passageway widths being 1540mm clear or alternatively a space of 1540mmx2070mm provided at or within 2M of the end of the passageway.
- A space of 1540mmx2070mm is also required / provided in front of all passenger lift doors

Details to be verified at CC stage of works.

Requirement

Carpet specifications

Carpet if used in areas required to be accessible are to be provided with pile height or thickness not more than 11mm and carpet backing not more than 4mm bringing the total height to a maximum of 15mm.

Compliance N/A

Comments

Use of carpets have not been identified in the common use areas
Details to be verified at CC stage of works.

BCA 2022 Part D4D5 Exemption

Requirement

Access is not required to be provided in the following areas:

- Where access would be inappropriate because of the use of the area
- Where area would pose a health and safety risk
- Any path which exclusively provides access to an exempted area

Compliance

For information only

Comments

Areas such as lift machine rooms, fire services room, commercial kitchens etc. in the development are exempted from providing access under this clause due to WHS concerns.

Where a caretaker is provided in the development, the toilet provided exclusively for use by the caretaker can be excluded from providing access based on the provisions in this clause.

BCA 2022 Part D4D6 Accessible Carparking

Requirement

Class 2

There are no Accessible carparking requirements for a Class 2 under the BCA.

If adaptable housing has been mandated by the Council, then carparking spaces for Adaptable units will be required under the requirements of AS4299- Adaptable housing.

Compliance


Capable of compliance (Subject to performance solution for accessible car parking space design at CC stage)

Comments

Subject to performance solution at CC stage

Northern Beaches Council requires provision of 10% Adaptable units in the development. Development has total number of 4 units. $10\% \text{ of } 4 = 0.4 = 1$ required Adaptable unit. Therefore, 1 accessible carparking spaces are required for the residential component of the development.

1 Accessible car parking spaces has been provided in development which is required to be allocated to the Adaptable unit.



[Image description: Plan of basement above shows the provision of Accessible parking spaces]

AS2890.6-2009 requirements for Accessible car parking space

Requirement


- Dedicated space 2.4Mx5.4M, Shared space 2.4Mx5.4M at the same level
- Slip resistant flooring surface with maximum fall 1:40 in any direction or maximum 1:33 if bituminous and outdoors.
- Central Bollard in shared space at 800+/-50mm from entry point.
- Pavement marking in dedicated space by means of access symbol between 800mm-1000mm high placed on a blue rectangle of maximum 1200mm and between 500mm-600mm from its entry point (marking not required where allocated to an Adaptable unit).
- Minimum headroom of 2.2M at entrances and 2.5M is required over shared space as well as dedicated spaces.
- Non-trafficked area of the shared space to have marking strips at 45°, 150-200mm wide at 200mm-300mm spaces (not required where driveways are used as shared spaces)
- The pavement marking shall have the appropriate slip resistance for the location. This requirement is to be added to the project specifications to ensure compliance.

Compliance

Capable of compliance (subject to a performance solution for use of side aisle as shared zone of accessible parking space at CC stage of works)

Comments

Details to be verified at CC stage of works.



BCA 2022 Part D4D7 Signage

Requirement

Braille and Tactile signage are required to identify Accessible Sanitary facilities

Compliance N/A

Comments

No common use sanitary facilities have been identified in the development.

Requirement

Braille and Tactile signage are required immediately outside an airlock or doorway that leads to separate male, female and accessible toilets.

Compliance N/A

Comments

No common use sanitary facilities have been identified in the development.

Requirement

Braille and Tactile signage are required to identify Ambulant Sanitary facilities

Compliance N/A

Comments

No common use sanitary facilities have been identified in the development.

Requirement

Braille and Tactile signage is required to identify Hearing Augmentation

Compliance N/A

Comments

Hearing augmentation is not provided since there is no inbuilt amplification system identified in the development.

Requirement

Braille and Tactile signage is required to identify a Fire exit door required by E4.5 by stating the 'Exit' and 'Level', followed by either the floor level number or floor level descriptor or a combination of both of the above and located on the side that faces a person seeking egress

Exit Level ?

[Image description: Image of Signage The "?" shown in image is to be replaced with the floor level where the door is located]

Compliance Capable of compliance

Comments

Signage selections generally take place at CC stage of works. Selection and location of signage as specified above will lead to compliance. Details of selected signage to be verified at CC stage of works.

Requirement

Signage is required to a non-accessible pedestrian entrance

Compliance N/A

Comments

The development has only 1 entry which has been designed to be accessible.

Requirement

Signage is required where a bank of sanitary facilities is not provided with an accessible unisex sanitary facility.

Compliance N/A

Comments

No common use sanitary facilities have been identified in the development.

Requirement

Signage is required to be as per Specification D3.6 Braille and Tactile Signs

This includes location of signage, specifications in regard to braille and tactile characters, luminance contrast and lighting.

Compliance Capable of compliance

Comments

Signage selections generally take place at CC stage of works. Selection and location of signage as specified above will lead to compliance. Details of selected signage to be verified at CC stage of works.

BCA 2022 Part D4D8 Hearing Augmentation

Requirement

Hearing Augmentation is only required where an inbuilt amplification system (other than emergency) is installed in a Class 9b building, or in an auditorium, conference / meeting room or a reception area where a screen is used.

Compliance N/A

Comments

No areas with provision of inbuilt amplification have been identified on plans and hence no hearing augmentation requirements apply to this development.

BCA 2022 Part D4D9 Tactile ground surface indicators (TGSIs)

Requirement

TGSIs are required when approaching:

- Stairways other than fire-isolated stairways.
- Escalators / passenger conveyor / moving walk.
- Ramp (other than fire-isolated ramps, kerb ramps, step ramps or swimming pool ramps).
- Under an overhead obstruction of <2M if no barrier is provided.
- When accessway meets a vehicular way adjacent to a pedestrian entry (if no kerb / kerb ramp provided at the location).

Compliance is required with AS1428.4.1 including Luminance contrast and slip resistance requirements for all TGSIs. TGSIs to extend for full width i.e., handrail to handrail.

Compliance

Capable of compliance

Comments

TGSI selections generally take place at CC stage of works. Selection of TGSIs as specified will lead to compliance and these selection details are to be verified at CC stage of works.

BCA 2022 Part D4D12 Limitations on Ramps

Requirement

On an accessway:

- A series of connected ramps must not have a combined vertical rise of more than 3.6M;
- And a landing for a step ramp must not overlap a landing for another step ramp or ramp.

Compliance

N/A

Comments

No step ramps have been provided.

BCA 2022 Part D4D13 Glazing on Accessways

Requirement

Glazing requirements:

- Where there is no chair rail, handrail or transom, all frameless or fully glazed doors, sidelights and any glazing capable of being mistaken for a doorway or opening are required to have a glazing strip
- The marking should be for the full width with a solid and non-transparent 75mm wide, contrasting line located 900-1000mm above FFL and provide a minimum luminance contrast of 30% when viewed against the floor surface within 2M of the glazing on the opposite end. Graphical representation or cut-outs are not permitted.

Compliance

Capable of compliance

Comments

Glazing strips are required to be provided to full height glazed areas (doors and windows) used in common use areas such as lift lobbies and common passageways

Glazing strip selections generally take place at CC stage of works. Selection of glazing strips as specified above will lead to compliance and details are to be verified at CC stage of works.

BCA Part F Accessible Sanitary Facilities

BCA 2022 Part F4D5 Accessible Sanitary facilities

Requirement

Accessible unisex toilet is to be provided in accessible part of building such that;

- It can be entered without crossing an area reserved for 1 sex only
- Where male and female sanitary facilities are provided at different locations, Accessible unisex toilet is only required at one of the locations
- Even distribution of LH and RH facilities
- An accessible facility is not required on a level with no lift / ramp access.

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

BCA 2022 Part F4D6 Accessible unisex sanitary compartments

Requirement

Class 2

At least 1 unisex Accessible toilet when sanitary compartments are provided in common areas.

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

BCA 2022 Part F4D7 Requirements for Accessible unisex showers

Requirement

Class 2

At least 1 unisex Accessible shower when showers are provided in common areas.

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

Requirement

Toilets / Showers for Accessible use are to be designed in accordance with AS1428.1

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

Requirement

Ambulant use male / female toilets are to be provided if an additional toilet to the Accessible unisex toilet is provided

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

Requirement

Ambulant use toilets are to be designed in accordance with AS1428.1-2009

Compliance N/A

Comments

No common use sanitary facilities have been identified on the plans

BCA Part E Lift Installations

BCA 2022 Part E3D3 Stretcher facility in lifts

Requirement

A **Stretcher lift** is to be provided if a passenger lift is installed to serve any storey with an effective height of 12M. The space requirement is 600mm wide x 2000mm deep x 1400mm high above the floor level. Confirm this requirement with your BCA consultant.

Compliance For information only

Comments

Contact BCA consultant in regard to applicable requirements.

BCA 2022 Part E3D7 Passenger lift and their limitations

Requirement

In an accessible building, **Every Passenger Lift** (excluding electric passenger lift, electrohydraulic passenger lift, inclined lift) must be subject to limitations on use and must comply with **BCA 2022, E3D7, E3D8 and E3D10**

Compliance Capable of compliance

Comments

A certificate of compliance from the lift supplier, stating that the proposed lift complies with the requirements of BCA Part E3- Lift installations will be required at the CC stage of works

Limitations on use of types of passenger lifts

Requirement

Limitations on use of Stairway platform lifts, Low-rise platform lift, Low-rise, low-speed constant pressure lift and small sized, low-speed automatic lift

Compliance

N/A

Comments

Not identified in the development.

BCA 2022 Part E3D8 Accessible features required for passenger lifts

Requirement

Handrail requirements for passenger lifts. Apart from stairway platform lift and low-rise lifts, a handrail is required as per AS1735.12:

- 600mm minimum handrail not more than 500mm from control panel
- Top of handrail between 850-950mm above FFL
- Diameter of handrails to be between 30-50mm and located not less than 50mm from adjacent walls with no obstructions to top 270° arc

Lift floor dimensions (excluding stairway platform lift)

- Lifts traveling **12M** or under, floor size, **1100mm wide x 1400mm deep**
- Lifts travelling **more than 12M**, floor size **1400mm wide x 1600mm deep**

Minimum **Door opening size** complying with AS1735.12, not less than 900mm clear (excluding stairway platform lift).

All lifts with a power operated door are required to have a **Passenger protection system** complying with AS1735.12.

Lift landing doors to be provided at upper landing (excluding stairway platform lift).

Lift car and landing control buttons complying with AS1735.12

Some of the requirements listed below. Refer to AS1735.12 for further details.

For internal control panel:

- If width or depth of car is less than 1400mm, 2 control panels to be provided, one to the left and one to the right of the person entering the car
- Tactile symbol and Braille equivalent to be provided
- Buttons to be located between 900-1100mm above FFL
- All buttons to be 300mm from corner (near entry) and 400mm of all other corners

For external control panel:

To be located between 900-1100mm above FFL and not less than 500mm from internal corners unless otherwise permitted by AS1735.12

Lighting (for all enclosed lift cars) to be provided in accordance with AS1735.12 and AS1680. Minimum illuminance of 100 lx is required at the level of the car floor and average of 50 lx is required on the control panel surface.

To all lifts serving more than 2 levels

- Automatic audible information to identify level when car stops

- Audible and visual indication at landing to indicate arrival of lift car
Audible information and indication to be provided between 20-80 dB(A) at a maximum frequency of 1500Hz

Emergency hands free communication (excluding stairway platform lift) – provide a button that alerts a call centre and a light that the call has been received.

Compliance

Capable of compliance

Comments

A certificate of compliance from the lift supplier, stating that the proposed lift complies with the requirements of BCA Part E3- Lift installations will be required at the CC stage of works

AS4299.1995- Adaptable Housing

Appendix A of AS4299 schedule is a list of features to be incorporated into a housing unit for it to be termed an 'Adaptable House'.

There are 3 Classification levels for Adaptable Housing

Adaptable Class C in which all essential features are to be incorporated.


Adaptable Class B in which all Class C and 50% of 64 available desirable features are to be incorporated

Adaptable Class A in which all 119 essential and all desirable features are to be incorporated.


1 Adaptable unit is required by the Council's DCP to a **Class C** level.

The unit designated as adaptable is unit number 101.

Pre-adaptation layout



Post-adaptation layout



By incorporating the essential requirements listed Checklist below in the Specifications, the nominated Adaptable units can achieve full compliance with Adaptable House Class C

AS4299.1995 - Class C – Essential requirements



R☑ = Required;

C☑ = Capable of compliance at **by adding the requirement to the project specifications** or in some cases capable of compliance at post adaptation stage (where noted in comments).

	Clause No	Requirements as per AS4299	R	C	Comments
	Drawings				
1	2.3	Provision of drawings showing the housing unit in its pre-adaptation and post-adaptation stages	☑	☑	

	Clause No	Requirements as per AS4299	R	C	Comments
	Siting				
3	3.3.2	A continuous accessible path of travel from street frontage and vehicle parking to entry complying with AS 1428.1	✓	✓	Access is provided from street by means of an AS1428.1 compliant walkway and from accessible parking space by means of a lift. Details to be verified at the CC stage
	Letter boxes				
11	3.8	Letterboxes to be on hard standing area connected to accessible pathway	✓	✓	Letterboxes for all Adaptable units to be between 900mm to 1100mm above FFL and min 500mm from any internal corner. Details to be verified at the CC stage
	Parking				
14	3.7.2	Car parking space or garage min. area 6.0Mx 3.8M or a hard surfaced level outside of 5.4Mx3.8M is provided as a sheltered car park or can be provided in the future	✓	✓	Can also be provided as per AS2890.6, which is permissible. Details to be verified at the CC stage
	Accessible Entry				
20	4.3.1	Accessible entry	✓	✓	Refer to door circulation requirements noted earlier in the report. Details to be verified at the CC stage
22	4.3.2	Accessible entry to be level (i.e. maximum of 1:40 slope)	✓	✓	
23	4.3.2	Threshold to be low-level	✓	✓	
24	4.3.2	Landing to enable wheelchair manoeuvrability	✓	✓	
25	4.3.1	Accessible entry door to have 850mm min. clearance	✓	✓	Usually achieved by 920mm door leaf. Door circulation spaces to be as per AS1428.1
27	4.3.4	Door lever handles and hardware to AS1428.1	✓	✓	Details to be verified at the CC stage
	Interior: General				
32	4.3.3	Internal doors to have 820mm minimum clearance	✓	✓	Provide an 850mm clear opening door to the adaptable bathroom and 1 main bedroom. Rest to have 820mm clear opening.
33	4.3.7	Internal corridors min. width of 1000mm	✓	✓	

	Clause No	Requirements as per AS4299	R	C	Comments
34	4.3.7	Provision for compliance with AS1428.1 for door approaches	✓	✓	Can be compliant post adapt, with easily removable cabinetry.
Living room and dining room					
36	4.7.1	Circulation space of min. 2250mm diameter.	✓	✓	
38	4.7.4	Telephone adjacent to GPO	✓	✓	Details to be verified at the CC stage
41	4.10	Potential illumination level minimum 300 lux	✓	✓	Details to be verified at the CC stage
Kitchen					
42	4.5.2	Minimum width 2.7M, (1550mm clear between benches)	✓	✓	Can be compliant post adaptation.
43	4.5.1	Provision for circulation at doors to comply with AS1428.1	✓	✓	N/A, No door provided to kitchen.
44	4.5.5	Provision for benches to include at least one work surface of 800mm length, adjustable in height from 750mm to 850mm or replaceable.	✓	✓	Can be compliant post adaptation.
45	4.5.5	Refrigerator adjacent to work surface	✓	✓	Can be compliant post adaptation.
46	4.5.6	Kitchen sink adjustable to heights from 750mm to 850 mm or replaceable	✓	✓	Can be compliant post adaptation.
47	4.5.6	Kitchen sink bowl maximum 150mm deep	✓	✓	Can be compliant post adaptation.
48	4.5.6 e	Tap set capstan or lever handles or lever mixer	✓	✓	Can be compliant post adaptation.
49	4.5.6 e	Tap set located within 300mm of front of sink	✓	✓	Can be compliant post adaptation.
51	4.5.7	Cooktops to include either front or side controls with raised cross bars.	✓	✓	Can be compliant post adaptation.
52	4.5.7	Cooktops to include isolating switch	✓	✓	Can be compliant post adaptation.
53	4.5.7	Work surface minimum 800 mm length, adjacent to cook top at same height	✓	✓	Can be compliant post adaptation.
54	4.5.8	Oven located adjacent to an adjustable height or replaceable work surface. It is recommended that a side door opening wall oven is provided with the clear work surface to be on the opposite side of the hinge.	✓	✓	Can be compliant post adaptation.
59	4.5.11	GPOs to comply with AS1428.1. At least one double GPO within 300mm of front of work surface.	✓	✓	Can be compliant post adaptation.

	Clause No	Requirements as per AS4299	R	C	Comments
60	4.5.11	GPO for refrigerator to be easily reachable when the refrigerator is in its operating position.	✓	✓	Can be compliant post adaptation.
61	4.5.4	Slip-resistant floor surface as per AS3661 and AS 4586	✓	✓	Details to be verified at the CC stage.
Main bedroom					
		 <p>[Image description: Diagram showing circulation spaces around a queen bed as per AS4299]</p>			
62	4.6.1	At least one bedroom of area sufficient to accommodate queen size bed and wardrobe and circulation space requirements of AS1428.2	✓	✓	A space of 1.54Mx2.07M at the base or one side of the bed is considered to be compliant.
Main Adaptable bathroom					
75	4.4.1	Provision for bathroom area to comply with AS1428.1	✓	✓	A bathroom with minimum space of 2Mx 2.95M or 2.3Mx2.7M or 2.4Mx2.45M is required.
		 <p>[Image description: Diagram shows Post Adaptation bathroom layout and location of wall reinforcements in pre-adaptation locations with reference to post adaptation layout] Noted dimensions on the above diagrams are approximate and depend on selected features such as size of the basin.</p>			
76	4.4.2	Slip-resistant floor surface as per AS3661 and AS 4586	✓	✓	Details to be verified at the CC stage

	Clause No	Requirements as per AS4299	R	C	Comments
77	4.4.4 f	Shower recess - no hob. Minimum size 1160x1100mm to comply with AS1428.1	✓	✓	Details to be verified at the CC stage
78	4.4.4 f	Shower area waterproofed to AS3740 with floor to fall to waste	✓	✓	Details to be verified at the CC stage
79	4.4.4 f	Recessed soap holder	✓	✓	If recessed is not provided a heavy duty load bearing soap holder will be required.
80	4.4.4 f	Shower taps positioned for easy reach to access side of shower sliding track.	✓	✓	Details to be verified at the CC stage
82	4.4.4 h	Provision for adjustable, detachable hand held shower rose mounted on a slider grabrail or fixed hook plumbing and wall-strengthening provision (unless brick walls provided)	✓	✓	Reinforcement to wall to take the grabrails has to be provided as per requirements of AS4299
83	4.4.4 h	Provision for grabrail in shower to comply with AS1428.1	✓	✓	Details to be verified at the CC stage
<p>[Image description: Diagram showing wall reinforcement requirements for the Adaptable unit for WC and Shower, in post adaptive position]</p>					
86	4.4.4 c	Tap sets to be capstan or lever handles with single outlet	✓	✓	Details to be verified at the CC stage.
88	4.4.4 g	Provision for washbasin with clearances to comply with AS1428.1	✓	✓	Min of 425mm is required from the side wall to the centre line of the basin. Basin is required to be at least 300mm away from door swing.
90	4.4.4 d	Double GPO bedside mirror	✓	✓	Details to be verified at the CC stage.
Toilet					

	Clause No	Requirements as per AS4299	R	C	Comments
92	4.4.3	Provision of either 'visitable toilet' or accessible toilet	✓	✓	Visitable is provided. Accessible can be provided post-adaptation.
93	4.4.1	Provision to comply with AS 1428.1	✓	✓	
94	4.4.3	Location of WC pan at correct distance from fixed walls	✓	✓	450mm – 460mm is required from the side wall to the centre line of the WC pan. Details to be verified at the CC stage.
95	4.4.4 h	Provision for grabrail zone.	✓	✓	Reinforcement to wall to take the grabrails has to be provided as per requirements of AS4299 unless brick walls have been provided. Details to be verified at the CC stage.
96	4.4.2	Slip-resistant floor surface as per AS3661 and AS 4586	✓	✓	Details to be verified at the CC stage.
Laundry					
98	4.8	Circulation at doors to comply with AS1428.1	✓	✓	N/A cupboard style laundry is proposed.
99	4.8	Provision for adequate circulation space in front of or besides appliances (minimum 1550mm depth)	✓	✓	Details to be verified at the CC stage.
100	4.8 e	Provision for automatic washing machine	✓	✓	Details to be verified at the CC stage.
102	4.8 a	Where clothes line is provided, an accessible path of travel to this	✓	✓	Details to be verified at the CC stage.
105	4.8 g	Double GPO	✓	✓	Details to be verified at the CC stage.
108	4.9.1	Slip-resistant floor surface as per AS3661 and AS 4586	✓	✓	Details to be verified at the CC stage.
Door locks					
110	4.3.4	Door hardware operable with one hand, located 900-1100mm above floor	✓	✓	Details to be verified at the CC stage.

Requirement

- Where the location of fixtures such as WC pans, wash basins, sinks, laundry fixtures and any other fixtures are to be relocated post-adaptation to comply with AS1428.1, then the service pipes (waste and water supply pipes) have to be laid in the correct AS1428.1 specified position at pre-adaptation itself and the services to be capped off for future use.

General recommendations (Advisory only / not mandatory)

- It is recommended that where balconies / outdoor areas have been provided to Adaptable units, provide the sliding doors such that the floor tracks are recessed, so level access can be provided to the balcony / outdoor areas from inside the unit.
 - Sliding doors in the living areas leading to outdoor areas are to be such that opening of the door is able to provide a clear opening space of 850mm with a latch side space of 530mm.
 - If the balcony is to be brought up to the same level as the unit at post-adaptation by means of decking etc. then ensure that the minimum handrail height requirements required under the BCA are complied with, considering the raised height of the balcony.
 - Consideration to be given to recess the slab to the wet areas so that there is no level difference once the floor finishes are applied (i.e. flush transition from carpeted area to tiles area).
-

SEPP 65 – Part 4Q1 of Apartment Design Guide

Compliance assessment with Objective 4Q-1 Universal Design

Objectives	Design guidance
<p>Objective 4Q-1</p> <p>Universal design features are included in apartment design to promote flexible housing for all community members</p>	<p>Developments achieve a benchmark of 20% of the total apartments incorporating the Livable Housing Guideline's silver level universal design features</p>




Total number of residential units in the development = 20% of 4 = 0.8 = **1** required Livable unit.

Since **1** of the unit (**101**) already comply with the Adaptable unit requirements, these unit is also capable of satisfying the intent of Silver level of Livable Housing Guidelines as noted in the table below.



Note that a wall of minimum 600mm is required forward of the WC pan clear of door opening. This is to be detailed at CC stage of works

In addition to the above all other units are also capable of compliance with Silver level as shown below






By incorporating the requirements of the below Checklist in the Specifications of the project, the nominated Livable units can achieve full compliance with Livable Housing Guidelines- Silver Level

Note that in this case the adaptable units are also be counted as Livable / LHA Silver level unit in which case the below requirements apply in addition to the AS4299 requirements.

All details to be verified at the CC stage


Design Element	Requirements (All dimensions noted are required to be clear of finishes as required under AS1428.1)	Compliance / Comments
1 Dwelling Access	<ul style="list-style-type: none"> a. Provide a safe and continuous 1M clear width pathway from front site boundary to an entry door to the dwelling. b. Path including any ramps and walkways to have no steps, even firm, slip-resistant surface, max 1:40 crossfall, max slope of 1:14 with landings of 1.2M every 9M and landings every 15M for 1:20 walkways. 1M clear width of ramps are required. c. Pathway may be provided via an associated car parking in which case the car parking space to be <ul style="list-style-type: none"> ▪ 3200 (width) x5400 (length), ▪ even, firm and slip resistant, level surface of 1:40 max grade and 1:33 max grade for bitumen d. Step ramp may be provided at an entrance doorway. The step ramp to be max 190mm height, max 1:10 grade, max 1900mm length. e. Level landings of 1200mm are required exclusive of the swing of the door or gate and to be provided at the head and foot of the ramp. 	<p>Complies. Details to be verified at CC stage of works</p> <p>N/A Access is provided from the site boundary.</p> <p>N/A</p> <p>N/A</p>
2 Dwelling entry	<ul style="list-style-type: none"> a. Dwelling Entry should provide an entrance door with <ul style="list-style-type: none"> i. min clear opening width of door to be 820mm ii. Step free threshold of max 5mm with rounded or beveled lip iii. reasonable shelter from the weather b. Level landing of 1200x1200mm at step-free entrance door on the arrival / external side of the entrance door. c. Max permissible threshold is less than 56mm where provided with a 1:8 grade threshold ramp. d. Entrance to be connected to a pathway (specified under Element 1) Note: The entrance to incorporate waterproofing and termite management requirements as specified in the NCC 	<p>Complies. Details to be verified at CC stage of works</p> <p>Complies. Details to be verified at CC stage of works</p> <p>N/A</p> <p>Complies. Details to be verified at CC stage of works Waterproofing compliance by others.</p>
3 Internal doors and corridors	<ul style="list-style-type: none"> a. Doors to rooms on the entry level used for living, dining, bedroom, bathroom, kitchen, laundry and sanitary compartments to be <ul style="list-style-type: none"> i. 820mm clear opening and 	<p>Complies. Details to be verified at CC stage of works</p>

	<ul style="list-style-type: none"> ii. provided with a level threshold of max 5mm between abutting surfaces with rounded or beveled lip 	
	<ul style="list-style-type: none"> b. Internal corridors and passageways to doorway to be min 1M clear (measured from skirting to skirting) 	Complies. Details to be verified at CC stage of works
4 Toilet	<ul style="list-style-type: none"> a. One Toilet to be provided on the ground or entry level that provides, <ul style="list-style-type: none"> i. Min 900mm between walls or amenities ii. Min 1200mm clear space in forward of the WC pan exclusive of door swing. iii. The toilet pan to be positioned in the corner of a room to enable handrails 	Complies. Details to be verified at CC stage of works
5 Shower	<ul style="list-style-type: none"> a. One bathroom should feature a slip resistant, hobless shower recess. Shower screens are permitted provided they can be easily removed at a later date. b. The shower recess should be located in the corner of the room to enable the installation of grabrails at a future date. <p>For hobless specification please see Australian Standard AS3740-3.6. Reinforcement guidelines for walls in bathrooms and toilets are found in element 6</p>	Capable of compliance. Details to be verified at CC stage of works
6 Reinforcement of bathroom & toilet walls	<ul style="list-style-type: none"> a. Except for walls constructed of solid masonry or concrete, the walls around the shower, bath (if provided) and toilet should be reinforced to provide a fixing surface for the safe installation of grabrails. <p>(b), (c) and (d) the walls around toilet, bath and shower to be via:</p> <ul style="list-style-type: none"> i. Noggins with a thickness of at least 25mm ii. Sheeting with a thickness of at least 12mm <p>Refer to diagrams provided in the Livable Housing Guideline document.</p>	Complies. Details to be verified at CC stage of works




[Image description: Diagram shows wall reinforcements options of noggings or sheeting for a toilet]

Note: In a standalone toilet, the wall reinforcements are required to both sides. Any door openings/ door frames are required to be clear of the required wall reinforcements. If wall with cavity slider is used for wall reinforcements, then allow for additional thickness for the wall.



[Image description: Diagram shows wall reinforcements options of noggings or sheeting for a shower]



[Image description: Diagram shows wall reinforcements options of noggings or sheeting for a bathtub]

7

Internal Stairways

Stairways in dwellings must feature:

- a continuous handrail on one side of the stairway where there is a rise of more than 1m. a minimum clear width of 1000mm

N/A

No internal stairway in units.

Statement of Experience

Vista Access Architects specialises in access consultancy services, including, Access requirements and Access Performance Solutions under the NCC, NDIS SDA Certifications, Livable Housing Certifications and Changing Places Certifications.



Farah Madon - Director

ACAA Accredited Access Consultant
NDIS Accredited SDA Assessor
Livable Housing Assessor
Changing Places Assessor

- Accredited member of the Association of Consultants in Access Australia (ACAA) - 281
- NDIS Accredited SDA (Specialist Disability Accommodation) Assessor SDA00001
- Architect registered with the NSW Architect's Registration Board - Registration 6940
- Member of Australian Institute of Architects (RAIA), A+ Practice Member 49397
- Registered Assessor of Livable Housing Australia - Registration 10032
- Global Alliance on Accessible Technologies and Environments (GAATES) - BE-02-021-20
- Registered Assessor of Changing Places Australia - Registration CP006

Farah's Educational Profile and Qualifications include:

- Bachelor of Architecture Degree with Honours (B.Arch.)
- International Certification of Accessibility Consultants – Built Environment (ICAC-BE) Program, Level 2 Advanced Accessibility Consultant
- Diploma of Access Consulting

Farah has 20 years of experience of working in the field of Architecture and Access.

Farah is the lead author of the NDIS SDA Design Standard. She has been invited on multiple occasions as an expert witness for Access related matters in the NSW Land and Environment Court.

Farah currently participates on the following key committees concerning access for people with disabilities, on an honorary basis:

- Member of Standards Australia's ME-064 Committee responsible for the AS4299 and AS1428 suite of standards.
- Vice President of Association of Consultants in Access Australia (ACAA)
- Community Representative Member of the Penrith City Council's Access Committee
- Member of Australian Institute of Architect's National Enabling Architecture Committee (NEAC)
- Management Committee member of NSW Network of Access Consultants
- Director of Livable Housing Australia (LHA)
- Member of Changing Places Australia Technical Advisory Team

Some Recent Awards presented to Farah include:

- 2021 Australian Access Awards Winner for the Educational App of the Year - SDA Tools
- 2021 Excellence in Inclusion - Altitude Awards - Winner
- 2021 Western Sydney Executive Woman of the Year - Finalist
- 2019 Penrith Citizen of the Year
- 2019 Access Inclusion Award
- 2019 Australian Access Awards Educational App of the Year - LRV Contrast App - Finalist





Vanessa Griffin

ACAA Accredited Access Consultant
 NDIS Accredited SDA Assessor
 Livable Housing Assessor
 Changing Places Assessor

- Accredited member of the Association of Consultants in Access Australia (ACAA) - 500
- NDIS Accredited SDA (Specialist Disability Accommodation) Assessor SDA00009
- Registered Assessor of Livable Housing Australia - Registration 20035
- Registered Assessor of Changing Places Australia Registration CP010

Vanessa's Educational Profile and Qualifications include:

- Diploma of Surveying and Diploma of Health and Building Surveying, Sydney Institute of Technology
- Certificate IV in Access Consulting



Jenny Desai

ACAA Accredited Access Consultant
 NDIS Accredited SDA Assessor
 Livable Housing Assessor

- Accredited member of the Association of Consultants in Access Australia (ACAA) - 572
- NDIS Accredited SDA (Specialist Disability Accommodation) Assessor SDA00043
- Registered Assessor of Livable Housing Australia - Registration 20242

Jenny's Educational Profile and Qualifications include:

- Master of Design (M.Des) from University of Technology, Sydney
- Certificate IV in Access Consulting



Art Phonsawat

ACAA Associate Access Consultant

- Associate member of the Association of Consultants in Access Australia (ACAA) - 695

Art's Educational Profile and Qualifications include:

- Advanced Diploma in Interior design, Sydney
- Certificate IV in Access Consulting

