

## Natural Environment Referral Response - Coastal

<b>Application Number:</b>	DA2020/0133
<b>Responsible Officer</b>	Lashta Haidari
<b>Land to be developed (Address):</b>	Lot 17 DP 8595 , 121 Pacific Road PALM BEACH NSW 2108

### Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The application has been assessed in consideration of the *Coastal Management Act 2016*, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

#### **Coastal Management Act 2016**

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development.

The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

#### **State Environmental Planning Policy (Coastal Management) 2018**

As the subject site has been identified as being within the coastal zone and therefore SEPP (Coastal Management) 2018 is also applicable to the proposed development.

The subject land has been included on the 'Proximity Area to Littoral Rainforest' but not been included on the Coastal Vulnerability Area Map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 11 and 15 of the CM SEPP apply for this DA.

#### Comment:

As assessed in the submitted Statement of Environmental Effects (SEE) report prepared by GSA Planning dated February 2020 and Council accepts the assessment, the DA satisfies requirements under clauses 11 and 15 of the CM SEPP.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.

## **Pittwater LEP 2014 and Pittwater 21 DCP**

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### **Recommended Natural Environment Conditions:**

## **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

### **Erosion and Sediment Control Plan**

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities);
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls;
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.

## **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

### **Installation and Maintenance of Sediment and Erosion Control**

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the



site