



3rd June, 2020 – AG 20120
77 Myola Road, Newport NSW

GEOTECHNICAL COMPLIANCE LETTER

77 Myola Road, Newport NSW

Ascent Geotechnical Consulting Pty Ltd (Ascent) have reviewed the architectural plans for a small timber deck prepared by Hamerest Pty Ltd, Project 35-05-002, Sheets 1 & 2, Issue C, dated 18th March, 2020.

Ascent attended the site in August 2019, for site assessment and geotechnical report for retaining wall (AG 19134, 16th August, 2019).

The design, as presented in the architectural plans, referenced above, do not require any significant earthworks, and are not considered to pose a significant risk to slope stability, property generally, or life. Provided the below listed recommendations are followed, the existing Site conditions and proposed development are considered to constitute an “**Acceptable**” risk to life and a “**Low**” risk to property.

- All new footings are to be taken to the underlying bedrock using piers as required.
- No footings are to be placed within the zone of influence of any existing retaining structures.
- It is a condition of this letter that Ascent are engaged to inspect and approve all new footings before concrete and steel is placed.

If you have any questions or require any clarification, please call **Ben Morgan** on **0448 255 537**

For and on behalf of, **Ascent Geotechnical Consulting Pty Ltd,**

Ben Morgan BSc Geol MAIG.
Engineering Geologist
Operations Manager