

---

**Sent:** 26/05/2015 9:04:46 AM  
**Subject:** MOD 2015/0083 Ausgrid submission 34 Robert Ave, Nth Manly  
**Attachments:** Referral to AUSGRID - SEPP - Infrastructure 2007.DOCX; plan notification.PDF; 34 Robert Ave, North Manly - response to Council 20150526.pdf;

Please refer to attached Ausgrid submission.

Regards,

**SCOTT CORAM** | LOW VOLTAGE PLANNER  
Network Operations - Central | AUSGRID  
Level 1, Building 5, 14 Nelson St, Chatswood NSW 2067 AUSTRALIA  
T: 02 9477 8321 (x38321) | E: [scoram@ausgrid.com.au](mailto:scoram@ausgrid.com.au)

----- Forwarded by Scott Coram/Ausgrid on 26/05/2015 09:02 AM -----

From: Manager Property Portfolios/Ausgrid  
To: [scoram@ausgrid.com.au](mailto:scoram@ausgrid.com.au),  
Cc: [bwarters@ausgrid.com.au](mailto:bwarters@ausgrid.com.au)  
Date: 11/05/2015 03:40 PM  
Subject: Fw: MOD2015/0083 - 34 Robert Ave Nth Manly  
Sent by: Brian Warters

---

----- Forwarded by Brian Warters/Ausgrid on 11/05/2015 03:40 PM -----

<b>John Slater</b> < <a href="mailto:John.Slater@warringah.nsw.gov.au">John.Slater@warringah.nsw.gov.au</a> >  11/05/2015 08:34 AM	To	" <a href="mailto:manager.property.portfolios@energy.com.au">manager.property.portfolios@energy.com.au</a> " < <a href="mailto:manager.property.portfolios@energy.com.au">manager.property.portfolios@energy.com.au</a> >,
	Cc	
	Subject	MOD2015/0083 - 34 Robert Ave Nth Manly

Referral for your comments

-----< HP TRIM Record Information >-----

Record Number : 2015/131804  
Title : Referral to AUSGRID - SEPP -  
Infrastructure 2007

-----< HP TRIM Record Information >-----

Record Number : 2015/128920  
Title : plan notification

This e-mail may contain confidential or privileged information.

If you have received it in error, please notify the sender immediately via return e-mail and then delete the original e-mail.

If you are the intended recipient, please note the change of sender email address to @ausgrid.com.au.

Ausgrid has collected your business contact details for dealing with you in your business capacity. More information about how we handle your personal information, including your right of access is contained at <http://www.ausgrid.com.au/>

11 May 2015

AUSGRID  
GPO Box 4009  
Sydney NSW 2001

Sent Via Email to [manager.property.portfolios@energy.com.au](mailto:manager.property.portfolios@energy.com.au)

To Whom It May Concern,

**Re: Request for Comments on Application**

**Application No: Mod2015/0083**

**Description: Modification of Development Consent DA2014/0837 granted for Alterations and additions to a dwelling house and construction of a swimming pool and driveway**

**Address: 34 Robert Avenue NORTH MANLY NSW 2100**

I am writing with regard to the above-mentioned application which has been lodged with Council for assessment and determination.

This application is being forwarded for consideration pursuant to the provisions of

- **State Environmental Planning Policy (Infrastructure) 2007**

Please find attached:

- A copy of documentation (plans and reports) submitted within the application.

Your response to this request would be greatly appreciated if it was provided within 21 days of the date of this letter.

Alex Keller is the Planner allocated to assess this application and can be contacted on (02) 9942 2111 during the available hours of 8.30am to 5.00pm Monday to Friday or via email [council@warringah.nsw.gov.au](mailto:council@warringah.nsw.gov.au) – all responses to Council should be marked to the attention of the Planner.

Should you wish to monitor the progress of the application and review the submissions as they are lodged with Council, please feel free to visit Application Search on [www.warringah.nsw.gov.au](http://www.warringah.nsw.gov.au)

Yours faithfully,



▼



John Slater  
**Senior Development Assessment Liaison Officer**





570 George Street  
Sydney NSW 2000

Address all mail to  
51-59 Bridge Rd  
Hornsby NSW 2077



26 May 2015

General Manager  
Warringah Council  
Via email: [council@warringah.nsw.gov.au](mailto:council@warringah.nsw.gov.au)

To Whom It May Concern,

**Re: MOD 2015/0083 – 34 Robert Ave, North Manly**

I refer to Council's letter dated 11 May 2015 advising of the Development Proposal at the above address and wish to advise that Ausgrid has no objection to the matter proceeding at this stage subject to the following conditions: -

- The existing overhead electricity service to the premise is to be re-routed as required to ensure that adequate clearance is achieved from the proposed car port. Refer to Section 3.5 of the Service and Installation Rules of New South Wales for the compliance requirements.

Should any further information on this matter be required, please contact Scott Coram on 9477 8321 or [scoram@ausgrid.com.au](mailto:scoram@ausgrid.com.au).

Yours sincerely,

A handwritten signature in black ink, appearing to read "SCoram", written in a cursive style.

Scott Coram  
Engineering Officer