

## Parks, Reserves and Foreshores Referral Response

Application Number:	DA2020/0277
Date:	28/04/2020
To:	Catriona Shirley
Land to be developed (Address):	Lot 32 DP 8013 , 37 Sturdee Lane ELVINA BAY NSW 2105

### Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore  
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

### Officer comments

The subject property lies to the south of Floods Peninsula Reserve. The topography of the northern part of the site where development is occurring falls towards the reserve. Sedimentation control has been recommended to ensure continued reserve amenity.

No other issues with the proposal.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Parks, Reserves and Foreshores Conditions:

#### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Installation and Maintenance of Sediment and Erosion Control**

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.