

Building Assessment Referral Response

Application Number:	DA2024/0859
Proposed Development:	Alterations and additions to a dwelling house including secondary dwelling and garage
Date:	18/07/2024
To:	Thomas Burns
Land to be developed (Address):	Lot 11 DP 28394 , 11 Moresby Place ALLAMBIE HEIGHTS NSW 2100

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Fire Separation - Separating walls

A separating wall between Class 1 buildings is required to comply with Part 9.3 – ‘Separating Walls’, and Part 10.7 - ‘Sound Insulation’ of the Building Code of Australia 2022.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety.



northern
beaches
council