

Building Assessment Referral Response

Application Number:	DA2019/1304
To:	Kent Bull
Land to be developed (Address):	Lot 100 DP 709585 , 16 Myoora Road TERREY HILLS NSW 2084

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Building Code of Australia & Access Report

The recommendations made in the Building Code of Australia & Access Assessment Report prepared by AED Group, dated 26 September 2019, Report Ref No. 9267 - Rev 02 are to be carried out in full to the building.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

Construction in Bush Fire Prone Areas

The recommendations made in the Bush Fire Assessment Report prepared by Australian Bushfire Consulting Services, dated 16 October 2019, Report Ref No. 19-085 are to be carried out in full to the building.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for the design and construction of the building to reduce the risk of ignition from a bushfire and provide building occupant safety

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE****Building Code of Australia & Access Report**

The recommendations made in the Building Code of Australia & Access Assessment Report prepared by AED Group, dated 26 September 2019, Report Ref No. 9267 - Rev 02 are to be carried out in full to the building.

Details demonstrating implementation and compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate .

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant safety.

Construction in Bush Fire Prone Areas

The recommendations made in the Bush Fire Assessment Report prepared by Australian Bushfire Consulting Services, dated 16 October 2019, Report Ref No. 19-085 are to be carried out in full to the building.

Details demonstrating implementation and compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate .

Reason: To ensure adequate provision is made for the design and construction of the building to reduce the risk of ignition from a bushfire and provide building occupant safety

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of a part Occupation Certificate or Occupation Certificate.

Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.