

# Hydraulic Certificate

Date: 26<sup>th</sup> April 2022 Job No. 2009109

Client: Nathan & Michelle Cahill Engineer: LG

**Site: 135 Seaforth Crescent, Seaforth**

Luke Gerkens of Northern Beaches Consulting Engineers P/L inspected the additions and alterations to the above building during construction.

We hereby certify that, at the time of inspection, the following items as detailed on the structural plans by Northern Beaches Consulting Engineers P/L (Job No: 2009109; Drawings D01 and D02 and Sketch SK02 dated 17/5/2021), are generally in accordance with the above mentioned drawings and site instructions issued during construction and Australian Standards AS3500 and Northern Beaches Council 'Water management for development policy':


- 22/09/2021 – Stormwater system

Survey information has confirmed the swimming pool has been built some 500mm higher than the approved plans. The recommendations of the original Stormwater plans dated Sept 2020 are still current for the proposed modification to the approved Development Application DA 2020/1324.

This certificate does not relate to and we assume no responsibility for the certification of any structural or other elements that have not been inspected by the companies' representatives or are not referred to in this certificate.

We trust that this certificate meets with your requirements. Please contact the author if further clarification is required.

## **NORTHERN BEACHES CONSULTING ENGINEERS P/L**



**Richard Wray**

BE(Civil), CPEng, MIEAust., NER, RPEG, PRE, DEP.  
(Director NB Consulting Engineers)



**Luke Gerkens**

Senior Engineer | BE(Civil) MIEAust

X:\Synergy\Projects\2009109 135 SEAFORTH CRESCENT, SEAFORTH (190808)\ENG Design\2009109 HC001  
2022-03-30.docx