

Waste Referral Response

Application Number:	DA2021/1039
Date:	25/07/2022
To:	Adam Susko
Land to be developed (Address):	Lot 2566 DP 752038 , 16 Wyatt Avenue BELROSE NSW 2085 Lot 2597 DP 752038 , 16 Wyatt Avenue BELROSE NSW 2085

Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

Officer comments

Waste Management Assessment - Amended Plans (submitted 12 July 2022)
Recommendation - Acceptable - subject to conditions

The Lower (rear) Building

The bins one one side of the storage room are double banked which makes rear row of bins difficult to access. The plan of management needs to be updated to make the property manager responsible for rotating empty bins to the front row where the bins are double banked, as the bins fill up.

The Plan of Management, clause 5.0 Waste Management needs to be updated to reflect the amended plans.

The Plan of Management also must include that the property manager is to bring the vegetation bins out from the basement to a place adjacent to the bin storage room for servicing by Council. Council will supply 240litre vegetation bins, not 660 litre as shown on the plans.

No parking signage is to be placed in the turning area adjacent to the Bin storage room.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Waste Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Waste and Recycling Requirements

Details demonstrating compliance with Northern Beaches Waste Management Guidelines, are to be submitted to and approved by the Certifying Authority prior to the issue of any Construction Certificate.

Note: If the proposal, when compliant with the Northern Beaches Waste Management Guidelines, causes inconsistencies with other parts of the approval i.e. architectural or landscaped plans, a modification(s) to the development may be required.

Reason: To ensure adequate and appropriate waste and recycling facilities are provided.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Waste/Recycling Requirements (Waste Plan Submitted)

During demolition and/or construction the proposal/works shall be generally consistent with the submitted Waste Management Plan titled dated [INSERT].

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided.

Waste/Recycling Requirements (Materials)

During demolition and/or construction the following materials are to be separated for recycling: timber, bricks, tiles, plasterboard, metal, concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Plan of Management to be updated to include the following management requirements

The Plan of Management, Boarding House 16 Wyatt Ave Belrose is to include the following changes at Clause 5.0 - Waste Management.

The clause is to be updated to reflect the plans submitted 12 July 2022.

The Manager is responsible to rotate the bins in the waste storage room at the back of the development where bins inside the storage room are double banked, so that full bins are moved the the rear row and empty bins are moved to the front row to allow ready access to empty bins by residents.

The Manager is to move the vegetation bins to a location adjacent to the rear bin storage area for servicing by Council

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area

Garbage and Recycling Facilities

All internal walls of the waste rooms shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate

cleaning.

Waste room floors shall be graded and drained to an approved Sydney Water drainage system.

Waste rooms shall be clear of any other services or utilities infrastructure such as gas, electricity air-conditioning, plumbing, piping ducting or equipment.

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.

Waste and Recycling Facilities Certificate of Compliance

The proposal shall be constructed in accordance with the Northern Beaches Waste Management Guidelines.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste and recycling facilities are provided.

Waste/Recycling Compliance Documentation

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste is minimised and recycled.

Positive Covenant for Council and Contractor Indemnity

A positive covenant shall be created on the title of the land prior to the issue of an Interim/Final Occupation Certificate requiring the proprietor of the land to provide access to the waste storage facilities. The terms of the positive covenant are to be prepared to Council's requirements, (Appendix E of the Waste Management Guidelines), at the applicant's expense and endorsed by Council prior to lodgement with NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities.

Authorisation of Legal Documentation Required for Waste Services

The original completed request form (NSW Land Registry Services form 13PC) must be submitted to Council for authorisation prior to the issue of the Interim/Final Occupation Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. Where required by Council or the Certifying Authority, a Compliance Certificate shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

No Parking in truck turning area

No parking signage is to be placed in the truck turning area at the rear of the property

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.



northern
beaches
council