

16 June 2023

Rawson Homes
PO Box 3099
Rhodes NSW 2138

Our Ref: RW6158
Your Ref: A/000350

RE: SOIL CLASSIFICATION REPORT SUPPLEMENTARY LETTER

Site: Lot 7 (10) Courtney Road, Beacon Hill

CERTIFICATE

We, Residential Engineering, hereby verify that an assessment of the amended architectural plans, soil classification report and structural drawings prepared by this office has been undertaken and can confirm that the recommendations of the original report remain unchanged. It shall be noted that a total of 225mm of clean rolled fill is proposed to be placed over the existing prepared platform and shall be carried out in accordance with the structural engineering general note 9(a).



RESIDENTIAL ENGINEERING
Gervase Purich
FIE Aust. CPEng, NER, BRB, RBP, RPEQ