

Landscape Referral Response

Application Number:	DA2019/1420
Date:	05/03/2020
Responsible Officer:	Nick England
Land to be developed (Address):	Lot 1 DP 601101 , 8 Wyatt Avenue BELROSE NSW 2085

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The Landscape Plans and Arborist's Report submitted with the application are noted.

The Landscape Plans indicate regrading of grassed areas around the proposed building with retaining walls and proposed tree, shrub and ground-cover planting.

The Arborist's Report indicates that four native trees are required to be removed to accommodate the works. Two of the trees are rated in the Arborist's Report as being of Low retention value and two are rated as Medium retention value.

The Landscape Plan proposes replanting of nine native trees and four deciduous exotic trees. (Thirteen trees in total).

In view of the above, no objections are raised to approval with regard to landscape issues subject to tree protection and replanting conditions as indicated below.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

- (a) Existing trees which must be retained
- i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation. For clarity, Trees Numbered 37a, 37b, 38b and 39 as

DA2019/1420 Page 1 of 3



identified in the Arboricultural Impact Assessment dated November 2019 prepared by Accurate Tree Assessment are approved for removal.

ii) Trees located on adjoining land

(b) Tree protection

- i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by the Project Arborist on site.
- ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by the Project Arborist on site.
- iii) All tree protection to be in accordance with the Arboricultural Impact Assessment dated November 2019 prepared by Accurate Tree Assessment and AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with relevant local planning controls and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

Project Arborist

- i) A Project Arborist with minimum qualification AQF Level 5 is to be appointed prior to commencement of works.
- ii) The Project Arborist is to oversee all tree protection measures, removals, inspection hold points and works adjacent to protected trees as outlined in the Arboricultural Impact Assessment dated November 2019 prepared by Accurate Tree Assessment and AS4970-2009 Protection of trees on development sites.
- iii) The Project Arborist is to ensure compliance as relevant with any other environmental requirements conditioned under this consent.

Reason: to ensure protection of vegetation proposed for retention on the site.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Landscape completion certification

a) Prior to the issue of an Occupation Certificate, a landscape report prepared by a landscape architect or landscape designer shall be submitted to the Certifying Authority, certifying that the landscape works have been completed in accordance with the approved landscape plan and inclusive of any conditions of consent.

Reason: To ensure that the landscape treatments are installed to provide landscape amenity.

Condition of retained vegetation

Prior to the issue of an Occupation Certificate, a report prepared by the Project Arborist shall be submitted to the Certifying Authority assessing the health and impact of trees and vegetation required to be retained as a result of the proposed development, including the following information:

- a) Compliance to Arborist recommendations for tree protection and excavation works.
- b) Extent of damage sustained by vegetation as a result of the construction works.

DA2019/1420 Page 2 of 3



c) Any subsequent remedial works required to ensure the long term retention of the vegetation.

Reason: To ensure compliance with the requirement to retain and protect significant planting on development sites.

Required Planting

a) Trees shall be planted in accordance with the following schedule:

Minimum No. of Trees Required.	Species	Location	Pot Size
All trees	As indicated on Landscape Plan Dwg No. LPDA20-38/1 Rev. F dated 29.11.19 prepared by Conzept Landscape Architects	As indicated on the Landscape Plan	As indicated on the Landscape Plan

b) Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Landscape maintenance

- i) Trees shrubs and groundcovers required to be planted under this consent are to be mulched, watered and fertilized as required at the time of planting.
- ii) If any tree, shrub or groundcover required to be planted under this consent fails, they are to be replaced with similar species to maintain the landscape theme and be generally in accordance with the approved Landscape Plan.

Reason: To maintain local environmental amenity.

DA2019/1420 Page 3 of 3