

DEVELOPMENT APPLICATION

FIRE SAFETY SCHEDULE

Sky Racing Master Control

Upgrade Plan Proposed Stage 2-Levels 3 & 4

79 EAST FRENCHS FOREST ROAD
FRENCHS FOREST, NSW

| Existing Fire Safety Measures | | Proposed Fire Safety Measures |
|--|--|--|
| Fire Safety Measure | Minimum Standard of Performance | Minimum Standard of Performance |
| Automatic Fire Detection and Alarm System | AS1670.1-1995 | AS1670.1-1995 |
| Smoke and Heat Detectors | AS1670.1-1995 | AS1670.1-1995 |
| Mechanical Air Handling Systems Shutdown Fire Trip | AS1670.1-1995 | AS1670.1-1995 |
| Building Occupant Warning System | AS1670.1-1995 | AS1670.1-1995 |
| Emergency Lighting | AS2293.1-1995 | AS2293.1-1995 |
| Exit Signs | AS2293.1-1995 | AS2293.1-1995 |
| Fire Hose Reels | AS2441-1995 | AS2441-1995 |
| Fire Hydrant System | AS2419.1-1994 | AS2419.1-1994 |
| Portable Fire Extinguishers | AS2444-1995 | AS2444-1995 |
| Fire Doors | AS1905.1-1990 | AS1905.1-1990 |
| Fire Alarm Communication Link | AS4428.6-1997, AS1670.3-2004 & AS3013-2005 | AS4428.6-1997, AS1670.3-2004 & AS3013-2005 |
| Wall Wetting Drenches | AS2118.2-2010 | AS2118.2-2010 |
| Fire Curtains | AS1530.4-2005 & AS1530.7-2007 | AS1530.4-2005 & AS1530.7-2007 |
| Fire Seals | AS1530.4 & AS4072 | AS1530.4 & AS4072 |
| Light Weight Construction | BCA C1.8 excluding PABX & Broadcast Technology Room on Level 4 | BCA C1.8 excluding PABX & Broadcast Technology Room on Level 4 |