

## Engineering Referral Response

Application Number:	DA2019/0580
To:	Catriona Shirley
Land to be developed (Address):	Lot 4 DP 38402 , 167 Plateau Road BILGOLA PLATEAU NSW 2107

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

The front of the development/site is located in Geotechnical Hazard H2 Area, an "Acceptable Risk Management" level is achievable in accordance with the geotechnical report.  
Recommend approval subject to conditions.

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Refusal comments

### Recommended Engineering Conditions:

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### Stormwater Disposal

Stormwater shall be disposed of to an existing approved system or in accordance with Northern Beaches Council's PITTWATER DCP21 clause B5.10,

A certificate is to be provided to the Certifying Authority with the Construction Certificate application by a qualified experienced practicing Civil Engineer, with Corporate membership of the Institute of Engineers Australia (M.I.E.) or who is eligible to become a Corporate member and has appropriate experience and competence in the related field that the existing approved system can accommodate the additional flows or provide drainage plans demonstrating compliance with Council's requirements.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from development.

### **Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans**

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by Jack Hodgson Consultants dated 17th December 2018 are to be incorporated into the construction plans. Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **Road Reserve**

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Geotechnical Certification Prior to Occupation Certificate**

Prior to issue of the Occupation Certificate, Form 3 of the Geotechnical Risk Management Policy is to be completed and submitted to the Principal Certifying Authority.

Reason: To ensure geotechnical risk is mitigated appropriately.

### **Certification of Water Management**

Certification is to be provided to the accredited certifier by a qualified experienced practising Civil Engineer with corporate membership of the Institute of Engineers Australia (M.I.E.), or who is eligible to become a corporate member and has appropriate experience and competence in the related field, that the drainage/stormwater management system has been installed to the manufacturer's specification (where applicable) and completed in accordance with the engineering plans and specifications required under this consent.

Reason: To ensure Stormwater Management has been built in accordance with the plans and specifications required under this consent