

Natural Environment Referral Response - Coastal

Application Number:	DA2022/0099
Date:	15/02/2022
Responsible Officer	Brittany Harrison
Land to be developed (Address):	Lot 61 DP 771456 , 188 McCarrs Creek Road CHURCH POINT NSW 2105 Lot PO 169846 , 188 McCarrs Creek Road CHURCH POINT NSW 2105

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

Comment:

On internal assessment, the DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP. As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.

Pittwater LEP 2014 and Pittwater 21 DCP

Estuarine Risk Management

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL 2.53 m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.04m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m.

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Peterdownes Designs undated, the ground floor level for the proposed boatshed and base of the Incline lift is at or above the applicable EPL for the site.

The proposed development is therefore able to satisfy the relevant estuarine risk management requirements of P21 DCP.

Development on Foreshore Area

A section of the subject property is within the foreshore building line. Part 7, Clause 7.8 –Limited development on foreshore area of the Pittwater LEP 2014 applies for any development within the foreshore area.

The DA proposes construction of a boatshed and base of the incline lift located in the foreshores area. All these proposed works are consistent with Clause 7.8(2)(b).

On internal assessment, the DA satisfies the objectives and requirements of Part 7, Clause 7.8 of the Pittwater LEP 2014.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Boatshed Not for Habitation

At no time shall the boatshed be utilised or converted to provide for residential habitation. The boatshed must not be used for any other purpose than the storage of small boats, light watercraft and boating and marine equipment. The incorporation of any internal kitchen facilities, habitable rooms, shower or toilet facilities is not permitted.

Reason: To ensure compliance with Pittwater Estuarine Risk Management Policy.