

## MULTITASK CIVIL CONSTRUCTION SOLUTIONS PTY, LTD.

25/5/2025

## TO WHOM IT MAT CONCERN

I attended the site at no 2 Cherana Cres Forestville

We attend the site to investigate the integrity of the 600mm stormwater line that runs along the eastern boundary.

The pipeline is in good condition and I believe that it would service the development with out any additional load placed on the system

The pipeline is approximately 1mtr to invert and is clear of any obstructions.

The stormwater line meets AS3500 requirements.

Regards,

Joe Belcastro
Director
Multitask Civil P/L

Tel: 0418 447 138

Email: joe.belcastro61@gmail.com

ABN: 51 165 894 566