

Engineering Referral Response

Application Number:	DA2018/1342
To:	David Auster
Land to be developed (Address):	Lot 3A DP 13374 , 1165 Barrenjoey Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The development proposal is to provide for two car spaces, similar to the adjoining properties. Council has recently built new concrete footpath and guard rails at this location. The proposed car spaces will necessitate removal of the guard rail, if approval is granted.

Prior to assessment of this development, Council Traffic comments/approval is requested in regards to the car spaces and removal of the guard rails.

Date 17/02/2020

Based on Traffic and RMS comments, no development engineering objections subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION
CERTIFICATE**

**Geotechnical Report Recommendations have been Incorporated into Designs and Structural
Plans**

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by Jack Hodgson Consultants dated 27th July 2018 [INSERT] are to be incorporated into the construction plans. Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

Submission Roads Act Application for Civil Works in the Public Road

An Application for Works to be approved within Council Roadway, including engineering plans is to be submitted to Council for approval under the provisions of Sections 138 and 139 of the Roads Act 1993. The application is to include four (4) copies of Civil Engineering plans within the public Road through the nature strip and driveway crossing which are to be generally in accordance with the Development Application, RMS approval and Council's specification for engineering works - AUS-SPEC #1. The plan shall be prepared by a qualified structural engineer. The design must include the following information:

- The proposed car stand area, steps and inclinator are to be located within the private property.
- Provision for a vehicular crossing generally in accordance with Council's standard profile.
- Submission to Council the approved design plans from (RMS) Transport for NSW for the 11.0 M crush barrier and guardrails.
- Structural details of any slab within the road reserve.
- Longitudinal section of the driveway to the center line of the road to the car stand area.
- Detail survey of the footpath reserve to demonstrate that the proposed road works does not compromise the exiting Council's paved footpath.

The fee associated with the assessment and approval of the application is to be in accordance with Council's Fee and Charges. An approval is to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate

Reason: To provide public and private safety.

Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

(a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and

(b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

Shoring of Adjoining Property

Should the proposal require shoring to support an adjoining property or Council land, owner's consent for the encroachment onto the affected property owner shall be provided with the engineering drawings.

Council approval is required if temporary ground anchors are to be used within Council land. A Temporary Ground Anchors (Road Reserve) Application is to be submitted with Council for assessment and approval subject to Council's Fees and Charges. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate

Reason: To ensure that owners consent is obtained for ancillary works, and to ensure the protection of adjoining properties and Council land.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

Geotechnical Certification Prior to Occupation Certificate

Prior to issue of the Occupation Certificate, Form 3 of the Geotechnical Risk Management Policy is to be completed and submitted to the Principal Certifying Authority.

Reason: To ensure geotechnical risk is mitigated appropriately.

Certification of road Works and Works as Executed Data

A suitably qualified Civil Engineer shall certify that the completed works within the road reserve have been constructed in accordance with this consent and the approved road works plans. Works as Executed data certified by a registered surveyor shall be submitted to the Council for approval prior to the issue of the Occupation Certificate - Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate

Reason: To ensure compliance of road works with Council's and RMS specification for engineering works within the road reserve.