

Environmental Health and Protection Referral Response - commercial use

| | |
|--|--|
| Application Number: | Mod2014/0230 |
| To: | Luke Perry |
| Land to be developed (Address): | Lot 100 DP 1015283 , 145 Old Pittwater Road BROOKVALE NSW 2100 |

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments

No objections subject to compliance with Food premises conditions attached

Recommended Environmental Health and Protection Conditions:

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from a person who is eligible as a 'Member' of Environmental Health Australia (EHA) that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements. (DACHPFPOC3)

Mechanical Ventilation certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from the installer of the mechanical ventilation system that the design, construction and installation of the mechanical ventilation system is compliant with the requirements of AS1668 The use of mechanical ventilation.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the mechanical ventilation system complies with the design requirements. (DACHPFPOC4)

