

Building Assessment Referral Response

Application Number:	DA2020/0180
Date:	10/03/2020
To:	Phil Lane
Land to be developed (Address):	Lot 61 DP 869675 , 155 - 171 Fisher Road North CROMER NSW 2099

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Lighting and Ventilation

Light and Ventilation is to be provided to all habitable rooms in accordance with Part F4 of the Building Code of Australia.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for building occupant health and amenity

Sound Transmission and Insulation (Class 2)

Prior to the issue of any interim or final Occupation Certificate details demonstrating implementation and compliance with Part F5 of the Building Code of Australia – ‘Sound Transmission and Insulation’ are to be provided to the Principal Certifier.

Reason: To ensure adequate provision is made for building occupant health and amenity

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.