

Northern Beaches Council PO Box 882 MONA VALE NSW 1660

Your reference: DA2021/2573 (CNR-33950) Our reference: DA20220116000390-Original-1

ATTENTION: Northern Beaches Council Date: Tuesday 25 January 2022

Dear Sir/Madam,

Development Application s4.14 - Infill - Single Dwelling - Alterations & Additions 22a Connemara Avenue Killarney Heights NSW 2087, 648//DP217209

I refer to your correspondence dated 13/01/2022 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act* 1979.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

## **Asset Protection Zones**

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

1. From the start of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire property must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2 metres above the ground;
- tree canopies should be separated by 2 to 5 metres;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

1

- grass should be kept mown (as a guide grass should be kept to no more than 100 mm in height); and
- leaves and vegetation debris should be removed.

## **Construction Standards**

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities. To achieve this, the following conditions shall apply:

- **2.** New construction on the southern, eastern and western elevations and new roof must comply with section 3 and section 7 (BAL 29) Australian Standard AS3959-2018 Construction of buildings in bush fire-prone areas or NASH Standard (1.7.14 updated) National Standard Steel Framed Construction in Bushfire Areas 2014 as appropriate and Section 7.5 of Planning for Bush Fire Protection 2019.
- 3. New construction on the northern elevation(s) must comply with section 3 and section 6 (BAL 19) Australian Standard AS3959-2018 Construction of buildings in bush fire-prone areas or NASH Standard (1.7.14 updated) National Standard Steel Framed Construction in Bushfire Areas 2014 as appropriate and Section 7.5 of Planning for Bush Fire Protection 2019.
- **4.** The existing dwelling must be upgraded to improve ember protection by enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any sub floor areas, openable windows, vents, weepholes and eaves. External doors are to be fitted with draft excluders.

## **Water and Utility Services**

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

**5.** Any new provision of water, electricity and gas must comply with Table 7.4a of *Planning for Bush Fire Protection 2019*.

## **Landscaping Assessment**

The intent of measures is for landscaping. To achieve this, the following conditions shall apply:

- **6.** Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:
  - A minimum 1 metre wide area (or to the property boundary where the setbacks are less than 1 metre), suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
  - Planting is limited in the immediate vicinity of the building;
  - Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
  - Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do no touch or overhang buildings;
  - Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
  - Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
  - Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
  - Avoid climbing species to walls and pergolas;
  - Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
  - Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
  - Low flammability vegetation species are used.

**General Advice - Consent Authority to Note** 

• The above recommendations are for the proposed alterations and additions to the existing dwelling on Lot 647 DP217209.

For any queries regarding this correspondence, please contact Rohini Belapurkar on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese
Manager Planning & Environment Services
Built & Natural Environment