

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2024/0944
Proposed Development:	Demolition works and construction of a plant nursery and landscape material supplies premises
Date:	09/10/2024
То:	Anne-Marie Young
Land to be developed (Address):	Lot 3 DP 26902 , 12 Boondah Road WARRIEWOOD NSW 2102 Lot 4 DP 26902 , 10 Boondah Road WARRIEWOOD NSW 2102

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore

And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The property adjoins a public reserve to the west. No physical encroachments over the site boundaries are permitted, and structures and built elements are not permitted beyond the site boundaries. All development works must ensure that surface sediment runoff and/or erosion is controlled, managed and contained within the site boundaries.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Storage of Materials on Land Owned or Managed by Council Prohibited

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

Protection of Council's Public Assets

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

Existing trees shall be protected in accordance with AS4970-2009 Protection of Trees on Development

DA2024/0944 Page 1 of 2



Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance.

Reason: To protect and/or restore any damaged public asset.

DA2024/0944 Page 2 of 2