

DECK CERTIFICATION

ADDRESS: 1 Narrabeen park pde

CLIENT : Nourished cafe and lounge

Items inspected :

Deck

The mentioned structure has been built to above code standards in relation to AS 1684.2. Existing holes were used where old posts were previously sitting and mechanical fixings tie structural members together and to foundations. All member sizes are spanning well beneath their max span in accordance to AS 1684.2 and joist protection is installed to ensure longevity of structure.

Yours sincerely

Lachlan Warwick

Certificate no. 0162752

A handwritten signature in black ink, appearing to read 'Lachlan', with a stylized flourish extending from the end.