

John Bubb and Christina Neumann-Bubb
C/- Vaughan Milligan Development Consulting Pty Ltd
Attention: Vaughan Milligan
PO Box 49
Newport Beach NSW 2106
(sent by email only to vmdc@bigpond.net.au)

4 January 2020

Coastline Risk Management Report for 9 Ocean Road Palm Beach

1. INTRODUCTION AND BACKGROUND

It is proposed to demolish and rebuild a dwelling at 9 Ocean Road Palm Beach, for which a Development Application is to be submitted to Northern Beaches Council.

The property is located within a “wave inundation” area designated on the Coastal Risk Planning Map (Sheet CHZ_014) that is referenced in *Pittwater Local Environmental Plan 2014*. The property is also mapped as being subject to coastal erosion and coastal inundation hazards in the *Pittwater Coastline Hazard Definition and Climate Change Vulnerability Study* and on the *Pittwater 21 Development Control Plan (DCP)*¹ Map MDCP016.

Therefore, the property is subject to Chapter B3.3 of the DCP, and the *Coastline Risk Management Policy for Development in Pittwater* (denoted as the “Coastline Policy” herein, which is Part D and Appendix 6 of the DCP), and a Coastline Risk Management Report must be submitted as part of the DA. Horton Coastal Engineering was engaged to prepare the required Coastline Risk Management Report, as set out herein.

In the report herein, all 11 items (namely a to k) listed in Clause 9.3 of the Coastline Policy are addressed where appropriate. As required, completed Forms 1 and 1(a) as given in the Coastline Policy are also attached.

The report author, Peter Horton [BE (Hons 1) MEngSc MIEAust CPEng NER], is a professional Coastal Engineer with 27 years of coastal engineering experience. He has postgraduate qualifications in coastal engineering, and is a Member of Engineers Australia (MIEAust) and Chartered Professional Engineer (CPEng) registered on the National Engineering Register (NER). He is also a member of the National Committee on Coastal and Ocean Engineering (NCCOE) and NSW Coastal, Ocean and Port Engineering Panel (COPEP) of Engineers Australia. Peter has prepared Coastline Risk Management Reports for numerous properties along Ocean Road at Palm Beach in recent years, and has inspected the area in the vicinity of the subject property on several occasions in the last few years, including a specific recent inspection on 7 August 2019. He was the lead author of the CZMP referred to above.

¹ The Pittwater 21 DCP up to Amendment No. 25, which came into effect on 1 December 2019, was considered herein.

Note that all levels given herein are to Australian Height Datum (AHD). Zero metres AHD is approximately equal to mean sea level at present.

2. INFORMATION PROVIDED

Horton Coastal Engineering was provided with 15 drawings of the proposed development prepared by MAP Architecture and Interiors Pty Ltd, dated 12 September 2019 and Revision A (namely Dwg No. DA-001 to 004, 101 to 104, 200, 201, 300 to 302, 400 and 500). A site survey completed by Adam Clerke Surveyors Pty Ltd was also provided, Reference 819B and dated 21 August 2019.

3. EXISTING SITE DESCRIPTION

The sandy Palm Beach is about 2.3km long, formed between the rocky Barrenjoey Head in the north and Little Head in the south. The subject property is located on the landward (western) side of Ocean Road towards the southern centre of the beach, with an aerial image provided in Figure 1. At this location, the shoreline is sheltered (by Little Head) to some degree from the dominant south to south-east storm swell waves that occur in Sydney, but is fully exposed to waves from the east and north-east. Photographs of the property at the time of the site inspection on 7 August 2019 are provided in Figure 2 and Figure 3.

Based on the site survey provided, ground elevations at the centreline of Ocean Road are at about 5.9m AHD, increasing to 6.0m AHD and 7.2m AHD at the seaward and landward edges of the driveway respectively. The finished Ground Floor level is 7.3m AHD. Ground levels on the landward side of the dwelling increase to about 11m AHD, and increase further to 34m to 38m AHD at the landward property boundary.

Seaward of Ocean Road, levels fall to the sandy beach, with a cross-shore vegetation width of about 10m. Based on May 2011 Airborne Laser Scanning data held by Horton Coastal Engineering, sand levels at the sand/vegetation interface at that time were about 4.5m AHD. Based on review of photogrammetric data in the NSW Beach Profile Database collected near the property from 1941 to 2018, the distance to the shoreline at mean sea level, seaward of the property, is typically about 80m (reducing after coastal storms that cause erosion of Palm Beach).

4. PROPOSED DEVELOPMENT

It is proposed to demolish the existing dwelling and construct a new dwelling over three levels. The lowest level (Level 1 or Ground) finished floor level is proposed to be 7.3m AHD, the same as existing, with the next level up (Level 2) at 10.8m AHD.

Based on Stormwater Management Drainage Plans and Details prepared by NB Consulting Engineers (3 Drawings, Sheet D01 to D03, Job No. 190875, Issue A, 23 September 2019), the proposed development will include rainwater tanks with a total volume of about 9,000L, with excess stormwater piped to a new kerb and gutter outlet on Ocean Road.



Figure 1: Aerial view of subject property on 30 August 2018



Figure 2: View of subject property (dwelling at arrow) from Palm Beach on 7 August 2019, looking west



Figure 3: View of subject property (dwelling at arrow) from Ocean Road on 7 August 2019, looking WSW

5. SUBSURFACE CONDITIONS

A geotechnical investigation of the subject property has been undertaken by Douglas Partners (2019). As evident in an interpreted geotechnical cross section derived from analysis of 5 boreholes over the site, the inferred level of insitu sandstone or laminite bedrock is above 3m AHD over the proposed development footprint, and above 6m AHD on the seaward side of the dwelling. This bedrock would not be subject to typical sandy beach erosion/recession, and being at such a high level (as well there generally being colluvium² sandstone boulders above the bedrock), geotechnical constraints rather than traditional coastal hazard lines apply at the site.

Douglas Partners (2019) recommended that the proposed development should be supported on footings founded on the insitu bedrock.

6. DESIGN LIFE

In the Coastline Policy, it is noted that a planning period (design project life) of 100 years should be adopted unless otherwise justified. A 60-year planning period has been considered herein, and this can be justified as this is the same planning period adopted in the *Coastal Zone Management Plan for Bilgola Beach (Bilgola) and Basin Beach (Mona Vale)* (CZMP), which was certified by the Minister for the Environment on 30 June 2016 and gazetted on 14 July 2017³. Although this CZMP does not geographically apply at the subject property, it is the only gazetted CZMP in the former Pittwater Council area, and hence is relevant to consider in the selection of design life at a similar open coast beach.

Douglas Partners (2019) adopted a 100 year design life in their geotechnical assessment of the property. It is not unreasonable to have a different (and more conservative) design life for the geotechnical assessment, which includes consideration of risk to life, compared to the coastal engineering assessment for which risk to life is not applicable (only risk to property from coastal inundation).

7. EROSION/RECESSION COASTLINE HAZARDS

As noted in Section 5, elevated bedrock at the subject property means that traditional sandy beach coastal hazards do not apply at the property. In the draft "Coastline Hazard Definition and Climate Change Vulnerability Study" prepared for Pittwater Council and dated 3 July 2012 (denoted as the "Hazard Study" herein), coastline hazard lines in the vicinity of the subject property were derived assuming an entirely sandy erodible subsurface above -1m AHD, which is not applicable. Given that the Hazard Study hazard lines are not relevant at the subject property, they are not depicted herein.

Erosion/recession from coastal processes is not considered to be a significant risk to the proposed development. Based on the Coastline Policy, it is theoretically required to define a Coastline Hazard Line (CHL) and Coastline Management Line (CML)⁴, but these lines do not actually apply at the property due to the elevated bedrock.

² Landslip material that has accumulated at the base of the slope over geological time.

³ A detailed justification of the suitability of a 60-year design life for infill residential development is provided in the CZMP. In summary, a design life of 40 to 60 years is used in numerous Australian Standards relevant to residential construction, and the cost of new residential development is amortised for tax purposes over 40 years based on Subdivision 43-25 of the *Income Tax Assessment Act 1997*, so a 60-year design life is considered to be reasonable and conservative (particularly given the relative frequency at which beachfront property at Palm Beach is redeveloped).

⁴ In the Coastline Policy it is recommended that the CML be defined to be 10m landward of the CHL, unless otherwise justified.

As noted in Section 5, the proposed development should be founded on underlying bedrock. There are no particular foundation requirements from a coastal engineering perspective.

8. COASTAL INUNDATION AND WAVE RUNUP

Wave runup levels at Palm Beach in a severe storm may exceed 8m AHD, particularly taking sea level rise into account over the next 60 years, and assuming an infinite height foreshore. In reality, any waves that overtopped the foreshore seaward of the subject property (at a level of about 6m AHD) would 'fold over' the crest and travel as a sheet flow at shallow depth, spreading out and infiltrating over landward areas⁵. There is the expectation of a significant reduction in the velocity and depth of the runup within the order of 10m from the foreshore crest.

To reduce the risk of wave runup impacting the proposed development, it is recommended that:

- ground levels are contoured to direct wave runup seaward (this has essentially been depicted on the Drawings);
- the Ground Floor and walls up to 0.5m above the floor comprise materials that can tolerate inundation, such as concrete or tiles;
- any electrical equipment, wiring, and any other service pipes and connections in the dwelling that could be damaged by inundation are located at least 0.5m above the ground floor, or waterproofed if below this;
- only items that can withstand periodic inundation are stored on the Ground Floor within 0.5m above the floor level; and
- fuels and other chemicals or potentially toxic materials are stored at least 0.5m above the Ground Floor or in watertight containers.

Based on discussions with Easy Living Home Elevators, in the unlikely event that inundation enters the dwelling and reaches the lift:

- there will be a float switch incorporated into the lift pit (such that once water is detected it will shut the entire lift down); and
- an automatic sump will be incorporated into the pit to drain any inundation, leading to a single way return valve;

The lift unit will also be set to be parked at the highest level, further reducing the potential for it to be inundated.

For the purpose of the report herein, a Coastline Planning Level of 7.8m AHD has been adopted, which is 0.5m above the Ground Floor level. Note that a freeboard does not need to be added to this.

⁵ Although there would be limited infiltration into the Ocean Road surface.

9. MERIT ASSESSMENT

9.1 *State Environmental Planning Policy (Coastal Management) 2018*

9.1.1 *Preamble*

Based on *State Environmental Planning Policy (Coastal Management) 2018* (SEPP Coastal) and its associated mapping, the subject property is within a “coastal environment area” and “coastal use area”.

9.1.2 *Clause 13*

Based on Clause 13(1) of SEPP Coastal, “development consent must not be granted to development on land that is within the coastal environment area unless the consent authority has considered whether the proposed development is likely to cause an adverse impact on the following:

- (a) the integrity and resilience of the biophysical, hydrological (surface and groundwater) and ecological environment,
- (b) coastal environmental values and natural coastal processes,
- (c) the water quality of the marine estate (within the meaning of the *Marine Estate Management Act 2014*), in particular, the cumulative impacts of the proposed development on any of the sensitive coastal lakes identified in Schedule 1,
- (d) marine vegetation, native vegetation and fauna and their habitats, undeveloped headlands and rock platforms,
- (e) existing public open space and safe access to and along the foreshore, beach, headland or rock platform for members of the public, including persons with a disability,
- (f) Aboriginal cultural heritage, practices and places,
- (g) the use of the surf zone”.

This is not a coastal engineering matter, but it can be noted that with regard to (a), the proposed development would not be expected to adversely affect the biophysical, hydrological (surface and groundwater) and ecological environments, being constructed on an already developed property with stormwater being collected in rainwater tanks and any excess stormwater being discharged to Ocean Road as at present. Broader ecological issues are not coastal engineering matters so are not considered herein.

With regard to (b), the proposed development would not be expected to adversely affect coastal environmental values or natural coastal processes any differently to the existing dwelling.

With regard to (c), the proposed development would not be expected to adversely impact on water quality as long as appropriate construction environmental controls are applied, given the residential land use. No sensitive coastal lakes are located in the vicinity of the proposed development.

With regard to (d), this is not a coastal engineering matter so is not definitively considered herein. That stated, there are no undeveloped headlands or rock platforms, nor marine vegetation, in proximity to the proposed development. No significant impacts on marine fauna and flora would be expected as a result of the proposed development, as the proposed development would generally not be expected to interact with subaqueous areas over its

design life. Assuming that there is no native vegetation or fauna or their habitats of significance at the property, this clause has been satisfied.

With regard to (e), it can be noted that the proposed development is entirely within the subject property boundary, and will not alter existing public access arrangements seaward of the property.

With regard to (f), a search of the Office of Environment and Heritage “Aboriginal Heritage Information Management System” (AHIMS) was undertaken on 19 November 2019. This indicated that there were no particular Aboriginal sites recorded nor Aboriginal Places declared within at least 50m of the subject property.

With regard to (g), the proposed development would generally not be expected to interact with the surf zone over its design life.

Based on Clause 13(2) of SEPP Coastal, “development consent must not be granted to development on land to which this clause applies unless the consent authority is satisfied that:

- (a) the development is designed, sited and will be managed to avoid an adverse impact referred to in subclause (1), or
- (b) if that impact cannot be reasonably avoided—the development is designed, sited and will be managed to minimise that impact, or
- (c) if that impact cannot be minimised—the development will be managed to mitigate that impact”.

The proposed development has been designed and sited to avoid any potential adverse impacts referred to in Clause 13(1).

9.1.3 Clause 14

Based on Clause 14(1) of SEPP Coastal, “development consent must not be granted to development on land that is within the coastal use area unless the consent authority:

- (a) has considered whether the proposed development is likely to cause an adverse impact on the following:
 - (i) existing, safe access to and along the foreshore, beach, headland or rock platform for members of the public, including persons with a disability,
 - (ii) overshadowing, wind funnelling and the loss of views from public places to foreshores,
 - (iii) the visual amenity and scenic qualities of the coast, including coastal headlands,
 - (iv) Aboriginal cultural heritage, practices and places,
 - (v) cultural and built environment heritage, and
- (b) is satisfied that:
 - (i) the development is designed, sited and will be managed to avoid an adverse impact referred to in paragraph (a), or
 - (ii) if that impact cannot be reasonably avoided—the development is designed, sited and will be managed to minimise that impact, or
 - (iii) if that impact cannot be minimised—the development will be managed to mitigate that impact, and
- (c) has taken into account the surrounding coastal and built environment, and the bulk, scale and size of the proposed development”.

With regard to Clause (a)(i), the proposed development is entirely on private property and will not affect public foreshore, beach, headland or rock platform access.

Clauses (a)(ii) and a(iii) are not coastal engineering matters so are not considered herein.

With regard to (a)(iv), as noted in Section 9.1.2, there are no particular Aboriginal sites recorded nor Aboriginal Places declared within at least 50m of the subject property.

With regard to (a)(v), the nearest environmental heritage items to the subject property listed in Schedule 5 of *Pittwater Local Environmental Plan 2014* are the “Skye” house at 9 Northview Road Palm Beach (about 70m from the subject property) and the “Villa d’Este” house at 3 Northview Road Palm Beach (about 80m from the subject property). There is also the Sunrise Hill Heritage Conservation Area about 60m from the subject property. The proposed development would not be expected to impact on these locations from a coastal engineering perspective.

With regard to (b), the proposed development has been designed and sited to avoid any potential adverse impacts referred to in Clause 14(1) for the matters considered herein.

Clause (c) is not a coastal engineering matter so is not considered herein.

9.1.4 Clause 15

Based on Clause 15 of SEPP Coastal, “development consent must not be granted to development on land within the coastal zone unless the consent authority is satisfied that the proposed development is not likely to cause increased risk of coastal hazards on that land or other land”.

The proposed development, being founded on bedrock, would not increase the risk of coastal hazards on the subject property or adjacent properties over the design life.

9.1.5 Synthesis

The proposed development satisfies the requirements of *State Environmental Planning Policy (Coastal Management) 2018* for the matters considered herein.

9.2 *Pittwater Local Environmental Plan 2014*

Clause 7.5 of *Pittwater Local Environmental Plan 2014* (LEP 2014) applies at the subject property, as the property is identified as a “wave inundation” area on the Coastal Risk Planning Map (Sheet CHZ_014). Based on Clause 7.5(3) of LEP 2014, “development consent must not be granted to development on land to which this clause applies unless the consent authority is satisfied that the development:

- (a) is not likely to cause detrimental increases in coastal risks to other development or properties, and
- (b) is not likely to alter coastal processes and the impacts of coastal hazards to the detriment of the environment, and
- (c) incorporates appropriate measures to manage risk to life from coastal risks, and
- (d) is likely to avoid or minimise adverse effects from the impact of coastal processes and the exposure to coastal hazards, particularly if the development is located seaward of the immediate hazard line, and

- (e) provides for the relocation, modification or removal of the development to adapt to the impact of coastal processes and coastal hazards, and
- (f) has regard to the impacts of sea level rise, and
- (g) will have an acceptable level of risk to both property and life, in relation to all identifiable coastline hazards”.

With regard to (a) and (b), the proposed development would not increase coastal risks nor alter coastal processes and the impacts of coastal hazards over its design life. This is because it is to be founded on bedrock considering impacts for an acceptably rare storm over an acceptably long life, and has measures incorporated to reduce the risk of coastal inundation damage (see Section 8).

With regard to (c) and (g), founding the proposed development on bedrock and adopting the recommendations in Section 8 are appropriate measures to achieve an acceptably low risk to property and life from coastal risks. With regard to (d), founding the proposed development on bedrock and adopting the recommendations in Section 8 also minimises the adverse effects from the impact of coastal processes and the exposure to coastal hazards for the proposed development, and the proposed development is located landward of the Immediate Hazard Line. Given that the proposed development is at an acceptably low risk of damage for an acceptably long life, (e) is not necessary.

With regard to (f), sea level rise has been considered herein, with the coastline hazard lines and wave runup levels adopted incorporating sea level rise projections.

9.3 *Pittwater 21 DCP*

Based on Section B3.3 of the DCP:

- “development must be designed and constructed to ensure that every reasonable and practical means available is used to remove risk to an acceptable level for the life of the development; and,
- the development must not adversely affect or be adversely affected by coastal processes nor must it increase the level of risk for any people, assets and infrastructure in the vicinity due to coastal processes”.

As discussed in Section 9.1 and 9.2, if the recommendations outlined herein are followed the proposed development would be at an acceptably low risk of being damaged or adversely affected by coastal processes for a 60 year design life (for both erosion/recession and wave runup), and would not adversely affect or increase the level of risk to any people, assets or infrastructure in its vicinity.

Based on Section 8.1(i) of the Coastline Policy:

- a) “all structures below the Coastline Planning Level shall be constructed from flood compatible materials;
- b) all development must be designed and constructed so that it will have a low risk of damage and instability due to wave action and/or oceanic inundation hazards;
- c) all development and/or activities must be designed and constructed so that they will not adversely impact on surrounding properties, coastal processes or the amenity of public foreshore lands;
- d) all uncontaminated dune sand excavated during construction operations shall be returned to the active beach zone as approved and as directed by Council;

- e) wherever present, remnant foredune systems shall be appropriately rehabilitated and maintained for the life of the development to stabilise an adequate supply of sand (as determined by a coastal engineer) that is available to buffer erosion processes and/or minimise the likelihood of oceanic inundation;
- f) all vegetated dunes, whether existing or created as part of coastal protection measures shall be managed and maintained so as to protect the dune system from damage both during construction of the development and as a result of subsequent use during the life of the development;
- g) all electrical equipment, wiring, fuel lines or any other service pipes and connections must be waterproofed to the Coastline Planning Level;
- h) the storage of toxic or potentially polluting goods, materials or other products, which may be hazardous or pollute waters during property inundation, will not be permitted below the Coastline Planning Level;
- i) for existing structures, a tolerance of up to minus 100mm may be applied to the Coastline Planning Level in respect of compliance with these controls;
- j) building heights must not exceed 8.0 metres above the Coastline Planning Level or 8.5 metres above existing ground level, whichever is higher; and,
- k) where land is also subject to the provisions of the Flood Risk Management Policy for Development around Pittwater, the higher of the Coastline Planning Level and Flood Planning Level shall apply”.

For Item (a), this has been recommended for within 0.5m of the Ground Floor (see Section 8), that is, below the Coastline Planning Level of 7.8m AHD.

For Item (b), it has been noted previously that the proposed development has an acceptably low risk of damage and instability due to wave action (erosion/recession) and oceanic inundation (wave runup) hazards over an acceptably long design life.

For Item (c), it has been noted previously that the proposed development would not be expected to adversely impact on surrounding properties or coastal processes.

For Item (d), any excess suitable excavated sand can be placed on the active beach as may be required by Council, if directed by Council.

For Item (e), this requirement is noted, but is not applicable at the subject property.

For Item (f), no vegetated dunes would be impacted by the proposed development.

For Items (g) and (h), this was noted in Section 8 in relation to the Ground Floor level.

Item (i) is not applicable.

Item (j) is a matter for others to confirm or discuss.

For Item (k), the property is not mapped as being affected by catchment flooding.

In conclusion, the proposed development is consistent with the Coastline Policy matters considered above.

10. CONCLUSIONS

The proposed development would be at an acceptably low risk of damage (over a reasonable 60 year design life) from erosion/recession as it is to be founded on bedrock, and from coastal inundation and wave runup if the measures outlined in Section 8 are adopted.

The proposed development satisfies the requirements of *State Environmental Planning Policy (Coastal Management) 2018* (Clauses 13, 14 and 15), Clause 7.5 of *Pittwater Local Environmental Plan 2014*, Section B3.3 of the *Pittwater 21 DCP* and the *Coastline Risk Management Policy for Development in Pittwater* for the matters considered herein.


11. REFERENCES

Douglas Partners (2019), *Report on Geotechnical Investigation. Proposed New Residence, 9 Ocean Road Palm Beach*, Project 86970.00, Revision 0, 20 December

12. SALUTATION

If you have any further queries, please do not hesitate to contact Peter Horton via email at peter@hortoncoastal.com.au or via mobile on +61 407 012 538.

Yours faithfully
HORTON COASTAL ENGINEERING PTY LTD



Peter Horton
Director and Principal Coastal Engineer

This report has been prepared by Horton Coastal Engineering Pty Ltd on behalf of and for the exclusive use of John Bubb and Christina Neumann-Bubb (the client), and is subject to and issued in accordance with an agreement between the client and Horton Coastal Engineering Pty Ltd. Horton Coastal Engineering Pty Ltd accepts no liability or responsibility whatsoever for the report in respect of any use of or reliance upon it by any third party. Copying this report without the permission of the client or Horton Coastal Engineering Pty Ltd is not permitted.

Coastline Risk Management Policy for Pittwater Form No. 1 and Form No. 1(a) are attached overleaf

COASTLINE RISK MANAGEMENT POLICY FOR PITTWATER

FORM NO. 1 – To be submitted with Development Application

Development Application for <u>Vaughan Milligan Development Consuting</u>	Name of Applicant
Address of site <u>9 Ocean Road Palm Beach</u>	

Declaration made by a Coastal Engineer as part of a Coastal Risk Management Report

I, Peter Horton on behalf of Horton Coastal Engineering Pty Ltd
(Insert Name) (Trading or Company Name)

on this the 4 January 2020
(date)

certify that I am a Coastal Engineer as defined by the Coastline Risk Management Policy for Pittwater and I am authorised by the above organisation/company to issue this document and to certify that the organisation/company has a current professional indemnity policy of at least \$2 million.

I have:

Please mark appropriate box

- Prepared the detailed Coastal Risk Management Report referenced below in accordance with the Pittwater Council Coastline Risk Management Policy
- Am willing to technically verify that the detailed Coastal Risk Management Report referenced below has been prepared in accordance with the Pittwater Council Coastline Risk Management Policy
- Have examined the site and the proposed development/alteration in detail and, as detailed in my report, am of the opinion that the Development Application only involves Minor Development/Alterations or is sited such that a detailed coastal hazard analysis or risk assessment is not required.
- Provided the coastal hazard analysis for inclusion in the Coastal Risk Management Report


Coastal Risk Management Report Details:

Report Title: <u>Coastline Risk Management Report for 9 Ocean Road Palm Beach</u>
Report Date: <u>4 January 2020</u>
Author: <u>Horton Coastal Engineering Pty Ltd</u>

Documentation which relate to or are relied upon in report preparation:

<u>See Section 2 and Section 11 of report</u>

I am aware that the above Coastal Risk Management Report, prepared for the above mentioned site is to be submitted in support of a Development Application for this site and will be relied on by Pittwater Council as the basis for ensuring that the coastal risk management aspects of the proposed development have been adequately addressed to achieve an acceptable risk management level for the life of the structure, taken as at least 100 years unless otherwise stated and justified in the Report and that reasonable and practical measures have been identified to remove foreseeable risk.

Signature 

Name **Peter Horton**

Chartered Professional Status..... **MIEAust CPEng NER**

Membership No. **452980**

COASTLINE RISK MANAGEMENT POLICY FOR PITTWATER

FORM NO. 1(a) - Checklist of Requirements for Coastal Risk Management Report for Development Application or Part 5 Assessment

Development Application for <u>Vaughan Milligan Development Consuting</u> Name of Applicant
Address of site <u>9 Ocean Road Palm Beach</u>

The following checklist covers the minimum requirements to be addressed in a Coastal Risk Management Report. This checklist is to accompany the Coastal Risk Management Report and its certification (Form No. 1).

Coastal Risk Management Report Details:

Report Title: <u>Coastline Risk Management Report for 9 Ocean Road Palm Beach</u>
Report Date: <u>4 January 2020</u>
Author: <u>Horton Coastal Engineering Pty Ltd</u>

Please mark appropriate box

- Comprehensive site mapping conducted Survey provided as per Section 2
(date)
- Mapping details presented on contoured site plan to a minimum scale of 1:200 (as appropriate)
Not applicable, as site not subject to traditional coastal hazard lines
- Subsurface investigation required
 - No Justification
 - Yes Date conducted Refer to Douglas Partners (2019)
- Impact by and upon coastal processes identified
- Coastal hazards identified
- Coastal hazards described and reported
- Risk assessment conducted in accordance with Council's Policy
- Adequacy of existing coastal protection measures assessed and certified (not applicable)
- Opinion has been provided that the design can achieve the risk management criteria in accordance with Council's Policy provided that the specified conditions are achieved.

Design Life Adopted:

100 years

Other **60 years (as justified)**
specify

Development Controls as described in the Pittwater Coastline Risk Management Policy have been specified

Additional actions to remove risk where reasonable and practical have been identified and included in the Coastal Risk Management Report.

I am aware that Pittwater Council will rely on the Coastal Risk Management Report, to which this checklist applies, as the basis for ensuring that the coastal risk management aspects of the proposal have been adequately addressed to achieve an acceptable risk management level for the life of the structure, taken as at least 100 years unless otherwise specified, and justified in the Report and that reasonable and practical measures have been identified to remove foreseeable risk.

Signature 

Name **Peter Horton**

Chartered Professional Status **MIEAust CPEng NER**

Membership No. **452980**