

A large, stylized graphic of a flame or fire, rendered in shades of grey and blue, occupies the background of the page. The flame is composed of several overlapping, flowing shapes that create a sense of movement and heat. The top part of the flame is grey, while the bottom part is a solid blue. The overall shape is abstract and modern.

Concept Fire Engineering Strategy

171 Forest Way, Belrose NSW 2085




Revision: CFES 1.2

Date: 23 May 2022

Project Number: S21023

Prepared for: Forest Ridge

Document Control

Document Control and Verification					
Revision	Date		Prepared by	Reviewed By	Approved By
CFES 1.0	1/06/2021	Name:	Lin Li	Lei Wang C10: BDC3165	Mark McDaid C10: BDC2165
		Signature:			
		Comment:	Issue 1.0 - Concept Fire Engineering Strategy / Feasibility		
CFES 1.1	11/06/2021	Name:	Lin Li	Lei Wang C10: BDC3165	Mark McDaid C10: BDC2165
		Signature:			
		Comment:	Issue 1.1 - Updated Concept Fire Engineering Strategy / Feasibility incorporating design change.		
CFES 1.2	23/05/2022	Name:	Lin Li	Lei Wang C10: BDC3165	Mark McDaid C10: BDC2165
		Signature:			
		Comment:	Issue 1.2 - Updated Concept Fire Engineering Strategy / Feasibility incorporating design change.		

© MCD Fire Engineering Pty Ltd. All rights reserved.

MCD Fire Engineering has prepared this document for the sole use of Forest Ridge, Belrose and for a specific purpose, each as expressly stated in the document. No other party should rely on this document without the prior written consent of MCD Fire Engineering. MCD Fire Engineering undertakes no duty, nor accepts any responsibility, to any third party who may rely upon or use this document. This document has been prepared based on the description of requirements and MCD Fire Engineering's experience, having regard to assumptions that MCD Fire Engineering can reasonably be expected to make in accordance with sound professional principles. MCD Fire Engineering accepts no liability for information provided by the Client and other third parties used to prepare this document or as the basis of the analysis. Subject to the above conditions, this document may be transmitted, reproduced or disseminated only in its entirety.

Executive Summary

Forest Ridge has appointed MCD Fire Engineering Pty Ltd to carry out an initial review of the findings of concept drawings of the subject works from a fire engineering viewpoint. The intention of this report is to provide some preliminary fire engineering advice and conceptual fire engineering feasibilities for the proposed residential development at 171 Forest Way, Belrose NSW 2085.

The matters detailed in the BCA Assessment relate to a high-level fire and life safety review and the following matters have been identified as having a scope to rectify that does not have to strictly comply with the deemed-to-satisfy (DtS) provisions of the BCA. As such Performance Solutions are sought from a C10 Accredited Fire Safety Engineer to provide an alternative scope of works to address the variations to the DtS Provisions of the BCA/NCC.

The intent of this conceptual report is to provide a high-level fire engineering input for the project in order to document the likely fire safety measures for the building in order to achieve compliance with the relevant Performance Requirements of the BCA. The following is the currently agreed high level scope for fire engineering, the performance requirements listed in the tables below are the minimum Performance Requirements that must be considered, should the fire engineer identify more relevant Performance Requirements these are to be also considered.

Table 1: Summary of Performance Solution

No	DtS Clause	Description of non-compliance	Performance Requirement (A2.2(3) & A2.4)	Method of meeting Performance Requirements (A2.1)	Assessment Method (A2.2(2))
1.	C2.14	To review the length of public corridors on residential area exceeding 40 m (up to 46 m) without separation of smoke doors.	CP1, CP2	A2.1(1)	A2.2(2)(d)
2.	D1.4	To review the extended travel distance from carpark to a single exit up to 34 m in lieu of 20 m.	DP4, EP2.2	A2.1(1)	A2.2(2)(d)
3.	D1.7(b)	To review the fire-isolated stairs discharging into internal areas not complying with the requirement of BCA D1.7(b).	DP4, DP5, EP2.2	A2.1(1)	A2.2(2)(b)(ii)
4.	D1.7(c)	To review the egress routes following the discharge of the fire-isolated stairs being located within 6 m of unprotected openings.	DP4, DP5, EP2.2	A2.1(1)	A2.2(2)(b)(ii)

Contents

Executive Summary	3
1 Introduction.....	5
1.1 Objective.....	5
1.2 Applicable Legislation	5
1.3 Stakeholders and Documentation	5
1.4 Occupant Characteristics	11
1.5 BCA Building Information Characteristics	12
2 Conceptual Fire Safety Measures	13
3 Key Assumptions and Limitations.....	17
Appendix A Proposed Drawings	18

1 Introduction

1.1 Objective

Forest Ridge has appointed MCD Fire Engineering Pty Ltd to carry out an initial review of the findings of concept drawings of the subject works from a fire engineering viewpoint. The intention of this report is to provide some preliminary fire engineering advice and conceptual fire engineering feasibilities for the proposed residential development at 171 Forest Way, Belrose NSW 2085.


1.2 Applicable Legislation

The primary legislation applicable to the development is the National Construction Code (NCC), Volume One aka as the BCA 2019 (Amendment 1): Building Code of Australia. The BCA provides a set of prescriptive requirements, *Deemed-to-Satisfy* (DtS) Provisions that if meet, are deemed an acceptable level of safety and achieve compliance with the Performance Requirements of the BCA. Deviations from the BCA DtS Provisions must be shown and be addressed as a Performance Solutions to demonstrate they comply with the BCA Performance Requirements.

This Report is not a Performance Solution Report, but rather a Conceptual Fire Engineering Strategy that sets down the intentions or proposed fire safety strategy and likely fire engineering Performance Solution requirements.

The assessment of a Performance Solution can be undertaken using a variety of methods. These are defined in BCA Clause A2.2(3) and A2.4. One or more, or a combination of these methods can be adopted to determine whether the proposed Performance Solution complies with the BCA Performance Requirements. The relevant BCA Performance Requirements are determined in accordance with BCA Clause A2.2(3) and A2.4. Compliance with BCA Performance Requirements is undertaken in accordance with BCA Clause A2.1. BCA Clause A2.1 and A2.2(2) are presented below in Table 2.

Table 2: Methods of Meeting the Performance Requirements and Assessment Method for Performance Solution

BCA Clause A2.1	BCA Clause A2.2(2)
<p>Performance Requirements are satisfied by one of the following—</p> <ol style="list-style-type: none"> (1) A Performance Solution; or (2) A Deemed-to-Satisfy Solution; or (3) A combination of (1) and (2) <p>as shown below:</p>  <pre> graph TD CR[Compliance Level] --> PR[PERFORMANCE REQUIREMENTS] PR --> PS[PERFORMANCE SOLUTION] PR --> DTS[DEEMED-TO-SATISFY SOLUTION] PS --- OR[and/or] DTS --- OR OR --- CS[Compliance Solutions] </pre>	<p>A Performance Solution must be shown to comply with the relevant Performance Requirements through one or a combination of the following Assessment Methods:</p> <ol style="list-style-type: none"> (a) Evidence of suitability in accordance with Part A5 that shows the use of a material or product, plumbing and drainage product, form of construction or design meets a Performance Requirement. (b) Verification Methods including the following: <ol style="list-style-type: none"> (i) the Verification Methods in the NCC; or (ii) Other Verification Methods, accepted by the appropriate authority that show compliance with the relevant Performance Requirements (c) Expert Judgement (d) Comparison with the Deemed-to-Satisfy Provisions

The following New South Wales Legislation is applicable:

- NSW Environmental Planning and Assessment Act, 1979 and subsequent amendments
- NSW Environmental Planning and Assessment Regulation, 2000 and subsequent amendments

1.3 Stakeholders and Documentation

The relevant stakeholders in the design of this development are listed in Table 3 below.

Table 3: Relevant Stakeholders

Name	Organisation	Role
Steve Horrell	Forest Ridge	Client
TBA	Barry Rush & Associates Pty Ltd	Architect
TBA	TBA	Principal Certifier
Mark McDaid, Lei Wang, Lin Li	MCD Fire Engineering Pty Ltd	Fire Engineering

1.3.1 Use and Location

The proposed building is located at 171 Forest Way, Belrose NSW 2085. The proposed building consists of Class 2 (Residential Apartments) and Class 7a (Carpark). The Fire Service can access the building from Forest Way as shown in Figure 1.



Figure 1: Map showing brigade access

1.3.2 Size and shape

The site steps down from street level (Level 8) at Forest Way at the front (RL 167.0) to Level 1 at rear (RL 146.6). There are 6 blocks (A-F), each not more than 4 storeys but overall being connected along the slope. The total gross floor area of the building is approximately 5,399 m².

Refer to Appendix A for more details.

1.3.3 Exit arrangements

The exit provisions for each levels are shown in Figure 2 - Figure 10.

Note: the “green arrows” used in the following figures are illustrative only and not the confirmed exit / directional exit sign posting locations (to be confirmed by electrical engineer).




Figure 2: Exit provisions on Level 1



Figure 3: Exit provisions on Level 2



Figure 4: Exit provisions on Level 3



Figure 5: Exit provisions on Level 4




Figure 6: Exit provisions on Level 5



Figure 7: Exit provisions on Level 6




Figure 8: Exit provisions on Level 7




Figure 9: Exit provisions on Level 8




Figure 10: Exit provisions on Level 9

1.4 Occupant Characteristics

Building occupants can generally be classified into separate distinctive groups; residents and visitors. All occupants are assumed to be representative of the general population with no specific or unusual distributions in respect to gender, age and physical or mental attributes. A detailed description is contained in Table 4 below:

Table 4: Occupancy Characteristics

Characteristic	Description
Familiarity	<p>Residents: Residents are expected to be familiar with the layout of the building and the location of exits.</p> <p>visitors: Visitors will generally be aware of the route they entered the building and are more likely to evacuate the building via this route even if other exits are closer.</p> <p>Most occupants, however, are expected to be mostly transient and it cannot be guaranteed that all occupants would be familiar with the building, its layout and the exit points.</p>
Awareness	Residents and visitors may be under the influence of alcohol or other mild narcotics at some times.
Mobility	The occupants are considered to be representative of the general population including a limited proportion of mobility impaired occupants. These occupants may require crutches, a wheelchair or similar to evacuate on their own or need assistance from other occupants.
Training	It is assumed that occupants in the development will not have any emergency training.
Age	All occupants are considered to be representative of the general population with no specific or unusual distributions in respect to gender or age.
Culture / language	The occupants are considered to be representative of the general population with some members having varying cultural backgrounds and languages.
Occupancy Loading	Occupancy levels and distribution throughout the building is assumed to be in accordance with the occupancy loadings of Table D1.13 of the BCA.

1.5 BCA Building Information Characteristics

The initial review has identified the following information for the building as listed in Table 5.

Table 5: Relevant Building Information

BCA Clause		Description
Schedule 3	Effective Height	Less than 25 m
A6	Occupancy Classification	BCA Class 2 (Residential) BCA Class 7a (Carpark)
C1.1	Minimum Type of Construction	Type A
C1.2	Rise in Storeys	4
C2.2	Fire Compartment Floor Area and Volume	BCA Class 2 – N/A BCA Class 7a < 5,000 m ² , 30,000 m ³
Spec E1.5a	Sprinkler Required?	Yes

2 Conceptual Fire Safety Measures

The following high level fire safety measures should be read in conjunction with a BCA review for the building. These measures aim to act as a base point of any further and more detailed fire engineering assessment and reports as part of the Certification / Approvals processes.

It is outlined herein that, subject to the preliminary fire safety measures being incorporated into the design as detailed in Table 6 below as part of the concept fire safety design, and in conjunction with DtS fire safety measures as listed in a BCA Assessment Report, the future fire engineering assessments undertaken should be able to demonstrate that the identified deviations from the Deemed-to-Satisfy (DtS) Provisions meet the relevant Performance Requirements of the BCA. All other aspects of the proposed works are understood to be in accordance with the BCA DtS Provisions or as accepted by the Principal Certifier/Council.

Table 6: Required Fire Safety Features

Fire Safety Measure	Description
Construction Requirements (general)	<p>In accordance with Part C of the BCA, the building is required to be of Type A construction. All building elements are required to have a fire resistance level (FRL) as listed in Table 4 of Specification C1.1 of the BCA, except where addressed as a performance solution.</p> <p>All penetrations in fire rated construction shall be fire stopped in accordance with the BCA DtS requirements.</p>
Fire stopping at penetrations through fire rated elements	<ul style="list-style-type: none"> All penetrations through fire rated elements (wall, floor, ceiling etc) shall be fire stopped/sealed in accordance with BCA C3.15/Spec C3.15 and/or tested systems. Fire stopping schedule shall be prepared by each contractor detailing the full FRL, product/system used, location of application, date of installation, personnel for the installation, test/assessment report, completed photo, label, etc. If the fire stopping schedule is not prepared by each contractor, an independent fire stopping specialist shall check and confirm the compliance of all the fire stopping works, and prepare a full fire stopping register for the entire building.
General Requirement - Electrical/Comms rooms/cupboard along path of travel	<p>In accordance with BCA Clause D2.7, any Electrical/Comms rooms/cupboard located along path of travel shall be smoke sealed/separated from the remaining area:</p> <ul style="list-style-type: none"> Any penetration through the Electrical/Comms rooms/cupboard shall be smoke sealed. The doors to the Electrical/Comms rooms/cupboard shall be fitted with ambient and medium smoke seals (refer to below separate section for detailed requirements for smoke seals). The doors to the Electrical/Comms rooms/cupboard, if not fire doors, shall be fitted with non-combustible backing such as metal sheeting, FC sheeting, plasterboard etc.
Fire safety doors and exit doors – general requirements of statutory signage	<p><u>General requirement - BCA D2.23</u></p> <p>Fire doors and smoke doors (except for SOU entry doors) must be provided with a sign in 20 mm capital lettering on both sides of the doors as required in BCA D2.23. The signs are required to be as follows:</p> <ul style="list-style-type: none"> to fire or smoke doors held open with automatic closing hold-open devices: FIRE SAFETY DOOR – DO NOT OBSTRUCT to self-closing fire or smoke doors: FIRE SAFETY DOOR DO NOT OBSTRUCT DO NOT KEEP OPEN to a door discharging from a fire-isolated exit: FIRE SAFETY DOOR – DO NOT OBSTRUCT <p><u>General requirement – EP&A Clause 183</u></p>

Fire Safety Measure	Description
	<p>Fire safety notices shall be provided to any fire-isolated stairway, passageway or ramp as required in EP&A Clause 183. The notice shall contain the wording as follows. The words “OFFENCE RELATING TO FIRE EXITS” in the notice must be in letters at least 8 millimetres high, and the remaining words must be in letters at least 2.5 millimetres high:</p> <p style="text-align: center;">“OFFENCE RELATING TO FIRE EXITS</p> <p><i>It is an offence under the Environmental Planning and Assessment Act 1979:</i></p> <p><i>(a) to place anything in or near this fire exit that may obstruct persons moving to and from the exit, or</i></p> <p><i>(b) to interfere with or obstruct the operation of any fire doors, or</i></p> <p><i>(c) to remove, damage or otherwise interfere with this notice.”</i></p>
Fail-safe to doorways	<ul style="list-style-type: none"> All automatic sliding doors, where serving as a path of travel or an exit in a fire emergency, shall fail safe to open and remain in open position on a general fire alarm. All doorways that are normally secured/locked, where serving as a path of travel or an exit in a fire emergency, shall fail safe to unlock on a general fire alarm.
Smoke seals (general requirements)	<p>Where required in this Report (or proposed Fire Engineering Performance Solution) or by any DTS requirement for the ambient and medium temperature rated smoke seals, they shall have a smoke leakage rate of < 40 m³/h (at medium temperature conditions at a pressure differential of 25 Pa after exposure at 200 °C for at least 30 minutes) when tested to AS1530.7. The smoke seals shall be fitted to all sides of the door including the bottom side. When selecting the smoke seals, the following shall be considered:</p> <ul style="list-style-type: none"> Considerations shall be made when selecting smoke seals products such that they shall be compatible with the fire doors, such as the gaps around the perimeters of the doors and if the seals are suitable for the floor covering (if applicable). The installation of smoke seals shall be the same as that for the tested specimen and the provisions of AS 6905-2007. The clearances, seal contacts and other critical design attributes for fire doors shall be within the range established by test to AS 1530.7 and any variations permitted by AS 6905-2007. Recommended smoke seals products are Lorient LAS1212 & LAS1515 Batwing Perimeter Seals door frame perimeters and LAS8001si, LAS8002si, LAS8003si, LAS8005si, LAS8008si and LAS8009si threshold drop seals. Test Report EWFA Report No: 33937100.1 by Exova Warringtonfire for the above mentioned Lorient smoke seals have been reviewed, which demonstrates a smoke sealing performance that meets the set criteria above.
Smoke seals to fire doors	All fire doors in the building (including SOU entry doors, fire stair entry doors etc) shall be provided with ambient and medium temperature rated smoke seals.
Extended length of residential public corridors	Subject to detailed assessment in Fire Engineering Report in Construction Certificate stage, it is permitted to have the length of public corridors on residential area exceeding 40 m (up to 46 m) without separation of smoke doors, with enhancements to be provided to the active (e.g. detection and sprinklers) and passive (e.g. smoke seals) fire safety measures to the affected parts of the building.
Extended travel distance in carpark areas	Subject to detailed assessment in Fire Engineering Report in Construction Certificate stage, it is permitted to have extended travel distance in carpark areas up to 34 m instead of 20 m to a single exit, with enhancements to be provided to the active (e.g. detection and sprinklers) and passive (e.g. smoke seals) fire safety measures to the affected parts of the building.
Discharge of fire-isolated stairs	<p>Subject to detailed assessment in Fire Engineering Report in Construction Certificate stage, the following DTS departures for the discharge of fire-isolated stairs may be permitted, with enhancements to be provided to the active (e.g. detection and sprinklers) and passive (e.g. smoke seals) fire safety measures to the affected parts of the building:</p> <ul style="list-style-type: none"> Fire-isolated stairs discharging into internal areas not complying with the requirement of BCA D1.7(b). Egress routes following the discharge of the fire-isolated stairs being located within 6 m of unprotected openings.

Fire Safety Measure	Description
	<p>Note: At this stage, the location/extent of the above DtS departures are yet to be confirmed and will be subject to a more detailed BCA review.</p> <p>The expected fire safety requirements for the proposed fire safety requirements are:</p> <ul style="list-style-type: none"> Management on fuel load control in the fire-isolated stair internal discharge area with signage installed on the wall. Smoke seals to all doors opening into the fire-isolated internal discharge area. The openings that are within 6 m of an egress route following the discharge of a fire-isolated stair shall have a dedicated row of sprinklers provided in the room within 0.5 m of the glazed openings.
Automatic fire detection and alarm system	<p>A fire detection system shall be provided in accordance with BCA Spec E2.2a Clause 5 and AS 1670.1-2018 and additional requirements as follows:</p> <ul style="list-style-type: none"> Smoke detectors in accordance with AS 1670.1-2018 (Section 5) in: <ul style="list-style-type: none"> Carpark: Garbage/Recycle Room, Electrical Room All residential common areas including lobby, storage room, cupboards for electrical or comms services Fire-isolated stair and lift shaft as per 1670.1-2018 Smoke detectors in accordance with AS 1670.1-2018 (Section 7) in carpark circulation spaces and in front of fire stair door. Smoke alarms in accordance with AS 3786-2014 inside residential SOUs. <ul style="list-style-type: none"> Where there is more than one smoke alarm inside the one single SOU, they shall be interconnected. For Smoke detectors in accordance with AS 1670.1-2018 (Section 5), the spacing of smoke detectors shall be maximum 10 m apart, and maximum 5 m to end wall or bulkhead/beams more than 300 mm deep. For Smoke detectors in accordance with AS 1670.1-2018 (Section 7), the spacing of smoke detectors shall be maximum 15 m apart, and maximum 7.5 m to end wall or bulkhead/beams more than 300 mm deep. Refer to Clause 5.1.6 of AS 1670.1-2018 for detailed requirements for location of detectors on level surfaces with deep beams/bulkhead. The following general requirements from AS 1670.1 to detectors (including both smoke and heat detectors) shall be noted: <ul style="list-style-type: none"> Where an area is divided into sections by walls, partitions or storage racks reaching within 300 mm of the ceiling (or the soffits of the joists where there is no ceiling), each section shall be treated as a room, and shall be protected. A clear space for access of at least 300 mm radius, to a depth of 600 mm, shall be maintained from the detector or sampling point. Minor building structure and service occupying this space shall not exceed 25 percent of the clear space provided it does not prevent access to the detector. Detectors shall not be installed closer than 900 mm to any air supply opening.
Building Occupant Warning System (BOWS)	<p>A Building Occupant Warning System (BOWS) shall be provided throughout in accordance with BCA Spec E2.2a Clause 7 and AS 1670.1-2018.</p> <ul style="list-style-type: none"> The Building Occupant Warning System (BOWS) shall be interconnected with the AS 1670.1 smoke detection system and fire sprinkler system (except for FPAA101D system).
Fire sprinkler system	<p>The subject building is required to be provided with a sprinkler system in accordance with BCA Clause E1.5 and Spec E1.5a <u>throughout</u>.</p> <ul style="list-style-type: none"> The system can be an AS 2118.1, AS 2118.4, FPAA101D or FPAA101H system. Note: there are certain requirements/concessions applicable on other DtS requirements – refer to BCA Spec E1.5a for details. For example, typical concessions applied to sprinkler protected building that DO NOT apply to a building protected by a FPAA101D system are: <ul style="list-style-type: none"> BCA Clause C2.6 (Spandrels);



Fire Safety Measure	Description
	<ul style="list-style-type: none"> ○ BCA Clause C2.7 (lower roof areas and protections); ○ BCA Spec C1.1 clause 3.5 (Roof Concession); ○ BCA Spec C1.1 clause 3.10 (FRL Concession); ○ BCA Clause C1.10 and Spec C1.10 (Fire Hazard Properties); ○ BCA Clause D1.3 (When fire isolated stairs are required) ○ Various BCA Clause C, D and E parts relating to fire trips/activations/release of systems, etc. <p>The following additional requirements are noted:</p> <ul style="list-style-type: none"> ■ All ceiling mounted sprinkler heads shall be fast response with an RTI of 50 (m·s)^{1/2} or less. ■ Activation temperature of 68°C except where otherwise required by AS 2118.1 (such as under glazed skylights and roof areas). ■ Activation of the sprinkler system shall activate the Building Occupant Warning System (except for a FPAA101D system). ■ Attention is drawn to the specific requirements of AS 2118.1 with regard to height of storage / racking and clearances below sprinkler heads, generally required to be at least 500 mm. Where the sprinklers heads are located above a storage cage, a perforated barrier shall be installed to the top of the cage to ensure there is no storage within the 500 mm clearance below the sprinkler heads. ■ The openings that are within 6 m of an egress route following the discharge of a fire-isolated stair shall have a dedicate row of sprinklers provided in the room within 0.5 m of the glazed openings.
Fire hydrant system	<p>A fire hydrant system shall be provided in accordance with BCA E1.3 and AS 2419.1, OR Spec E1.5a Clause 3(b)(vii), i.e., a dry fire hydrant system that otherwise complies with AS 2419.1, except as permitted for the following:</p> <ul style="list-style-type: none"> ■ The system pipework is not connected to the water supply; ■ An on-site fire pumpset is not required; ■ The minimum fire hydrant outlet flow of 6 L/s may be achieved when boosted by a fire brigade pumping appliance; ■ The minimum pipe sizes specified in AS 2419.1 do not apply; ■ Each fire hydrant head is located in accordance with E1.3 and fitted with a blank end cap or plug; ■ A hydrant booster inlet connection is provided in accordance with E1.3; ■ An external street or feed hydrant capable of providing the required system flow is located within 60 m of the hydrant booster connection.
Fire hose reels	<p>Fire hose reels shall be provided to non-residential areas in accordance with BCA 2019 (Amendment 1) Clause E1.4 and AS 2441-2005.</p>
Portable fire extinguishers	<p>Portable fire extinguishers shall be provided in accordance with BCA 2019 (Amendment 1) Clause E1.6 and AS 2444.</p>
Emergency lighting and exit signs	<p>Emergency lighting and exit signage shall be provided to building in accordance with BCA 2019 (Amendment 1) E4.2 and E4.5 respectively, and AS 2293.1.</p>
Maintenance	<p>A maintenance program shall be developed with all essential safety measures (active, passive and management) maintained in accordance with AS 1851 and AS 2293.2, and is to incorporate system interface testing, where relevant.</p>

3 Key Assumptions and Limitations

- This report is consistent with the fire safety provisions, objectives and limitations of the NCC 2019 (Amendment 1) - Building Code of Australia (BCA) Volume One:
 - All new works associated with the works comply with the current DtS provisions of the BCA except for any specific Performance Solution report carried out in addressing DtS non-compliances.
 - This report excludes the assessment and design against fires that include incendiary ones involving accelerants, explosives, multiple ignition sources, or acts of terrorism.
 - The concepts outlined in this report assume a complete and operational building, and do not address protection of the building during construction, renovation or demolition.
 - All of the fire safety systems are assumed to be designed, installed and operate in accordance with the appropriate Australian standards, other design codes, legislation and regulations relevant to the project unless specifically stated otherwise. All essential services equipment will be maintained, to the operational capacity to which they were designed, installed, commissioned and certified, in accordance with the manufacturer's instructions. As such, all essential services equipment and management plans, etc discussed within this report are assumed to function correctly during a fire situation.
 - Access and Egress provisions for persons with disabilities including compliance with the Disability Discrimination Act (DDA) are considered to the same degree as the BCA.
 - Unless stated otherwise, protection of property (other than within the subject property), business continuity, interruption or losses, environmental impacts, personal or moral obligations of the owner/occupier, reputation, amenity or non-fire related matters in the building such as health, security, energy efficiency, and occupational health & safety or the costs associated with any fire damages are specifically excluded from this analysis.
- **This report is not a Performance Solution Report.**
- This report is not a compliance or conformance audit for any fire safety system. For example, operational checks of fire safety equipment, verification of construction techniques, fire resistance levels or the witnessing of fire drills or exercises are specifically excluded from the scope of this report.
- The findings and outcomes of this report apply only to the subject building / works and must not be utilised for any other purpose. Any modifications, extensions, change of use, etc. to the building, fire safety measures or essential services equipment, from that described in this report may invalidate the findings, necessitating a re-assessment.

Appendix A Proposed Drawings

FOREST WAY



SITE PLAN

SCALE (METRES) 1:500 AT A3

TOTAL NUMBER OF **UNITS** 35
(12 x 2 BED, 23 x 3 BED)
TOTAL **CAR SPACES** - 72 SPACES
(DOUBLE GARAGES - 23)
(VISITOR SPACES - 17)
1x AMBULANCE & 1x SERVICE SRV VEHICLE

SITE AREA 10,854 sq.m. 50% = 5427 sq.m.
GROSS FLOOR AREA (LEP) 4805 sq.m.
FSR 0.44: 1

LANDSCAPE AREA 6304 sq.m. 62%

Basire RBI Pty Ltd 171 Forest Way BELROSE		Basire Requirements Summary - Multi Dwelling Prepared by Chapman Environmental Services www.basirecertificates.com.au 1300 004 914		CHAPMAN	
Water Target	40	Water Score	40		
Energy Target	35	Energy Score	35		
Max Heating Load (MJ/m²)	40	Actual Heating Load	25.8		
Max Cooling Load (MJ/m²)	26	Actual Cooling Load	17.1		
Basire Commitments					
Landscaping	Total area of garden & lawn (m²)	5958	Area of indigenous/low water use plants (m²)	1000	
Fixtures	Shower heads	3 star (> 4.5 but <= 6 L/min)	Toilets	4 star	All taps 4 star
Alternative Water	Minimum Rainwater tank size (L)	10000	Collect run off from roof area of at least (m²)		
	400				
Energy	Hot water system	Electric heat pump - air sourced	Rating	31 to 35 STCs	
	Bathroom ventilation	Individual fan, ducted to facade or roof	with	Manual switch on/off	
Energy	Kitchen ventilation	Individual fan, ducted to facade or roof	with	Manual switch on/off	
	Laundry ventilation	Individual fan, ducted to facade or roof	with	Manual switch on/off	
Energy	Cooling - living areas	3-phase airconditioning	Rating	EER 3.0 - 3.5	
	Cooling - bedrooms	3-phase airconditioning	Rating	EER 3.0 - 3.5	
Energy	Heating - living areas	3-phase airconditioning	Rating	EER 3.0 - 3.5	
	Heating - bedrooms	3-phase airconditioning	Rating	EER 3.0 - 3.5	
Energy	Alternate Energy	Photovoltaic system able to generate at least	15	peak kilowatts of electricity	
	Electric cooktop & electric oven	No outdoor clothesline required	No indoor clothesline required		
Thermal Performance Assessment Based on the Following Requirements					
Floor Types	Concrete slab on ground	with	No insulation required		
	Suspended concrete slab	with	R1.2 Foilboard insulation to Units above Basement carpark (U10: R1.9)		
Floor Coverings	Tiles	Wet Areas	Timber	Living & Bedrooms	
	Carpet	Nil	Concrete	Basement	
External Walls	75mm Hebel (AAC) on battens	with	Sarking and R2.5 bulk insulation	Colour	Medium
	Timber framed Metal clad	with	Sarking and R2.5 bulk insulation	Colour	Medium
Internal Walls	190mm Concrete block lined	with	Sarking and R2.5 bulk insulation	Colour	Medium
	90mm Blockwork	with	Nil		
Party Walls	Plasterboard	with	No insulation required		
	162mm AFS or similar	with	Nil		
Ceiling (floor over)	Concrete above plasterboard	with			
	Concrete above plasterboard	with	R3.5 Foilboard insulation		
Ceilings (roof over)	Timber above plasterboard	with	R3.5 bulk insulation		
	Concrete above plasterboard	with			
Roof	Concrete	0 degrees	with	Waterproof membrane only	Colour
	Metal	2 degrees	with	R1.3 roof blanket	Colour
Windows and Doors	AF single glazed clear Louvers	Group B ALM-002-01 U-Value 6.70 or less SHGC 0.70 +/- 5%			
	AF double glazed clear	Group A ALM-003-01 U-Value 4.80 or less SHGC 0.51 +/- 5%			
	AF double glazed LowE (U10: L3-SGD6), (U35: L9-SGD4, L9-SGD6)	Group B ALM-004-03 U-Value 4.30 or less SHGC 0.53 +/- 5%			
	Group A windows are Awning, Bifold, Casement or Tilt'n'turn	Group B ALM-004-04 U-Value 4.90 or less SHGC 0.33 +/- 5%			
Notes					
1. U7, U14, U29: 1 x 1200mm dia ceiling fan to Living Rm					
2. U33, U35: 1 x 1200mm dia ceiling fan to Living Room & Bedrooms					

LEGEND

ISSUE DATE AMENDMENTS



Barry Rush & Associates Pty Ltd

Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client

BELROSE PAVILIONS

Project
171 FOREST WAY
BELROSE

LOT 9 IN DP 737255

Drawing
SITE PLAN 1:250
1:500 @A3

Scale 1:250 Drawn BR

File DA Pavilions November 2021.dwg

Plotted 8/12/2021 10:10 AM

Job No 2101

Version DA Drawing No: A02

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.



LEGEND

ISSUE	DATE	AMENDMENTS
1	8/12/2021	Initial Issue

Barry Rush & Associates Pty Ltd
Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client
BELROSE PAVILIONS

Project
**171 FOREST WAY
BELROSE**

Lot 9 in DP 737255

Drawing
**LEVEL 1 FLOOR PLAN
1:200**

Scale	1:200	Drawn	BR
File	DA Pavilions November 2021	Drawn	BR
Plotted	8/12/2021 10:10 AM	Drawn	BR
Job No	2101	Drawn	BR
Version	DA	Drawn	BR

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.










LEVEL 5 FLOOR PLAN
GFA 571m²

FOREST WAY

STONE WALL TO FRONT BOUNDARY PP

ENTRY
EXIT



SCALE (METRES)



LEVEL 6 FLOOR PLAN

GFA 571m²

ISSUE DATE AMENDMENTS



Barry Rush & Associates Pty Ltd

Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client

BELROSE PAVILIONS

Project
171 FOREST WAY
BELROSE

LOT 9 IN DP 737255

Drawing
LEVEL 6 FLOOR PLAN
1:200

Scale 1:200 Drawn BR

File DA Pavilions November 2021 BRwg

Plotted 8/12/2021 10:10 AM

Job No 2102

Version DA Drawing No: A08

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.



ISSUE	DATE	AMENDMENTS
1	8/12/2021	Initial Issue

Barry Rush & Associates Pty Ltd
Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client
BELROSE PAVILIONS

Project
**171 FOREST WAY
BELROSE**

Lot 9 in DP 737255

Drawing
**LEVEL 7 FLOOR PLAN
1:200**

Scale	1:200	Drawn	BR
File	DA Pavilions Nov 2021	Drawn	BR
Plotted	8/12/2021 10:10 AM	Plotted	BR
Job No	2102	Job No	2102
Version	DA	Drawing No:	A09

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.

FOREST WAY



LEVEL 8 FLOOR PLAN

GFA 703m²

ISSUE	DATE	AMENDMENTS
1	8/12/2021	Initial Issue

Barry Rush & Associates Pty Ltd
Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client
BELROSE PAVILIONS


Project
**171 FOREST WAY
BELROSE**

Lot 9 in DP 737255


Drawing
**LEVEL 8 FLOOR PLAN
1:200**

Scale 1:200 Drawn BR
File DA Pavilions November 2021 ABWg
Plotted 8/12/2021 10:10 AM
Job No 2102
Version DA Drawing No: **A10**

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.



FOREST WAY



LEVEL 9 FLOOR PLAN

GFA 695m²

ISSUE	DATE	AMENDMENTS
1	8/12/2021	Initial Issue

Barry Rush & Associates Pty Ltd
Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client
BELROSE PAVILIONS

Project
**171 FOREST WAY
BELROSE**


LOT 9 IN DP 737255

Drawing
**LEVEL 9 FLOOR PLAN
1:200**

Scale	1:200	Drawn	BR
File	DA Pavilions November 2021	Drawn	BR
Plotted	8/12/2021 10:10 AM	Drawn	BR
Job No	2102	Drawn	BR
Version	DA	Drawn	BR

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.

FOREST WAY



ROOF PLAN

ISSUE	DATE	AMENDMENTS
1	8/12/2021	Initial Issue

Barry Rush & Associates Pty Ltd
Architects
Suite 25A, 2 Beattie Street, Balmain,
NSW, Australia, 2041
Phone: (612) 9555 8028 Fax: (612) 9810 0161
Email: info@barryrush.com.au
www.barryrush.com.au

Client
BELROSE PAVILIONS

Project
**171 FOREST WAY
BELROSE**

Lot 9 IN DP 737255

Drawing
**ROOF PLAN
1:200**

Scale	1:200	Drawn	BR
File	DA Pavilions November 2021	Checked	ABWg
Plotted	8/12/2021 10:10 AM		
Job No	2102		
Version	DA	Drawing No:	A12

© COPYRIGHT BR&A P/L
Do not scale off this drawing. Use figured dimensions only.
Verify all dimensions on site.