

## DEVELOPMENT APPLICATION ASSESSMENT REPORT

<b>Application Number:</b>	DA2019/0412
<b>Responsible Officer:</b>	Kelsey Wilkes
<b>Land to be developed (Address):</b>	Lot 18 DP 241941, 5 Tamworth Place ALLAMBIE HEIGHTS NSW 2100
<b>Proposed Development:</b>	Use of part of dwelling house as a secondary dwelling
<b>Zoning:</b>	Warringah LEP2011 - Land zoned R2 Low Density Residential
<b>Development Permissible:</b>	Yes
<b>Existing Use Rights:</b>	No
<b>Consent Authority:</b>	Northern Beaches Council
<b>Land and Environment Court Action:</b>	No
<b>Owner:</b>	Jennifer Robyn Mirabito
<b>Applicant:</b>	Jennifer Robyn Mirabito Richard Samuel Mirabito
<b>Application lodged:</b>	18/04/2019
<b>Integrated Development:</b>	No
<b>Designated Development:</b>	No
<b>State Reporting Category:</b>	Residential - New second occupancy
<b>Notified:</b>	08/05/2019 to 22/05/2019
<b>Advertised:</b>	Not Advertised
<b>Submissions Received:</b>	0
<b>Clause 4.6 Variation:</b>	Nil
<b>Recommendation:</b>	Approval
<b>Estimated Cost of Works:</b>	\$ 0.00

### ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral to relevant internal and external bodies in accordance with the Act, Regulations and relevant

Development Control Plan;

- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

## SUMMARY OF ASSESSMENT ISSUES

There are no assessment issues.

## SITE DESCRIPTION

<b>Property Description:</b>	Lot 18 DP 241941 , 5 Tamworth Place ALLAMBIE HEIGHTS NSW 2100
<b>Detailed Site Description:</b>	<p>The subject site consists of Lot 18 within DP 241941 allotment located on the southern side of Tamworth Place, Allambie Heights.</p> <p>The site is regular in shape with a frontage of 17.162m along Tamworth Place and a depth of 36.6m. The site has a surveyed area of 623.159m<sup>2</sup>.</p> <p>The site is located within the R2 Low Density Residential Zone and accommodates a two storey dwelling with an attached double garage below and in ground swimming pool at the rear of the property.</p> <p>The site falls approximately 5 meters from front to rear. Vegetation includes low lying shrubs with the rear of the property backing onto bushland.</p> <p><b>Detailed Description of Adjoining/Surrounding Development</b></p> <p>Adjoining and surrounding development is characterised by residential development including a mixture of one and two storey dwellings of varying age, size and architectural design.</p>

Map:



## SITE HISTORY

A search of Council's records has revealed that there are no recent or relevant applications for this site.

The land has been used for residential purposes for an extended period of time.

## PROPOSED DEVELOPMENT IN DETAIL

The application seeks consent for the use of an attached secondary dwelling measuring 75m<sup>2</sup>. The proposed secondary dwelling is located within the basement level of the existing two storey dwelling and will be accessible via a pathway along the north eastern boundary to a door at the rear. Access via the existing internal staircase will be cut off by a new fire rated and acoustic wall. The development does not propose any changes to the existing building footprint.

## ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

Section 4.15 Matters for Consideration'	Comments
Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument	See discussion on "Environmental Planning Instruments" in this report.
Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument	None applicable.
Section 4.15 (1) (a)(iii) – Provisions of any development control plan	Warringah Development Control Plan applies to this proposal.
Section 4.15 (1) (a)(iiia) – Provisions of any planning agreement	None applicable.
Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment	<u>Division 8A</u> of the EP&A Regulation 2000 requires the consent authority to consider "Prescribed conditions" of

Section 4.15 Matters for Consideration'	Comments
Regulation 2000 (EP&A Regulation 2000)	<p>development consent. These matters have been addressed via a condition of consent.</p> <p><u>Clause 50(1A)</u> of the EP&amp;A Regulation 2000 requires the submission of a design verification certificate from the building designer at lodgement of the development application. This clause is not relevant to this application.</p> <p><u>Clauses 54 and 109</u> of the EP&amp;A Regulation 2000, Council requested additional information and has therefore considered the number of days taken in this assessment in light of this clause within the Regulations. No additional information was requested.</p> <p><u>Clause 92</u> of the EP&amp;A Regulation 2000 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This clause is not relevant to this application.</p> <p><u>Clauses 93 and/or 94</u> of the EP&amp;A Regulation 2000 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This matter has been addressed via a condition of consent.</p> <p><u>Clause 98</u> of the EP&amp;A Regulation 2000 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.</p> <p><u>Clause 98</u> of the EP&amp;A Regulation 2000 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.</p> <p><u>Clause 143A</u> of the EP&amp;A Regulation 2000 requires the submission of a design verification certificate from the building designer prior to the issue of a Construction Certificate. This clause is not relevant to this application.</p>
Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in the locality	<p>(i) <b>Environmental Impact</b> The environmental impacts of the proposed development on the natural and built environment are addressed under the Warringah Development Control Plan section in this report.</p> <p>(ii) <b>Social Impact</b> The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.</p>

Section 4.15 Matters for Consideration'	Comments
	(iii) <b>Economic Impact</b> The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.
Section 4.15 (1) (c) – the suitability of the site for the development	The site is considered suitable for the proposed development.
Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs	See discussion on “Notification & Submissions Received” in this report.
Section 4.15 (1) (e) – the public interest	No matters have arisen in this assessment that would justify the refusal of the application in the public interest.

## EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

## BUSHFIRE PRONE LAND

The site is classified as bush fire prone land. Section 4.14 of the Environmental Planning and Assessment Act 1979 requires Council to be satisfied that the development conforms to the specifications and requirements of the version (as prescribed by the regulations) of the document entitled Planning for Bush Fire Protection.

A Bush Fire Report was submitted with the application that included a certificate (prepared by Bushfire Planning and Design, dated 8 April 2019) stating that the development conforms to the relevant specifications and requirements within Planning for Bush Fire Protection. The recommendations of the Bush Fire Report have been included as conditions of consent.

## NOTIFICATION & SUBMISSIONS RECEIVED

The subject development application has been publicly exhibited in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2000 and the relevant Development Control Plan.

As a result of the public exhibition of the application Council received no submissions.

## REFERRALS

Internal Referral Body	Comments
Building Assessment - Fire and Disability upgrades	

External Referral Body	Comments
Ausgrid: (SEPP Infra.)	The proposal was referred to Ausgrid. No response has been received within the 21 day statutory period and therefore, it is assumed that no objections are raised and no conditions are recommended.
NSW Rural Fire Service –	The NSW RFS has recommended this development for approval,



External Referral Body	Comments
local branch (s79BA EPAA)	subject to conditions. The conditions of this report are to be read in conjunction with the conditions of consent.

## **ENVIRONMENTAL PLANNING INSTRUMENTS (EPIS)\***

All, Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

## **State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)**

### **SEPP 19 - Bushland in Urban Areas**

The provisions of the SEPP require that a person shall not disturb bushland zoned or reserved for public open space purposes without the consent authority considering the aims and objectives of the SEPP.

In this regard, consideration is given as follows:

(1) The general aim of this Policy is to protect and preserve bushland within the urban areas referred to in Schedule 1 because of:

- (a) its value to the community as part of the natural heritage,
- (b) its aesthetic value, and
- (c) its value as a recreational, educational and scientific resource.

(2) The specific aims of this policy are:

- (a) to protect the remnants of plant communities which were once characteristic of land now within an urban area,
- (b) to retain bushland in parcels of a size and configuration which will enable the existing plant and animal communities to survive in the long term,
- (c) to protect rare and endangered flora and fauna species,
- (d) to protect habitats for native flora and fauna,
- (e) to protect wildlife corridors and vegetation links with other nearby bushland,
- (f) to protect bushland as a natural stabiliser of the soil surface,
- (g) to protect bushland for its scenic values, and to retain the unique visual identity of the landscape,
- (h) to protect significant geological features,
- (i) to protect existing landforms, such as natural drainage lines, watercourses and foreshores,
- (j) to protect archaeological relics,
- (k) to protect the recreational potential of bushland,
- (l) to protect the educational potential of bushland,
- (m) to maintain bushland in locations which are readily accessible to the community, and
- (n) to promote the management of bushland in a manner which protects and enhances the quality of

the bushland and facilitates public enjoyment of the bushland compatible with its conservation.”

Comment:

The proposal makes no structural changes to the footprint of the existing dwelling and does not impact upon any aims of the policy. Overall, the proposal is considered to have minimal impact when considering the aims of this policy.

Based on the above, it is considered that the development would result in consistency with the aims of the plan.

## SEPP (Affordable Rental Housing) 2009

State Environmental Planning Policy (Affordable Rental Housing) 2009 (SEPP ARH) aims to provide new affordable rental housing and retain and mitigate any loss of existing affordable rental housing by providing a consistent planning regime. Specifically, SEPP ARH provides for new affordable rental housing by offering incentives such as expanded zoning permissibility, floor space ratio bonuses and non-discretionary development standards.

### Division 2: Secondary dwellings

#### Clause 19: Definition

Development for the purposes of a secondary dwelling includes the following:

- (a) the erection of, or alterations or additions to, a secondary dwelling,
- (b) alterations or additions to a principal dwelling for the purposes of a secondary dwelling.

**Note:** The standard instrument defines secondary dwelling as follows:

**"secondary dwelling means a self-contained dwelling that:**

- (a) is established in conjunction with another dwelling (the principal dwelling), and
- (b) is on the same lot of land (not being an individual lot in a strata plan or community title scheme) as the principal dwelling, and
- (c) is located within, or is attached to, or is separate from, the principal dwelling."

Comment:

The proposed use is defined under WLEP 2011 as 'secondary dwelling' and is defined under the WLEP 2011 as above.

#### Clause 20: Land to which this Division applies:

Requirement	Comment
This Division applies to land within any of the following land use zones or within a land use zone that is equivalent to any of those zones, but <i>only if</i> development for the purposes of a dwelling house is permissible on the land:	
(a) Zone R1 General Residential, or (b) Zone R2 Low Density Residential, or (c) Zone R3 Medium Density Residential, or	<b>Consistent.</b> The site is located within the R2 Low Density Residential Zone and, as such, the proposed use

(d) Zone R4 High Density Residential, or (e) Zone R5 Large Lot Residential.	is permissible with consent under WLEP 2011.
--	--

Clause 21: Development to which this Division applies

Requirement	Comment
This Division applies to development, on land to which this Division applies, for the purposes of a secondary dwelling.	<b>Consistent.</b> The development involves the construction of a secondary dwelling, as defined by the Standard Instrument. Therefore, this Division applies.

Clause 22: Development may be carried out with consent

Development to which this Division applies may be carried out with consent.

Requirement	Comment
(2) A consent authority must not consent to development to which this Division applies if there is on the land, or if the development would result in there being on the land, any dwelling other than the principal dwelling and the secondary dwelling.	The land will contain only the principal dwelling and the attached secondary dwelling.
(3) A consent authority must not consent to development to which this Division applies unless:  (a) the total floor area of the principal dwelling and the secondary dwelling is no more than the maximum floor area allowed for a dwelling house on the land under another environmental planning instrument, and  (b) the total floor area of the secondary dwelling is no more than 60m <sup>2</sup> or, if a greater floor area is permitted in respect of a secondary dwelling on the land under another environmental planning instrument, that greater floor area.	(a) There is no maximum floor area that applies to land under the WLEP 2011.  (b) The secondary dwelling meets the exception for the purposes of secondary dwellings in Zones R2 and R3 as per the WLEP 2011 which states: <i>Despite clause 5.4 (9), development consent may be granted for development for the purposes of a secondary dwelling on land to which this clause applies if:</i>  <i>(a) the total floor area of the secondary dwelling does not exceed 75 square metres, and</i>  <i>(b) the consent authority is satisfied that the secondary dwelling will be located entirely within an existing principal dwelling that contains no other secondary dwelling.</i>  The secondary dwelling measures 75m <sup>2</sup> and is located entirely within the existing principal dwelling which contains no other secondary dwelling.
(4) A consent authority must not refuse consent to development to which this Division applies on either of the following grounds:  (a) site area if:	(a)(i) the secondary is located within the principal dwelling (ii) the site area is greater than 450m <sup>2</sup>  (b) no additional parking is proposed as a result of the secondary dwelling



- (i) the secondary dwelling is located within, or is attached to, the principal dwelling, or  
(ii) the site area is at least 450 square metres.
- (b) parking if no additional parking is to be provided on the site.

**Note:** A consent authority may consent to development to which this Division applies whether or not the development complies with the standards set out in subclause (4).

#### Clause 24: No subdivision

Requirement	Comment
A consent authority must not consent to a development application that would result in any subdivision of a lot on which development for the purposes of a secondary dwelling has been carried out under this Division.	<b>Consistent.</b> This application does not propose any subdivision of the existing allotment.

#### Conclusion

The development meets the requirements of the SEPP (Affordable Rental Housing) 2009, along with the requirements of the Warringah LEP 2011 and Warringah DCP 2011. Therefore, the development is supported.

### **Sydney Regional Environmental Plan (Sydney Harbour Catchment) 2005**

The subject property is located within the Sydney Harbour Catchment therefore the provisions of this plan apply to this development.

An assessment of the proposal against Clause 2(1) (aims of the SREP), Clause 13 (nominated planning principles) and Clause 21 (relating to biodiversity, ecology and environmental protection) has been undertaken. The proposal is considered to be consistent with the above provisions of the SREP. Given the scale of the proposed modification and the works proposed referral to the Foreshores and Waterways Planning and Development Advisory Committee was not considered necessary.

### **Warringah Local Environmental Plan 2011**

Is the development permissible?	Yes
After consideration of the merits of the proposal, is the development consistent with:	
aims of the LEP?	Yes
zone objectives of the LEP?	Yes

#### Compliance Assessment

Clause	Compliance with Requirements

Clause	Compliance with Requirements
5.8 Conversion of fire alarms	Yes
6.4 Development on sloping land	Yes

## Warringah Development Control Plan

### Compliance Assessment

Clause	Compliance with Requirements	Consistency Aims/Objectives
A.5 Objectives	Yes	Yes
C2 Traffic, Access and Safety	Yes	Yes
C3 Parking Facilities	Yes	Yes
C9 Waste Management	Yes	Yes
D3 Noise	Yes	Yes
D8 Privacy	Yes	Yes
D10 Building Colours and Materials	Yes	Yes
D20 Safety and Security	Yes	Yes
E8 Waterways and Riparian Lands	Yes	Yes

## THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly effect threatened species, populations or ecological communities, or their habitats.

## CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

## POLICY CONTROLS

### Northern Beaches Section 7.12 Contributions Plan 2019

S7.12 levies are not applicable to this application as they were subject to the original development application relating to the whole site.

## CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2000;
- All relevant and draft Environmental Planning Instruments;
- Warringah Local Environment Plan;
- Warringah Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

## RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2019/0412 for Use of part of dwelling house as a secondary dwelling on land at Lot 18 DP 241941, 5 Tamworth Place, ALLAMBIE HEIGHTS, subject to the conditions printed below:

## DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

### 1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

#### a) Approved Plans

Architectural Plans - Endorsed with Council's stamp		
Drawing No.	Dated	Prepared By
Sheet 1 Drawing No. 5A - Secondary dwelling at basement level	27 March 2019	Peter Formosa
Sheet 2 Drawing No. 5A - Existing ground floor and upper floor plan	27 March 2019	Peter Formosa
Sheet 3 Drawing No. 5A - Basement level floor plan and eastern elevation	27 March 2019	Peter Formosa
Sheet 4 Drawing No. 5A - Elevations	27 March 2019	Peter Formosa

Reports / Documentation – All recommendations and requirements contained within:		
Report No. / Page No. / Section No.	Dated	Prepared By
Fire Engineering Report - Reference no.	12 March 2019	MCD Engineering

S19019		
Bushfire Report - Reference no. 2485	8 April 2019	BPAD Bushfire Planning and Design

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

## 2. **Compliance with Other Department, Authority or Service Requirements**

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

Other Department, Authority or Service	Reference No.	Dated
NSW Rural Fire Service	D19/1443 DA19050218499 PE	29 May 2019

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other Department, Authority or Body's.

## 3. **Prescribed Conditions**

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
  - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
  - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
  - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.
- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
  - (i) in the case of work for which a principal contractor is required to be appointed:
    - A. the name and licence number of the principal contractor, and
    - B. the name of the insurer by which the work is insured under Part 6 of that Act,
  - (ii) in the case of work to be done by an owner-builder:

- A. the name of the owner-builder, and
- B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
  - (i) protect and support the adjoining premises from possible damage from the excavation, and
  - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
  - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
  - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative Requirement

#### 4. **General Requirements**

- (a) Unless authorised by Council:  
Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (c) Where demolition works have been completed and new construction works have not

commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.

- (d) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (e) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (f) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (g) No building, demolition, excavation or material of any nature and no hoist, plant and machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (h) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (i) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (j) Prior to the commencement of any development onsite for:
  - i) Building/s that are to be erected
  - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
  - iii) Building/s that are to be demolished
  - iv) For any work/s that is to be carried out
  - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (k) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
  - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2008
- (iv) Australian Standard AS1926 Swimming Pool Safety



- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### 5. **Fire Safety Upgrade**

The Building Code of Australia works and fire upgrading measures to upgrade the building as detailed and recommended in the BCA Assessment Report prepared by GRS Building Reports P/L, dated 29 March 2019, Report Ref No. 2018/W748 are to be carried out to the building. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety

### 6. **Compliance with Standards**

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

In signing this report, I declare that I do not have a Conflict of Interest.

**Signed**



**Kelsey Wilkes, Planner**

The application is determined on 29/07/2019, under the delegated authority of:



**Alex Keller, Acting Development Assessment Manager**