

Engineering Referral Response

Application Number:	DA2020/0199
Date:	24/03/2020
To:	Penny Wood
Land to be developed (Address):	Lot 9 DP 271139 , 19 Bubalo Street WARRIEWOOD NSW 2102

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

No objections to the dwelling subject to conditions.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Rainwater Reuse Tank -Stormwater Drainage

A 4000 litre rainwater tank for non-potable purposes is to be installed and used as part of an integrated on-site Stormwater management system in accordance with Development Consent N0491/16.

The non-potable purposes are prescribed in the NSW Code of Practice for Plumbing and Drainage and

include toilet flushing, garden irrigation, car washing and cold water laundry.

Stormwater drainage plans are in accordance with the concept plans prepared by ALW Design Drw No SW20004-S1 are to be approved by the certifying authority prior to the issue of the construction certificate.

Reason: To ensure the stormwater management is implemented for the development.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Stormwater Disposal

The Applicant shall submit a certificate from a suitably qualified person that the stormwater drainage works have been constructed/installed in accordance with all relevant Australian Standards and Codes.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

Traffic Control During Road Works

Lighting, fencing, traffic control and advanced warning signs shall be provided for the protection of the works and for the safety and convenience of the public and others in accordance with RMS Traffic Control At Work Sites Manual (<http://www.rms.nsw.gov.au/business-industry/partners-suppliers/documents/technical-manuals/tcws-version-4/tcwsv4i2.pdf>) and to the satisfaction of the Roads Authority. Traffic movement in both directions on public roads, and vehicular access to private properties is to be maintained at all times during the works

Reason: Public Safety.