page 1/7

BASIX Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A420565

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretarv

Date of issue: Wednesday, 16, June 2021 To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning, Industry & Environment

| Project address | |
|-----------------------|----------------------------------|
| Project name | Mr & Mrs Evans |
| Street address | 16 Apara Street FORESTVILLE 2087 |
| Local Government Area | Northern Beaches Council |
| Plan type and number | Deposited Plan 251817 |
| Lot number | 9 |
| Section number | |
| Project type | |
| Dwelling type | Separate dwelling house |
| 0) 1 | |

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: JAH Design Services

ABN (if applicable): 22630690834

| Fixtures and systems | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------------|--------------------|
| Lighting | | | |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps. | | ~ | ~ |
| Fixtures | | | |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating. | | \checkmark | |

| Construction | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|--|---------------------------------|---------------------|---------------------------------------|--------------------|
| Insulation requirements | | | | | |
| The applicant must construct the new or alter the table below, except that a) additional insu is not required for parts of altered construction | ~ | ~ | ~ | | |
| Construction | Additional insulation required (R-value) | Other specifications | | | |
| concrete slab on ground floor. | nil | | | | |
| suspended floor above garage: framed (R0.7). | nil | | | | |
| external wall: brick veneer | R1.16 (or R1.70 including construction) | | | | |
| flat ceiling, pitched roof | ceiling: R1.45 (up), roof: foil backed blanket (55 mm) | dark (solar absorptance > 0.70) | | | |

| Glazing rec | quirements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|-----------------------------------|---|---------------------------|-----------------------------|--|--|----------------------|---------------------------------------|--------------------|
| Windows ar | nd glazed do | oors | | | | | | | I |
| | | | | | hading devices, in accordance with r each window and glazed door. | the specifications listed in the table below. | ~ | ~ | ~ |
| The following | requirements | must also | be satisfi | ed in relatior | n to each window and glazed door: | | | \checkmark | \checkmark |
| have a U-valu | ue and a Solai | r Heat Gair | n Coefficie | ent (SHGC) r | | d glass may either match the description, or, le below. Total system U-values and SHGCs s. | | ~ | ~ |
| have a U-valu must be calcu | ue and a Solar ulated in accor | r Heat Gair rdance with | n Coefficie n National | ent (SHGC) r Fenestratio | no greater than that listed in the tab | ar glazing, or toned/air gap/clear glazing must le below. Total system U-values and SHGCs s. The description is provided for information | | ~ | ~ |
| For projections described in millimetres, the leading edge of each eave, pergola, verandah, balcony or awning must be no more than 500 mm above the head of the window or glazed door and no more than 2400 mm above the sill. | | | | | | ~ | | ~ | |
| Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35. | | | | | | | ~ | \checkmark | |
| Pergolas with fixed battens must have battens parallel to the window or glazed door above which they are situated, unless the pergola also shades a perpendicular window. The spacing between battens must not be more than 50 mm. | | | | | | | ~ | ~ | |
| Windows a | and glazed | doors g | lazing r | equireme | nts | | | | |
| Window / doo no. | or Orientation | n Area of glass inc. frame (m2) | Oversha Height (m) | dowing Distance (m) | Shading device | Frame and glass type | | | |
| W1 | W | 2.88 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| W2 | W | 2.88 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| W3 | S | 1.35 | 0 | 0 | eave/verandah/pergola/balcony >=450 mm | standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75) | | | |

| Glazing red | quirements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|-------------|----------------|--------------------------------|---------------|-----------------|---|---|---------------------|---------------------------------------|--------------------|
| Window / do | or Orientation | | Oversha | adowing | Shading device | Frame and glass type | | | |
| no. | | glass inc. frame (m2) | Height (m) | Distance (m) | | | | | |
| W4 | S | 1.08 | 0 | 0 | eave/verandah/pergola/balcony >=450 mm | standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75) | | | |
| W5 | S | 1.08 | 0 | 0 | eave/verandah/pergola/balcony >=450 mm | standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75) | | | |
| W6 | S | 4.32 | 0 | 0 | eave/verandah/pergola/balcony >=450 mm | standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75) | | | |
| W7 | E | 4.32 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47) | | | |
| W8 | E | 4.32 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47) | | | |
| W9 | E | 3.6 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47) | | | |
| W10 | N | 1.08 | 0 | 0 | eave/verandah/pergola/balcony >=450 mm | standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47) | | | |
| W11 | W | 4.2 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| W12 | W | 1.44 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| W13 | W | 1.44 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| D1 | W | 2.6 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | timber or uPVC, single clear, (or U-value: 5.71, SHGC: 0.66) | | | |
| D2 | N | 14.52 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75) | | | |

| Glazing require | ements | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|------------------------------------|----------------------------------|---|---------------------|---------------------------------------|--------------------|
| The applicant mus | st install the skylight | s in accordance with the specifi | cations listed in the table below. | \checkmark | \checkmark | ~ |
| The following requirements must also be satisfied in relation to each skylight: | | | | | \checkmark | \checkmark |
| Each skylight may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. | | | | | | ~ |
| Skylights glaz | ing requiremer | its | | | | |
| Skylight number | Area of glazing inc. frame (m2) | Shading device | Frame and glass type | | | |
| S1 | 1.092 | no shading | timber, double clear/air fill, (or U-value: 4.3, SHGC: 0.5) | | | |
| S2 | 0.764 | no shading | timber, double clear/air fill, (or U-value: 4.3, SHGC: 0.5) | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " / " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "
"
"
"
"
"
"
"
"
"
"
"
"
Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a " / " in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.