

## Engineering Referral Response

<b>Application Number:</b>	Mod2021/0586
<b>Date:</b>	13/09/2021
<b>To:</b>	Gareth David
<b>Land to be developed (Address):</b>	Lot 309 DP 858106 , 6 Prosperity Parade WARRIEWOOD NSW 2102

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

#### 13/09/20/21:

No objections are raised to the proposed modification. No modification to Development Engineering conditions required.

Existing Development Engineering conditions for DA2018/0504 are considered to still be relevant and adequate.

The proposal is therefore supported

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Engineering Conditions:

Nil.