

Building Assessment Referral Response

Application Number:	DA2022/1574
Date:	01/12/2022
To:	Grace Facer
Land to be developed (Address):	Lot CP SP 98951 , 10 Golf Parade MANLY NSW 2095

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Fire Separation of External Walls

The external walls of the subject building where less than 900mm from an allotment boundary or less than 1.8 m from another building on the same allotment and any openings within these walls are required to comply with Part 3.7.2.4 of the Building Code of Australia – 'Construction of external walls'.

Note: The adjacent garage is a Class 7a structure and does not form part of Lot 6. It is Common Property.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety.