

# Landscape Referral Response

Application Number:	DA2020/1192
Date:	11/11/2020
Responsible Officer:	Gareth David
Land to be developed (Address):	Lot 3 DP 238000 , 23 Calool Crescent BELROSE NSW 2085

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc).
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

#### Officer comments

No significant landscape features are indicated by the plans to be affected by the proposed works. The DA is considered acceptable with regard to the relevant controls relating to landscape issues, subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

#### **Recommended Landscape Conditions:**

## CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

## Tree protection

- (a) Existing trees which must be retained
- i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
  - ii) Trees located on adjoining land
- (b) Tree protection
  - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
  - ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
  - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
  - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause
  - E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
  - v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

DA2020/1192 Page 1 of 1