

Engineering Referral Response

| Application Number: | DA2024/0537 |
|---------------------------------|--|
| Proposed Development: | Construction of a swimming pool |
| Date: | 24/07/2024 |
| То: | Reeve Cocks |
| Land to be developed (Address): | Lot 2 DP 1272873, 31 B Bennett Street CURL CURL NSW 2096 |

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

Development is unsupported.

Council's records indicate that thesite is burdened by a Council's stormwater pipeline traversing the site. This is shown on Council's stormwater map which is available on the webpage https://services.northernbeaches.nsw.gov.au/icongis/index.html

- To demonstrate compliance with Council's Water Management for Development policy, it is recommended that the following details are submitted with any application:
 - o Accurately locate, confirm dimensions including depth and plot to scale Council's public drainage system and associated infrastructure on the DA site plans that outline the proposal. This should be carried out by a service locating contractor and registered surveyor. (Evidence of methodology used for locating stormwater system should be provided);
 - If the applicant proposes to use a CCTV pipeline survey to confirm the location of the pipeline, it is recommended that the survey is carried out in accordance with Council's quideline.

DA2024/0537 Page 1 of 3



- o All structures are to be located clear of any Council pipeline, pit or easement and comply with minimum vertical and horizontal clearances.
- o Footings of any structure adjacent to an easement, pipeline, culvert or channel are to be designed in accordance with the above-mentioned policy; and
- o Structural details prepared by a suitably qualified Civil Engineer demonstrating compliance with Council's policy are to be submitted
- Plans and sections showing the offsets between the existing Council pipeline and the proposed pool are to be provided.

No plans have been provided and the application is therefore unsupported.

Additional Information Provided on 1/7/2024

Amended plans showing the Council asset location has been reviewed. No objections to approval subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

FEES / CHARGES / CONTRIBUTIONS

Construction, Excavation and Associated Works Security Bond(s)

The applicant is to lodge a bond with Council for the following:

Drainage Works

As security against any damage to Council's stormwater drainage assets as part of this consent a bond of \$4000.

Details confirming payment of the bond(s) are to be submitted to the Principal Certifier prior to the issue of the Construction Certificate.

Reason: Protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Pre-Construction Stormwater Assets Dilapidation Report

The Applicant is to submit a pre-construction / demolition Dilapidation Survey of Council's Stormwater Assets prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset, to record the existing condition of the asset prior to the commencement of works. Council's Guidelines are available

at: https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-

DA2024/0537 Page 2 of 3



specifications/2009084729guidelineforpreparingadilapidationsurveyofcouncilstormwaterassets2.pdf

The pre-construction / demolition Dilapidation Report must be submitted to Council for approval and the Principal Certifier prior to the issue of the Construction Certificate.

Reason: Protection of Council's infrastructure.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Post- Construction Stormwater Assets Dilapidation Report (Council stormwater assets)

The Applicant shall submit a post-construction Dilapidation Survey of Council's Stormwater Assets is to be prepared by a suitably qualified person in accordance with Council's Guidelines for Preparing a Dilapidation Survey of Council Stormwater Asset in order to determine if the asset has been damaged by the works. Council's Guidelines are available at

https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/general-information/engineering-specifications/preparingdilapidationsurveyforcouncilstormwaterassets.pdf

The post-construction / demolition dilapidation report must be submitted to Council for review and approval. Any damage to Council's stormwater infrastructure is to be rectified prior to the release of any Drainage security bonds. Council's acceptance of the Dilapidation Survey is to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: Protection of Council's infrastructure.

DA2024/0537 Page 3 of 3